

GENERAL NOTES



A-1,3,5
B a

A-1,3,5, ADJACENT TO ARROW INDICATES HOMERUN OF CIRCUITS 1,3,5 TO PANEL A. MARKS ACROSS RACEWAY RUNS INDICATE THE NUMBER OF #12 AWG CONDUCTORS. UNLESS NOTED NO MARKS INDICATE TWO #12 AWG CONDUCTORS. MULTI-WIRE BRANCH CIRCUITS SHALL BE PROVIDED WITH DEDICATED NEUTRALS PER PHASE; DO NOT SHARE NEUTRAL CONDUCTORS.

NUMERAL AND LOWER CASE LETTER INDICATES CIRCUIT CONNECTION AND SWITCH LEG DESIGNATION RESPECTIVELY. UPPER CASE LETTER INDICATES FIXTURE TYPE.

NOTES:

- ALL SYMBOLS INDICATED IN THIS LEGEND MAY NOT BE USED ON THE PLANS.
- DIMENSIONS INDICATED IN LEGEND ARE TO CENTER OF OUTLET OR EQUIPMENT, UNLESS OTHERWISE INDICATED. DIMENSIONS INDICATED ARE TO COMPLY WITH ACCESSIBILITY CODE(S).
- REFER TO SPECIFICATIONS FOR FINISH COLOR/TYPE OF DEVICES AND DEVICE PLATES; WHERE NOT INDICATED IN SPECIFICATIONS, CONFIRM FINISH REQUIREMENTS WITH ARCHITECT OR OWNER.
- REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT LOCATION OF LIGHTING FIXTURES.

SYMBOL LEGEND - RACEWAY

| | |
|--|--|
| | RACEWAY INSTALLED EXPOSED ON WALLS AND/OR ON CEILING. |
| | RACEWAY INSTALLED CONCEALED IN WALLS AND/OR ABOVE CEILING. |
| | RACEWAY INSTALLED CONCEALED BELOW FLOOR, SLAB, OR GRADE. |

SYMBOL LEGEND - SYSTEMS

| | |
|--|--|
| | RECESSED/FLUSH FLOOR BOX WITH UTILITIES INDICATED. INSTALLATION MAY REQUIRE POKE-THRU OR FLUSH MOUNTED BOX, REFER TO NOTES ON DRAWINGS OR SPECIFICATIONS. |
| | VOICE/DATA OUTLET 18" A.F.F. - 4"x4" BOX, PLASTER RING, AND 1" CONDUIT FROM BOX TO ACCESSIBLE CEILING, NETWORK CABLING AS SPECIFIED OR AS INDICATED. "X" INDICATES QUANTITY OF CONNECTIONS/CABLES PER OUTLET. NO "X" INDICATES (2) CONNECTIONS/CABLES, UNLESS OTHERWISE INDICATED. |
| | VOICE/DATA OUTLET CEILING MOUNTED - 4"x4" BOX, PLASTER RING, AND 1" CONDUIT FROM BOX TO ACCESSIBLE CEILING, NETWORK CABLING AS SPECIFIED OR AS INDICATED. "X" INDICATES QUANTITY OF CONNECTIONS/CABLES PER OUTLET. NO "X" INDICATES (1) CONNECTIONS/CABLE, UNLESS OTHERWISE INDICATED. |
| | TELEPHONE (ANALOG) OUTLET 18" A.F.F. - 4"x4" BOX, PLASTER RING, AND 1" CONDUIT FROM BOX TO ACCESSIBLE CEILING, CABLING AS SPECIFIED OR AS INDICATED. |
| | AUDIO/VISUAL BOX - 4"x4" BOX, PLASTER RING, AND 1" CONDUIT FROM BOX TO ACCESSIBLE CEILING, CABLING IS PROVIDED BY OTHERS. COORDINATE EXACT REQUIREMENTS WITH LOW VOLTAGE CONTRACTOR AND LOW VOLTAGE "AV" DRAWINGS. |

SYMBOL LEGEND - POWER


| | |
|--|--|
| | MECHANICAL EQUIPMENT TAG - REFER TO MECHANICAL EQUIPMENT ELECTRICAL CONNECTION SCHEDULE FOR ADDITIONAL INFORMATION AND BRANCH CIRCUIT REQUIREMENTS. |
| | PANELBOARD - FLUSH OR SURFACE MOUNTED, VOLTAGE AS INDICATED IN SCHEDULE. |
| | DISCONNECT SWITCH - RATING/POLES/ENCLOSURE/FUSING AS INDICATED. (EXAMPLE 30/3/30/1F) |
| | WEATHER PROOF ENCLOSURE PROVIDED FOR DEVICE OR EQUIPMENT. |
| | DUPLEX RECEPTACLE - 18" A.F.F. OR AT HEIGHT INDICATED. NEMA-5-20 |
| | DOUBLE DUPLEX RECEPTACLE - 18" A.F.F. OR AT HEIGHT INDICATED |
| | DUPLEX 20A GROUND FAULT CIRCUIT INTERRUPTER RECEPTACLE - 18" A.F.F., OR AT HEIGHT INDICATED. |
| | DOUBLE DUPLEX 20A GROUND FAULT CIRCUIT INTERRUPTER RECEPTACLE - 18" A.F.F., OR AT HEIGHT INDICATED. |
| | DUPLEX 20A RECEPTACLE - XX A.F.F. AS NOTED ON PLANS |
| | JUNCTION BOX - CEILING/WALL/FLOOR MOUNTED |
| | CENTER SHADING INDICATES OUTLET TO BE INSTALLED ABOVE COUNTER TOPS. INSTALL DEVICES HORIZONTALLY ABOVE COUNTER TOP AND/OR BACK SPLASH, UNLESS INDICATED ON ARCHITECTURAL DRAWINGS. COORDINATE ALL LOCATIONS WITH ARCHITECTURAL DETAILS AND ELEVATIONS. MAXIMUM OUTLET HEIGHT SHALL BE 46" TO CENTERLINE OF OUTLET PER ADA ADULT OBSTRUCTED REACH REQUIREMENTS. |
| | SPECIAL RECEPTACLE AS NOTED - 18" A.F.F., UNLESS OTHERWISE NOTED |
| | MOTORIZED DAMPER 120V POWER CONNECTION. DIV 26 TO PROVIDE 4"x4" DEVICE BOX WITH 20A TOGGLE SWITCH FOR LOCAL DISCONNECT AND FLEX CONNECTION TO CONTROL POWER TRANSFORMER SUPPLIED BY DIV 23. PROVIDE 120V CONNECTION FROM NEAREST VAV OR PIU CIRCUIT. |
| | MOTOR - SEE AS INDICATED |
| | GROUND ROD |

SYMBOL LEGEND - LIGHTING

| | |
|--|--|
| | CEILING BOX AND FLUORESCENT LIGHTING FIXTURE (HALF SHADED INDICATES EMERGENCY FIXTURE, REFER TO LIGHTING FIXTURE SCHEDULE FOR EMERGENCY BACK-UP) |
| | WALL BOX AND FLUORESCENT 1x4" FIXTURE |
| | CEILING OUTLET AND FLUORESCENT 4-0" FIXTURE (SHADED INDICATES EMERGENCY FIXTURE, REFER TO LIGHTING FIXTURE SCHEDULE FOR EMERGENCY BACK-UP) |
| | DOWNLIGHT FIXTURE (SHADED INDICATES EMERGENCY FIXTURE, REFER TO LIGHTING FIXTURE SCHEDULE FOR EMERGENCY BACK-UP) |
| | WALL OUTLET AND FIXTURE |
| | CEILING OR WALL MOUNTED EXIT SIGN. ARROWS DENOTE DIRECTION OF EGRESS |
| | FLOOD/SPOT OR TRACK MOUNTED FIXTURE |
| | LIGHTING TRACK |
| | SINGLE POLE TOGGLE SWITCH - 48" A.F.F. |
| | OCCUPANCY SENSOR SWITCH - 48" A.F.F. |
| | MECHANICALLY OPERATED TIMER SWITCH WITH BYPASS OVERRIDE - 48" A.F.F. |
| | OCCUPANCY SENSOR - CEILING MOUNTED |
| | POWER PACK |
| | THREE-WAY TOGGLE SWITCH - 48" A.F.F. |
| | LOW VOLTAGE LIGHT SWITCH |

FIRE ALARM SYMBOLS LEGEND

| | |
|--|---|
| | FIRE ALARM CONTROL PANEL. |
| | FIRE ALARM REMOTE ANNUNCIATOR PANEL, ALPHA-NUMERIC DISPLAY TYPE. |
| | FIRE ALARM REMOTE POWER SUPPLY. |
| | FIRE ALARM SYSTEM DUCT MOUNTED SMOKE DETECTOR REMOTE STATION. |
| | FIRE ALARM SYSTEM ADDRESSABLE INPUT - SUPERVISORY OR ALARM INPUT AS NOTED. |
| | FIRE ALARM SYSTEM ADDRESSABLE OUTPUT. |
| | VALVE TAMPER SWITCH - REFER TO FIRE PROTECTION FOR EXACT LOCATIONS. |
| | FLOW SWITCH - REFER TO FIRE PROTECTION FOR EXACT LOCATIONS. |
| | FIRE ALARM POST INDICATOR VALVE TAMPER SWITCH. |
| | FIRE FIGHTER'S TWO-WAY COMMUNICATION PHONE |
| | FIRE ALARM ANNUNCIATOR PANEL |
| | DOOR HOLD OPEN DEVICE - INTERCONNECT WITH FIRE ALARM SYSTEM, COORDINATE WITH DIVISION 8. |
| | FIRE ALARM SYSTEM SMOKE DETECTOR (P = PHOTOELECTRIC, I = IONIZATION, BLANK = SINGLE STATION) |
| | FIRE ALARM SOUNDER |
| | FIRE ALARM SYSTEM DUCT MOUNTED SMOKE DETECTOR - REFER TO DIV 23 FOR EXACT LOCATIONS. |
| | FIRE ALARM SYSTEM MANUAL PULL STATION. |
| | FIRE ALARM SYSTEM HORN/STROBE SIGNAL. BOTTOM OF STROBE LENS SHALL BE 80" AFF, LOCATE WITHIN 6" OF DOOR FRAME, ALIGN WITH WALL SWITCH, WHERE APPLICABLE. ("SS" INDICATES SPEAKER/STROBE IN LIEU OF HORN/STROBE) |
| | FIRE ALARM SYSTEM STROBE-ONLY SIGNAL. BOTTOM OF STROBE LENS SHALL BE 80" AFF. LOCATE WITHIN 6" OF DOOR FRAME, ALIGN WITH WALL SWITCH, WHERE APPLICABLE. |
| | FIRE/SMOKE DAMPER BY MECHANICAL. PROVIDE 120V CONNECTION FROM NEAREST VAV OR PIU CIRCUIT. OR, IF NOT AVAILABLE, FROM NEAREST 120V CONVENIENCE RECEPTACLE. INTERCONNECT WITH FIRE ALARM SYSTEM. PROVIDE A DUCT MOUNTED SMOKE DETECTOR WITHIN 5-FEET OF EACH F/SD, AND INTERCONNECT FOR ACTIVATION. |
| | FIRE ALARM SYSTEM FIRE-HEAT DETECTOR. |




THE ARCHITECTURE GROUP, INC.

377 Peachtree St.
Atlanta, GA 30303
Phone: (678) 222-0375
Fax: (678) 222-0384
tag@architecturegroup.com

COPYRIGHT © 2018 BY THE ARCHITECTURE GROUP, INC. ALL RIGHTS RESERVED.

THIS DRAWING MAY NOT BE USED IN ANY MANNER NOR REPRODUCED IN ANY FORM WITHOUT PRIOR WRITTEN CONSENT FROM THE ARCHITECTURE GROUP, INC.



2018 MRRF CAMPUS-WIDE
ADA IMPROVEMENTS

PROJECT No. IGSU-026-18
TAG PROJECT No. 1706

GEORGIA STATE UNIVERSITY
ATLANTA, GEORGIA

| | |
|----------------|----------|
| 100% CD | 2/5/2017 |
| REVISIONS | |
| DATE | 2/5/2017 |
| DRAWN BY | |
| CHECKED | |
| APPROVED | |
| SCALE | AS NOTED |
| PROJECT NUMBER | 1706 |
| DRAWING TITLE | |

ELECTRICAL
LEGENDS -
RIALTO

DRAWING NUMBER

RO E0.1



SPENCER BRISTOL
ENGINEERING, INC.

A Gray Company
3577 Parkway Lane, Suite 250
Peachtree Corners, Georgia 30092
Tel. 770.414.1628 Fax 770.414.6024
SBE Project No. 1744