

MECHANICAL SPECIFICATIONS (CONT)

DUCT HANGERS AND SUPPORTS:

- A. DUCT HANGERS AND SUPPORTS SHALL BE IN ACCORDANCE WITH THE HANGERS AND SUPPORTS SECTION OF THE REFERENCED SMACNA STANDARDS, EXCEPT:
- DO NOT SPACE HANGERS OVER 8'-0" ON CENTERS.
 - HANGERS SHALL BE THE GALVANIZED STEEL STRAP TYPE. SIZES AND NUMBER OF STRAP HANGERS SHALL BE BASED ON THE DUCT SIZE AS SCHEDULED IN THE SMACNA STANDARD.

FLEXIBLE ROUND DUCTWORK:

- A. FLEXIBLE ROUND DUCTWORK SHALL BE CLASS 1, UL 181 AIR DUCT WITH AN ALUMINIZED MYLAR OR POLYESTER INNER LINER LAMINATED TO A CORROSION RESISTANT STEEL WIRE HELIX. ALUMINUM HELIX IS NOT ACCEPTABLE.
- B. A 1" THICK, ONE POUND DENSITY FIBERGLASS INSULATION AND VINYL OUTER JACKET SHALL COVER THE WIRE HELIX.
- C. FLEXIBLE DUCTWORK SHALL BE DESIGNED FOR PRESSURES UP TO 4" WG. THE MAXIMUM ALLOWABLE LENGTH SHALL BE 5'-0" AND SHALL BE LIMITED TO RUN-OUTS CONNECTED TO ROUND NECK CEILING SUPPLY DIFFUSERS. PROVIDE A SPIN-IN FITTING WITH INTEGRAL VOLUME DAMPER AT ALL FLEXIBLE RUN-OUT CONNECTIONS.
- D. FLEXIBLE DUCTWORK MANUFACTURED BY GENFLEX, FLEXMASTER, ATCO OR ROYAL WILL BE ACCEPTABLE.

DUCTWORK INSTALLATION:

- A. INSTALL ALL DUCTWORK AND ACCESSORIES AS SHOWN AND IN ACCORDANCE WITH APPLICABLE SMACNA STANDARDS.
- B. SEAL ALL JOINTS IN DUCTWORK WITH A FIRE RETARDANT SEALANT. TAPE IS NOT ACCEPTABLE.


EXHAUST FANS

INLINE CENTRIFUGAL FANS

- A. HOUSING: SPLIT, SPUN ALUMINUM WITH ALUMINUM STRAIGHTENING VANES, INLET AND OUTLET FLANGES, AND SUPPORT BRACKET ADAPTABLE TO FLOOR, SIDE WALL, OR CEILING MOUNTING.
- B. DIRECT-DRIVE UNITS: MOTOR MOUNTED IN AIRSTREAM, FACTORY WIRED TO DISCONNECT SWITCH LOCATED ON OUTSIDE OF FAN HOUSING; WITH WHEEL, INLET CONE, AND MOTOR ON SWING-OUT SERVICE DOOR.
- C. FAN WHEELS: ALUMINUM, AIRFOIL BLADES WELDED TO ALUMINUM HUB.

ACCESSORIES:

- A. VARIABLE-SPEED CONTROLLER: SOLID-STATE CONTROL TO REDUCE SPEED FROM 100 TO LESS THAN 50 PERCENT.
- B. VOLUME-CONTROL DAMPER: MANUALLY OPERATED WITH QUADRANT LOCK, LOCATED IN FAN OUTLET.
- C. COMPANION FLANGES: FOR INLET AND OUTLET DUCT CONNECTIONS.
- D. VIBRATION ISOLATORS:
- TYPE: ELASTOMERIC HANGERS.




THE
ARCHITECTURE
GROUP, INC.

377 Peachtree St.
Atlanta, GA 30303
Phone: (678) 222-0375
Fax: (678) 222-0384
tag@architecturegroup.com

COPYRIGHT © 2018 BY THE ARCHITECTURE GROUP, INC. ALL RIGHTS RESERVED.

THIS DRAWING MAY NOT BE USED IN ANY MANNER NOR REPRODUCED IN ANY FORM WITHOUT PRIOR WRITTEN CONSENT FROM THE ARCHITECTURE GROUP, INC.



2018 MRRF CAMPUS-WIDE
ADA IMPROVEMENTS
PROJECT No. IGSU-026-18
TAG PROJECT No. 1706
GEORGIA STATE UNIVERSITY
ATLANTA, GEORGIA

100% CDs	2/5/2017
REVISIONS	
DATE	2/5/2017
DRAWN BY	
CHECKED	
APPROVED	
SCALE	AS NOTED
PROJECT NUMBER	1706
DRAWING TITLE	

**MECHANICAL
SPECIFICATIONS**

DRAWING NUMBER

UL M0.4



SPENCER BRISTOL
ENGINEERING, INC.
A Gray Company
3577 PARKWAY LANE, SUITE 250
PEACHTREE CORNERS, GEORGIA 30092
TEL. 770.414.1628 FAX 770.414.6024
SBE Project No. 1744

Order Plans @ WWW.LDILine