

Point Repair #	Start MH	End MH	Start MH Depth (ft)	End MH Depth (ft)	Total Length of Pipe (ft)	Pipe Diameter (in)	Location from Start MH (ft)	Pipe Material	Problem Summary	Service Position	Pre-CIPP	Repair	Repair Detail	Patch Detail
39	619-07	619-06	6.0	6.1	304.6	8	273.3	PVC	Service - Roots at Tee and Lateral	2		Pt. Repair (268.3 FT to 278.3 FT) - Install Tee and Lateral	2, 3, & 7	
40	619-02	619-01	6.1	18.0	281.0	8	273.9	PVC	Service - Roots at Tee	10		Pt. Repair (120.9 FT to 130.9 FT) - Install Tee	3	11


www.LDILine.com


Order Plans @

LEGEND

- 699-100 MSSD SANITARY SEWER MANHOLE
- MSSD SANITARY SEWER
- SERVICE LATERALS
- REWA SANITARY SEWER MANHOLE
- REWA SANITARY SEWER
- - - - - PROPERTY LINE
- EDGE-OF-PAVEMENT
- ▭ BUILDING FOOTPRINT
- STREAM/EDGE-OF-WATER
- — NEW SERVICE LATERAL

NOTE:
SERVICE LATERALS ARE SHOWN FOR INFORMATION PURPOSES ARE APPROXIMATELY BASED ON CCTV DATA AND MANHOLE INSPECTIONS. NOT ALL EXISTING SERVICES ARE SHOWN. ALL SERVICES TO BE REPAIRED ARE SHOWN.


 01/29/2018


 GAVEL & DORN
 ENGINEERING, PLLC
 C-3734
 CERTIFICATE OF AUTHORIZATION

METROPOLITAN SEWER SUBDISTRICT
 120 Augusta Ave. Way
 Greenville, SC 29605
 864-677-4442

PREPARED BY:
 Gavel & Dorn Engineering, PLLC
 License No. C-3734
 6730 Freedom Dr.
 Charlotte, NC 28214

PROJECT:
SOUTH GREENVILLE POINT REPAIR PROJECT

SHEET TITLE:
POINT REPAIR 39 - 40

MARK	DATE	DESCRIPTION

Apprval: _____
 Date: **1-29-2018**
 Checkd: **JLD**
 Drawn: _____
 Scale: **1"=200'**
 Project Number: **16-4005**
 Sheet: **C-7**