Store No.: L407 KMA: MID SOUTH

DESIGN AMBIENT: 95 VOLTAGE: 460 ALTITUDE: 983

BY: Maria Brinck REV. 1: E SEARS DATE 6/12/17 12/20/17 F1 DATE 6/12/17 12/15/17

RACK	CKT	L	W	H	CASE/COIL MODEL	DESCRIPTION	DEPT	STAT	ePRO ITEM	EVAP TEMP	LOAD (MBH)	SUCTION CON-TROL	DEFROST #/DAY	DEFROST TYPE	REFRIG	TOTAL LOAD	PARALLEL RACK INFORMATION COMPRESSOR	HP	SUCT TEMP	CAPACITY	THR	PERCENT LOADED
A															R404A		EXISTING PARALLEL RACK					
	1	3	QTY		RLN(IC-E-LED2)-5	5 DOOR G.D., ICE CREAM TEMP, NARROW	GROC.	NEW		-19	16.0	EVR	1	EL/TEMP			Reclaim: Air					
		1	QTY		RLN(IC-E-LED2)-4	4 DOOR G.D., ICE CREAM TEMP, NARROW	GROC.	NEW		-19	4.3		1	EL/TEMP			Controller: CPC Einstein II RX-400 Serving Racks A & B					
		1	QTY		RLN(IC-E-LED)-4	4 DOOR G.D., ICE CREAM TEMP, NARROW	GROC.	REL.		-19	4.7		1	EL/TEMP			Control Voltage: 208V					
	2	2	QTY		RLN(IC-E-LED)-6	6 DOOR G.D., ICE CREAM TEMP, NARROW (Converted from LT)	GROC.	REL.		-19	11.8	EVR	1	EL/TEMP			Control Valve Voltage: 208V					
		1	QTY		RLN(IC-E-LED)-4	4 DOOR G.D., ICE CREAM TEMP, NARROW (Converted from LT)	GROC.	REL.		-19	4.7		1	EL/TEMP			Compressor Voltage: 460V					
		2	QTY		RLN(IC-E-LED)-3	3 DOOR G.D., ICE CREAM TEMP, NARROW (Converted from LT)	GROC.	REL.		-19	7.0		1	EL/TEMP			Modify existing parallel rack electric as required to accomplish remodel					
		1	QTY		RLN(IC-E-LED2)-3	3 DOOR G.D., ICE CREAM TEMP, NARROW (Converted from LT)	GROC.	NEW		-19	3.2		1	EL/TEMP								
	3	7	QTY		RLN(IC-E-LED)-2	2 DOOR G.D., ICE CREAM TEMP, NARROW	GROC.	EX.		-19	16.3	EVR	1	EL/TEMP			2DLF20K		-23	21.1	34.5	
		1	QTY		RLN(IC-E-LED)-2	2 DOOR G.D., ICE CREAM TEMP, NARROW	GROC.	REL.		-19	2.3		1	EL/TEMP			3DFF40K		-23	42.6	69.3	
		1	QTY		RLN(IC-E-LED2)-2	2 DOOR G.D., ICE CREAM TEMP, NARROW	GROC.	NEW		-19	2.1		1	EL/TEMP			3DFF40K		-23	42.6	69.3	
	4	1	QTY		FWE(LT-E)	WIDE ISLAND END , LOW TEMP	MEAT	EX.		-20	2.1	EVR	1	EL/TEMP								
		1	QTY		FWE(LT-E)	WIDE ISLAND END , LOW TEMP	MEAT	REL.		-20	2.1		1	EL/TEMP		66.7				108.5	173.0	61.6%
		1	QTY		FW(LT-E)-12	12' WIDE ISLAND, LOW TEMP	MEAT	EX.		-20	6.3		1	EL/TEMP								
		1	QTY		FW(LT-E)-8	8' WIDE ISLAND, LOW TEMP	MEAT	NEW		-20	4.0		1	EL/TEMP								
AR	1	1	QTY		RLN(LT-E-LED)-5	5 DOOR G.D., LOW TEMP, NARROW, BACK-TO-BACK	GROC.	EX.		-11	4.9		1	EL/TEMP			3D8F33K		-14	44.4	69.3	
		3	QTY		RLN(LT-E-LED)-4	4 DOOR G.D., LOW TEMP, NARROW, BACK-TO-BACK	GROC.	EX.		-11	11.6		1	EL/TEMP			4DHF63K		-14	83.1	129.5	
		2	QTY		RLN(LT-E-LED)-3	3 DOOR G.D., LOW TEMP, NARROW, BACK-TO-BACK	GROC.	EX.		-11	5.8		1	EL/TEMP			4DHF63K		-14	83.1	129.5	
	2	4	QTY		RLN(LT-E-LED)-5	5 DOOR G.D., LOW TEMP, NARROW, BACK-TO-BACK	GROC.	EX.		-11	19.4		1	EL/TEMP								
		1	QTY		RLN(LT-E-LED)-2	2 DOOR G.D., LOW TEMP, NARROW, BACK-TO-BACK	GROC.	EX.		-11	1.9		1	EL/TEMP		177.8				210.5	336.2	64.5%
	3	4	QTY		RLN(LT-E-LED)-5	5 DOOR G.D., LOW TEMP, NARROW, BACK-TO-BACK	GROC.	EX.		-11	19.4		1	EL/TEMP								
		1	QTY		RLN(LT-E-LED)-2	2 DOOR G.D., LOW TEMP, NARROW, BACK-TO-BACK	GROC.	EX.		-11	1.9		1	EL/TEMP								
	4	4	QTY		RLN(LT-E-LED)-5	5 DOOR G.D., LOW TEMP, NARROW, BACK-TO-BACK	GROC.	EX.		-11	19.4		1	EL/TEMP								
		1	QTY		RLN(LT-E-LED)-3	3 DOOR G.D., LOW TEMP, NARROW, BACK-TO-BACK	GROC.	EX.		-11	2.9		1	EL/TEMP						A+AR	501.2	
	5	4	QTY		RLN(LT-E-LED)-5	5 DOOR G.D., LOW TEMP, NARROW, BACK-TO-BACK	GROC.	EX.		-11	19.4		1	EL/TEMP								
		1	QTY		RLN(LT-E-LED)-3	3 DOOR G.D., LOW TEMP, NARROW, BACK-TO-BACK	GROC.	EX.		-11	2.9		1	EL/TEMP			EXISTING 460V Air Cooled Condenser					
																	HUSSMANN LAVF-23410, 51.28 mbh/deg td capacity. 68 circuits. 10.0 TD Setpoint					
	6	2	QTY		RLN(LT-E-LED2)-5	5 DOOR G.D., LOW TEMP, NARROW (Convert from IC Temp)	GROC.	EX.		-11	9.6	EVR	1	EL/TEMP								
		2	QTY		RLN(LT-E-LED2)-4	4 DOOR G.D., LOW TEMP, NARROW (Convert from IC Temp)	GROC.	EX.		-11	7.6		1	EL/TEMP								
		1	QTY		RLN(LT-E-LED2)-3	3 DOOR G.D., LOW TEMP, NARROW (Convert from IC Temp)	GROC.	EX.		-11	2.9		1	EL/TEMP								
		1	QTY		RLN(LT-E-LED2)-2	2 DOOR G.D., LOW TEMP, NARROW (Convert from IC Temp)	GROC.	EX.		-11	1.9		1	EL/TEMP								
	7	2	QTY		FWE(MT-E)	WIDE ISLAND END , MED TEMP	DAIRY	EX.		19	2.6		1	EL/TEMP								
		1	QTY		FW(MT-E)-12	12' WIDE ISLAND, MED TEMP	DAIRY	EX.		19	4.8		1	EL/TEMP								
		1	QTY		FW(MT-E)-8	8' WIDE ISLAND, MED TEMP	DAIRY	EX.		19	3.1		1	EL/TEMP								
		2	QTY		FWE(MT-E)	WIDE ISLAND END , MED TEMP	MEAT	EX.		19	2.6		1	EL/TEMP								
		1	QTY		FW(MT-E)-12	12' WIDE ISLAND, MED TEMP	MEAT	EX.		19	4.8		1	EL/TEMP								
	8	2	QTY		FWE(MT-E)	WIDE ISLAND END , MED TEMP	DAIRY	NEW		19	2.6	(S)ORIT	1	EL/TEMP								
		1	QTY		FW(MT-E)-8	8' WIDE ISLAND, MED TEMP	DAIRY	NEW		19	3.1		1	EL/TEMP								
NEW	9	1	QTY		RLN(LT-E-LED)-5	5 DOOR G.D., LOW TEMP, NARROW, BACK-TO-BACK	GROC.	EX.		-11	4.9	EVR	1	EL/TEMP								
		3	QTY		RLN(LT-E-LED)-4	4 DOOR G.D., LOW TEMP, NARROW, BACK-TO-BACK	GROC.	EX.		-11	11.6		1	EL/TEMP								
		2	QTY		RLN(LT-E-LED)-3	3 DOOR G.D., LOW TEMP, NARROW, BACK-TO-BACK	GROC.	EX.		-11	5.8		1	EL/TEMP								
B															R404A		EXISTING PARALLEL RACK					
	1	2	QTY		D5XLEP-12	12' FIVE DECK, LOW FRONT	DAIRY	EX.		26	30.3	EVR	3	OT/TIME			Reclaim: Air					
		1	QTY		D5XLEP-12	12' FIVE DECK, LOW FRONT	DAIRY	REL.		26	15.2		3	OT/TIME			Controller: SEE RACK A					
	2	3	QTY		D5XLEP-12	12' FIVE DECK, LOW FRONT	DAIRY	EX.		26	45.5		3	OT/TIME			Control Voltage: 208v					
	3	663	SQ FT	10	EXIST COIL(S)	COOLER W/ (15) DOORS	DAIRY	EX.		26	60.0						Control Valve Voltage: 208V					
	4	3	QTY		D5XLEP-12	12' FIVE DECK, LOW FRONT	DAIRY	EX.		26	45.5		3	OT/TIME			Compressor Voltage: 460V					
		2	QTY		D5XLEP-8	8' FIVE DECK, LOW FRONT	DAIRY	EX.		26	20.2		3	OT/TIME								
	5	2	QTY		D5XLEP-12	12' FIVE DECK, LOW FRONT	BEV.	EX.		26	30.3		3	OT/TIME			2DLR78K		24	63.4	85.4	
	6	2	QTY		D5XLEP-12	12' FIVE DECK, LOW FRONT	BEV.	EX.		26	30.3		3	OT/TIME			3DFS11M		24	126.6	172.4	
		1	QTY		D5XLEP-6	6' FIVE DECK, LOW FRONT	BEV.	EX.		26	7.6		3	OT/TIME			3DFS11M		24	126.6	172.4	
	7	4	QTY		D5XLEP-12	12' FIVE DECK, LOW FRONT	BEV.	EX.		26	60.6	EVR	3	OT/TIME			3DFS11M		24	126.6	172.4	
		1	QTY		D5XLEP-6	6' FIVE DECK, LOW FRONT	BEV.	NEW		26	7.6		3	OT/TIME			3DFS11M		24	126.6	172.4	
	8	2	QTY		D5XULEP-12	12' FIVE DECK, ULTRA LOW FRONT	DAIRY	EX.		26	34.9		4	OT/TIME								
		3	QTY		D5XULEP-8	8' FIVE DECK, ULTRA LOW FRONT	DAIRY	EX.		26	34.8		4	OT/TIME		531.1				569.7	774.8	93.2%
	9	2	QTY		M5XGEP(LED)-12	12' FIVE DECK, W/G	MEAT	EX.		25	28.9		4	OT/TIME								
	10	2	QTY		M5XGEP(LED)-12	12' FIVE DECK, W/G	MEAT	EX.		26	28.8		4	OT/TIME								
		1	QTY		M5XGEP(LED)-8	8' FIVE DECK, W/G	MEAT	EX.		25	9.6		4	OT/TIME			EXISTING 460V Air Cooled Condenser					
	11	330	SQ FT	10	EXIST COIL(S)	COOLER	PROD.	EX.		26	22.8						HUSSMANN LAVF-23410, 51.28 mbh/deg td capacity 68 circuits, 15.0 TD Setpoint					
*	12	2	QTY		DD5XLP-12	12' FIVE DECK WITH DOORS	DAIRY	NEW		32	6.5	ORIT/EVR	1	OT/TIME								
		1	QTY		DD5XLP-6	6' FIVE DECK WITH DOORS	DAIRY	NEW		32	1.6		1	OT/TIME								
*	13	3	QTY		DD5XLP-12	12' FIVE DECK WITH DOORS	DAIRY	NEW		32	9.8	ORIT/EVR	1	OT/TIME								

(*) CREATE NEW LOOP FROM EXISTING SPARE CIRCUIT

UNIT	CKT	L	W	H	CASE/COIL MODEL	DESCRIPTION	DEPT	STAT	ePRO ITEM	EVAP TEMP	LOAD (MBH)	SUCTION CON-TROL	DEFROST #/DAY	DEFROST TYPE	REFRIG	TOTAL LOAD	DISTRIBUTED UNIT INFORMATION COMPRESSOR	HP	SUCT TEMP	CAPACITY	THR	PERCENT LOADED
1															R404A		EXISTING DISTRIBUTED UNIT					
	1	1	QTY		FWE(MT-E)	WIDE ISLAND END , MED TEMP	MEAT	EX.		19	1.3	EVR	1	EL/TEMP			Configuration: Vertical					
		1	QTY		FWE(MT-E)	WIDE ISLAND END , MED TEMP	MEAT	REL.		19	1.3		1	EL/TEMP			Reclaim: Air					
		1	QTY		FW(MT-E)-12	12' WIDE ISLAND, MED TEMP	MEAT	EX.		19	4.8		1	EL/TEMP			Controller: CPC Einstein II RX-400					
		1	QTY		FW(MT-E)-8	8' WIDE ISLAND, MED TEMP	MEAT	NEW		19	3.1		1	EL/TEMP			Control Voltage: 208V					
	**2	1	QTY		Q3-MS-12 (SERP)	SERVICE SINGLE-DECK SERPENTINE COIL (NO SHELF)	MEAT	NEW		28	1.8	SC BY OEM	1	OT/TIME			Control Valve Voltage: 208V					
		1	QTY		Q3-MS-12 (GRAV)	SERVICE SINGLE-DECK GRAVITY COIL (NO SHELF)	MEAT	NEW		28	1.2	SC BY OEM	1	OT/TIME			Compressor Voltage: 460V					
		1	QTY		Q3-MS-8 (GRAV)	SERVICE SINGLE-DECK GRAVITY COIL (NO SHELF)	MEAT	NEW		28	0.8	SC BY OEM	1	OT/TIME								
		1	QTY		Q3-MS-8 (SERP)	SERVICE SINGLE-DECK SERPENTINE COIL (NO SHELF)	MEAT	NEW		28	1.2	SC BY OEM	1	OT/TIME			ZB19KCE		17	19.2	27.4	
	3	1	QTY		2-2070R	3-DOOR REFRIGERATOR	SEAF.	REL.		20	3.8	EXISTING					ZB38KCE		17	38.5	54.7	
	4	2	QTY		DSFM-8	8' SERVICE	SEAF.	NEW		24	4.8	EVR	3	OT/TIME			ZB38KCE		17	38.5	54.7	
	5	700	SQ FT	10	EXIST COIL(S)	COOLER	MEAT	EX.		20	36.9											
	6	4	QTY		BLF-59SR	SELF SERVICE	BAK.	NEW		20	22.6	EVR	4	OT/TIME		83.7				96.3	136.8	88.9%
1R	1	1	QTY		D5XEP-8	8' FIVE DECK	DELI	EX.		26	9.7		3	OT/TIME			ZB19KCE		24	22.1	30.3	
	2	2	QTY		D5XEP-12	12' FIVE DECK	DELI.	EX.		26	29.0		3	OT/TIME			ZB45KCE		24	52.6	71.5	
	3	1	QTY		M5XGEP(LED)-8	8' FIVE DECK, W/G	SEAF.	EX.		26	7.2		4	OT/TIME			ZB45KCE		24	52.6	71.5	
	4	643	SQ FT		EXIST COIL(S)	PREP	MEAT	EX.		35	42.2					96.1				127.3	173.4	75.5%
	5	9	9	10	EXIST COIL(S)	RETARDER	BAK.	EX.		26	8.1											
																				1+1R:	310.3	
																	EXISTING 460V Air Cooled Condenser					
																	HUSSMANN LAVF-22210, 20.77 mbh/deg td capacity, 68 [illegible] Setpoint					
2															R404A		EXISTING DISTRIBUTED UNIT					
	1	1	QTY		FWE(LT-E)	WIDE ISLAND END , LOW TEMP	SEAF.	EX.		-20	2.1	EVR	1	EL/TEMP			Configuration: Vertical					
		1	QTY		FWE(LT-E)	WIDE ISLAND END , LOW TEMP	SEAF.	REL.		-20	2.1		1	EL/TEMP			[illegible] Air					
		1	QTY		FW(LT-E)-12	12' WIDE ISLAND, LOW TEMP	SEAF.	EX.		-20	6.3		1	EL/TEMP			[illegible]: CPC Einstein II RX-400					
		1	QTY		FW-L(LT-E)-8(1/2)	6' WIDE ISLAND W/ LIDS, LOW TEMP	SEAF.	NEW		-15	1.0		1	EL/TEMP			[illegible] Voltage: 208V					
		1	QTY		FW(LT-E)-8(1/2)	(1/2) - 8' WIDE ISLAND, LOW TEMP	SEAF.	NEW		-20	2.0		1	EL/TEMP			Control Valve Voltage: [illegible]					
	2	1	QTY		FME1200AE-3	ICE MACHINE	SEAF.	EX.		-1	7.5						Compressor Voltage: [illegible]					
	3	1	QTY		3GR-G31011	3-DOOR FREEZER	SEAF.	NEW		-20	4.7	SC BY OEM	0	NONE			Modify existing distributed unit electric as required to accomplish remodel					
	4	1	QTY		RLN(LT-E-LED)-5	5 DOOR G.D., LOW TEMP, NARROW	SEAF.	EX.		-11	5.5		1	EL/TEMP								
	5	1	QTY		RLN(IC-E-LED)-5	5 DOOR G.D., ICE CREAM TEMP, NARROW	BAK.	EX.		-19	5.8		1	EL/TEMP			ZF15K4E		[illegible]	16.2	28.1	
	6	705	SQ FT	10	EXIST COIL(S)	FREEZER	GROC.	EX.		-22	48.8						ZF18K4E		[illegible]	19.7	33.7	
																	ZF18K4E		-25	19.7	33.7	
																	ZF18K4E		-25	19.7	33.7	
																	ZF18K4E		-25	19.7	33.7	
																85.7				94.9	162.9	80.4%
																	EXISTING [illegible]60V Air [illegible] Condenser					
																	HUSSMA[illegible] LAVF-22205, 18.55 mbh/deg td capacity 68 circuits, 10.0 TD Setpoint					
3															R404A		[illegible]STING DISTRIBUTED UNIT					
	1	24	15	10	EXIST COIL(S)	FREEZER	BAK.	EX		-22	[illegible]						Configuration: Vertical					
	2	1	QTY		RBC100	BLAST CHILLER	DELI.	[illegible]		-10	[illegible]						Reclaim: Air					
	3	12	9	10	EXIST COIL(S)	FREEZER	DELI	[illegible]		-22	11.7						Controller: CPC Einstein II RX-300					
																	Control Voltage: 208V					
																	Control Valve Voltage: 208V					
																	Compressor Voltage: 460V					
																	Modify existing distributed unit electric as required to accomplish remodel					
																	ZF09K4E		-25	9.3	16.2	
																	ZF15K4E		-25	16.2	28.1	
																	ZF18K4E		-25	19.7	33.7	
																	ZF18K4E		-25	19.7	33.7	
																	ZF18K4E		-25	19.7	33.7	
																47.0				84.5	145.4	55.7%
																	EXISTING 460V Air Cooled Condenser					
																	HUSSMANN LAVE-22210, 18.11 mbh/deg td capacity, 68 circuits, 10.0 TD Setpoint					
4															R404A		EXISTING DISTRIBUTED UNIT					
	1	637	SQ FT	10	EXIST COIL(S)	[illegible]	PROD.	EX.		24	36.6						Configuration: Vertical					
	2	701	SQ FT		EXIST COIL(S)	[illegible]	PROD.	EX.		35	26.6						Reclaim: Air					
	3	1	QTY		[illegible]	[illegible]	DELI.	EX.		20	4.3	EVR	2	OT/TEMP			Controller: CPC Einstein II RX-400					
		1	QTY		[illegible]	[illegible]	DELI.	NEW		20	4.3		2	OT/TEMP			Control Voltage: 208V					
	4	1	QTY		[illegible]	[illegible]	CHEESE	NEW		26	6.4	EVR	6	OT/TEMP			Control Valve Voltage: 208V					
		1	QTY		[illegible]	[illegible] CASE WEDGE	CHEESE	NEW		26	2.6		6	OT/TEMP			Compressor Voltage: 460V					
		1	QTY		[illegible]	6' SELF SERVICE	CHEESE	NEW		26	3.9		6	OT/TEMP								
	5	1	QTY		Q3-SS-6	SELF SERVICE [illegible]	DELI.	NEW		20	6.8	EVR	4	OT/TIME			ZB45KCE		18	46.7	65.6	
	6	1	QTY		[illegible]FS-8 (BOWLS & WRA[illegible]	[illegible] TO ORDER SERVICE	DELI.	NEW		25	1.0	EVR	6	OT/TEMP			ZB45KCE		18	46.7	65.6	
	7	1	QTY		Q3-SS-12	[illegible] SERVICE MULTI-DECK	DELI.	NEW		20	10.2	EVR	4	OT/TIME			ZB45KCE		18	46.7	65.6	
	8	[illegible]	QTY		D5XEP-12	[illegible]	DELI.	EX.		26	29.0		3	OT/TIME			ZB45KCE		18	46.7	65.6	
		[illegible]	QTY		D5XEP-8	[illegible]	DELI.	EX.		26	8.7		3	OT/TIME			ZB45KCE		18	46.7	55.6	
	[illegible]	[illegible]	QTY		KRO-16(1/4)	(1/4) - [illegible] BAR	PROD.	NEW		25	10.4	EVR	8	OT/TIME								
	[illegible]	[illegible]	QTY		KRO-16-E	16' SALA[illegible] END CAP	PROD.	NEW		25	2.0		8	OT/TIME		157.1				233.5	328.1	67.3%
	10	[illegible]	[illegible]		Q3-SS-4	SELF SERVICE MULTI-DECK	DELI.	NEW		20	3.4	EVR	4	OT/TIME								
																	EXISTING 460V Air Cooled Condenser					
																	HUSSMANN LAVF-22210, 20.77 mbh/deg td capacity, 68 circuits, 15.0 TD Setpoint					
5															R404A		EXISTING DISTRIBUTED UNIT					
	[illegible]	[illegible]	[illegible]	10	EXIST COIL(S)	COOLER	DELI.	EX.		26	16.0						Configuration: Vertical					
	2	[illegible]	QTY		DD5NX-L-12	12' FIVE DECK LOW FRONT WITH DOORS	SS BEV.	NEW		32	3.3	ORIT/EVR	1	OT/TIME			Reclaim: Air					
		[illegible]	[illegible]		DD5NX-L-8	8' FIVE DECK LOW FRONT WITH DOORS	SS BEV.	NEW		32	2.2		1	OT/TIME			Controller: CPC Einstein II RX-400					
	3	1	[illegible]		FL5NX-LEP-12	12' MULTI DECK, LOW FRONT, NARROW	FLOR.	NEW		28	15.9	EVR	3	OT/TIME			Control Voltage: 208V					
		2	[illegible]		FL5NX-LEP-8	8' MULTI DECK, LOW FRONT, NARROW	FLOR.	NEW		28	21.2		3	OT/TIME			Control Valve Voltage: 208V					
	4	7	9	10	ACM078S	COOLER (NEW)	FLOR.	NEW	K-0060919	29	6.9	EVR		OT/TIME			Compressor Voltage: 460V					
	5	4	QTY		DD5XLP-12	12' FIVE DECK WITH DOORS	PROD.	NEW		32	13.0	ORIT/EVR	1	OT/TIME								
	6	2	QTY		D5XLEP-12	12' FIVE DECK, LOW FRONT	PROD.	NEW		26	30.3	EVR	3	OT/TIME			ZB45KCE		24	52.6	71.5	
		1	QTY		D5XLEP-8	8' FIVE DECK, LOW FRONT	PROD.	NEW		26	10.1		3	OT/TIME			ZB45KCE		24	52.6	71.5	
	7	2	QTY		D5XLEP-12	12' FIVE DECK, LOW FRONT	PROD.	NEW		26	30.3	EVR	3	OT/TIME			ZB45KCE		24	52.6	71.5	
		2	QTY		D5XLEP-8	8' FIVE DECK, LOW FRONT	PROD.	NEW		26	20.2		3	OT/TIME			ZB45KCE		24	52.6	71.5	
	8	4	QTY		DD5NX-L-12	12' FIVE DECK LOW FRONT WITH DOORS	BEV.	NEW		32	13.0	ORIT/EVR	1	OT/TIME			ZB45KCE		24	52.6	71.5	
																182.3				263.1	357.7	69.3%
																	EXISTING 460V Air Cooled Condenser					
																	HUSSMANN LAVF-22310, 26.90 mbh/deg td capacity, 68 circuits, 15.0 TD Setpoint					

(**) OEM to supply (1) ORIT-6 EPR for System 1-2

SYS	L	W	H	CASE/COIL MODEL	DESCRIPTION	DEPT	STAT	ePRO ITEM	EVAP TEMP	LOAD (MBH)	CON-TROL	DEFROST #/DAY	DEFROST TYPE	REFRIG	TOTAL LOAD	CONDENSING UNIT INFORMATION COND UNIT MODEL	COMP BODY	HP	SUCT TEMP	CAPACITY	PERCENT LOADED	RECLAIM CIRCUIT
RT1	27	9'-8"	10	LCA6110S	1/2 CLICKLIST COOLER	GROC.	EX.		26	9.6			OT/TIME	R407A	19.3	HTHZ-0300MQK	ZB21KCE			24.7	78.0%	
				LCA6110S	1/2 CLICKLIST COOLER	GROC.	EX.		26	9.6			OT/TIME			EXISTING Condensing Unit, Unchanged						
RT2	14	9'-6"	10	MLT4166S	CLICKLIST FREEZER	GROC.	EX.		-22	13.5			EL/TEMP	R407A	13.5	HTHZ-0600LOK	ZF18K4E		-25	15.7	86.2%	
																EXISTING Condensing Unit, Unchanged						

NOTE: THIS DRAWING IS [illegible] ONLY TO SHOW THE REQUIREMENTS OF THE KROGER CO. THE DESIGN [illegible] BUILDING TO CONFORM TO ALL APPLICABLE LAWS, CODES, REGULATIONS [illegible] AND APPROVAL OF THE INSPECTION AUTHORITIES HAVING JURISDICTION IS THE RESPONSIBILITY OF THE ARCHITECT EMPLOYED BY THE OWNER.

LOUISVILLE
(NEW) BANNER
1600 ORMSBY STATION CT
LOUISVILLE , KY
PHONE: (502) 423-4962 FAX: (502) 425-2379

Kroger
GENERAL OFFICE
FACILITY ENGINEERING
1014 VINE ST, CINCINNATI, OHIO 45202
PH (513) 762-1467 FAX (513) 762-4012

WITHIN THE WALLS
L-407
3101 RICHMOND RD
LEXINGTON,KY

CURRENT PLAN DATE: 12/20/2017
ORIGINAL PLAN DATE: 6/16/2017
DRAWN: MARIA BRINCK CHECKED: GIGLIO
REVISIONS: ES 12/20/17
STANDARD PLOTTED SCALE: NONE

BUILDING STATS	
TOTAL SHELVING	5,677 LF
SALES AREA % OF GROSS BUILDING	91,879 SF 73 %
BASE STORE	115,608 SF
MEZZANINE	
DOCK / UTILITY	6,603 SF

GROSS BUILDING 126,467 SF

REFRIGERATION SCHEDULE

STEEL PACKAGE ID: Not Applicable

L-407

SHEET: R6.1

CAD FILE: L407R6.1.DWG

Order Plans @ WWW.LDILine.com