



- NOTE: GROUND GAS PIPING AS REQUIRED BY NCGC AND NEC, COORDINATE WITH ELECTRICAL CONTRACTOR.
- NOTE: ALL EXTERIOR PIPE AND FITTINGS SHALL BE PAINTED OR COATED WITH EXTERIOR GRADE PRODUCT IN ACCORDANCE WITH THE NCGC, FINISH COLOR SHALL MATCH BUILDING.
- NOTE: PROVIDE UV STABLE PIPE LABELS EVERY 5'-0" MAX. INDICATING "2 PSI" GAS PIPE.
- GAS NOTE: P.C. SHALL COORDINATE WITH LOCAL GAS UTILITY NEW GAS LOADS AND COVER IN HIS BID ANY COST RELATED WITH NEW NATURAL GAS SERVICE.
- CONNECTED LOAD:  
 2,889.800 BTUH, 2,889.8 CFH  
 350 FT. D.L. FOR 2 PSI SYSTEM.  
 1.0 PSI PRESSURE DROP  
 .80 SPECIFIC GRAVITY  
 TOTAL CONNECTED LOAD = 2,889.8 CFH
- NOTE: NATURAL GAS PIPING SYSTEM SHALL BE BONDED TO THE BUILDING ELECTRICAL GROUNDING SYSTEM IN ACCORDANCE WITH NCGC AND THE NEC.

**AIR TERMINALS**

Ⓐ = AIR TERMINAL WITH AIR REEL, PROVIDE 1/2" SHUTOFF VALVE, FILTER, REGULATOR, LUBRICATOR (EQUAL TO PARKER MODEL 07838A18A48DC) AND QUICK CONNECT FITTING. (COORDINATE WITH OWNER TYPE QUICK CONNECT FITTING REQUIRED AND FILTER MEDIA) TYPICAL AT EACH AIR TERMINAL

Ⓑ = AIR TERMINAL ONLY, PROVIDE 1/2" SHUTOFF VALVE, FILTER, REGULATOR, LUBRICATOR (EQUAL TO PARKER MODEL 07838A18A48DC) AND QUICK CONNECT FITTING. (COORDINATE WITH OWNER TYPE QUICK CONNECT FITTING REQUIRED AND FILTER MEDIA) TYPICAL AT EACH AIR TERMINAL

1 GROUND LEVEL WATER/AIR FLOOR PLAN - PLUMBING  
 SCALE: 1/8" = 1'-0"

Order Plans