

GENERAL LIGHTING NOTES

1. REFER TO GENERAL NOTES ON MEP COVER SHEET FOR ADDITIONAL REQUIREMENTS OF WORK.
2. LIGHT FIXTURES INDICATED AS EMERGENCY FIXTURES ARE FUNCTIONING AS NIGHT LIGHTS UNLESS SPECIFICALLY SHOWN SWITCHED.
3. ALL CIRCUITING SHOWN ON THIS PLAN IS DIAGNOSTIC.
 - 3.1. ALL FIXTURES SHALL BE FED FROM JUNCTION BOXES WITH LIGHT FIXTURE WHIPS (<6'). DOWT-CHAINING OF FIXTURES IS NOT ALLOWED.
 - 3.2. SWITCH BOX LOCATIONS SHALL BE WIRED SO THAT A NEUTRAL WIRE IS AVAILABLE AT THE SWITCH LOCATION EITHER IN THE BOX OR AVAILABLE TO BE ADDED VIA PENETRATOR FOR AN ACCESSIBLE WALL CAVITY.
 - 3.3. ALL SWITCHES FOR SEPARATE LOAD TYPES (EM/NORMAL, 120/277V, ETC.) SHALL NOT BE IN A SINGLE BOX.
 - 3.4. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.

LIGHTING PLAN KEYED NOTES


- ① CIRCUIT TO ROOM CONTROLLER SHOWN ON FIRST FLOOR PLAN.

MEZZANINE FLOOR PLAN - LIGHTING
3/16" = 1'-0"

KEMSTUDIO

1515 GENESSEE ST SUITE 11 KANSAS CITY MO 64102
t 816 756 1808 f 816 756 1828

kemstudio.com



S & S ENGINEERING, INC.
ELEC
MECH
10551 Berkley, Suite 601
Overland Park, Kansas 66212
Ph: 913-754-3673
F: 913-754-3674
E-mail: corporate@ss-engr.com
Web: www.ss-engr.com

PORT KC OFFICES

1000 BERKLEY PARKWAY - SPACE E177
KANSAS CITY, MO 64108
PROJECT NUMBER: A1718



ISSUED FOR:	DATE:
95% CDS	12.22.2017
Permit Set	01.12.2018

LIGHTING PLAN

E102