


GENERAL NOTES:

1. REFER TO SHEET E0.1 FOR SYMBOLS, ABBREVIATIONS AND GENERAL NOTES.
2. CONTRACTOR SHALL COORDINATE ALL ELECTRICAL DEVICE AND LIGHT FIXTURE LOCATIONS WITH OTHER TRADES PRIOR TO INSTALLATION.
3. REFER TO MECHANICAL SCHEDULES FOR DISCONNECT SIZES.


KEYED NOTES:

1. 1/2" C-1 POWERED VIA QDU-1. PROVIDE 3/4" C RATED TOGGLE SWITCH TO COORDINATE WITH MECHANICAL CONTRACTOR. DIVISION 23 CONTRACTOR RESPONSIBLE FOR INTERCONNECTING CONDUCTORS.
2. PROVIDE ADDRESSABLE MONITORING MODULE FOR AC HEATING FAILURE. COORDINATE LOCATION PRIOR TO INSTALLATION.

1 ELECTRICAL - GROUND FLOOR POWER PLAN
1/8" = 1'-0"



FINLEY DESIGN PA
7806 NC HWY 751
SUITE 110
DURHAM, NC 27713
P 919-493-8200
F 919-493-8113
FINLEYDESIGNARCH.COM



WESTPOINT 2
DURHAM, NC

REVISIONS

NO.	DATE	DESCRIPTION
1	2017-09-01	PERMIT COMMENTS

PROJECT: 1342
DATE: 11/11/16
DRAWN BY: ABA
CHECKED BY: MDH

ELECTRICAL
GROUND FLOOR
POWER PLAN

E2.0
15 OF 24