



GENERAL NOTES:

1. REFER TO SHEET E0.1 FOR SYMBOLS, ABBREVIATIONS AND GENERAL NOTES.
2. CONTRACTOR SHALL COORDINATE ALL ELECTRICAL DEVICE AND LIGHT FIXTURE LOCATIONS WITH OTHER TRADES PRIOR TO INSTALLATION.
3. REFER TO MECHANICAL SCHEDULES ON SHEET E0.07 FOR DISCONNECT SIZES.

KEYED NOTES

- 1 POWER CONDUIT RISER.
- 2 TELECOMMUNICATIONS CONDUIT RISER.
- 3 ODU-3 POWERED VIA ODU-3. PROVIDE 3/4" CIRCULAR RATED TOGGLE SWITCH TO COORDINATE WITH MECHANICAL CONTRACTOR. DIVISION 23 CONTRACTOR RESPONSIBLE FOR INTERCONNECTING CONDUCTORS.
- 4 TRANSFORMER SHALL BE PROVIDED WITH WEATHERSHIELD, NEMA 3R RATED.
- 5 COORDINATE POWER CONNECTION TO HOT BOXES PRIOR TO INSTALLATION.
- 6 COORDINATE INSTALLATION OF TAMPER SWITCHES FOR PIV AND HOT BOX WITH FIRE ALARM CONTRACTOR.
- 7 PROVIDE ADDRESSABLE MONITORING MODULE FOR HOT BOX. COORDINATE LOCATION PRIOR TO INSTALLATION.



FINLEY DESIGN PA
 7806 NC HWY 751
 SUITE 110
 DURHAM, NC 27713
 P 919-493-8200
 F 919-493-8113
 FINLEYDESIGNARCH.COM



WESTPOINT 2
DURHAM, NC

REVISIONS

2017-09-01	PERMIT COMMENTS

PROJECT: 1342
 DATE: 11/11/16
 DRAWN BY: ASB
 CHECKED BY: MDH

ELECTRICAL
FIRST FLOOR
POWER PLAN

E2.1
 16 OF 24

1 ELECTRICAL - FIRST FLOOR POWER PLAN
 1/8" = 1'-0"