

ELECTRICAL SYMBOL LEGEND			
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
S ₁	SINGLE POLE SWITCH (SUBSCRIPT INDICATES ITEM CONTROLLED)		
S ₃	THREE-WAY SWITCH		
S ₄	FOUR-WAY SWITCH		
SWP	SINGLE POLE SWITCH WITH WEATHERPROOF COVER		CEILING FAN
SM	MANUAL MOTOR STARTER WITH OVERLOAD HEATERS		
S ₀	DIMMER SWITCH		FIRE ALARM CONTROL PANEL
S _T	TIMER SWITCH		FIRE ALARM ANNUCIATOR PANEL
SOS	OCCUPANCY SENSOR SWITCH		
	DUPLEX RECEPTACLE		OCCUPANCY SENSOR, WATTSTOPPER WT-2255 WITH BZ-150 POWER PACKS
	FLOOR OUTLET BOX AND DUPLEX RECEPTACLE WITH APPROPRIATE FLANGE.		ELECTROMAGNETIC HOLD OPEN
	DUPLEX RECEPTACLE MOUNTED ABOVE COUNTER		TWO WAY COMMUNICATION SYSTEM USER INTERFACE
	DUPLEX RECEPTACLE WITH TOP HALF SWITCHED		TWO WAY COMMUNICATION SYSTEM MASTER CONTROL STATION
	GFI RECEPTACLE. WP DENOTES WEATHERPROOF COVER.		3/4" PLYWOOD TELEPHONE TERMINAL BOARD PAINTED WITH FIRE RETARDANT PAINT
	GFI RECEPTACLE MOUNTED ABOVE COUNTER		MAIN LUGS ONLY
	TWO DUPLEX RECEPTACLES WITH COMMON COVER		
	TWO DUPLEX RECEPTACLES WITH COMMON COVER MOUNTED ABOVE COUNTER		
	SPECIAL PURPOSE RECEPTACLE, RATING AS NOTED		
	PHOTOCELL, MOUNTED ON ROOF FACING NORTH		
	JUNCTION BOX WP = WEATHERPROOF PROVIDE BLOCKING FOR FUTURE FAN WHERE APPLICABLE		
	MOTOR CONNECTION, NUMBER DENOTES HORSEPOWER		
	TRANSFORMER		
	DISCONNECT SWITCH AR DENOTES AMP RATING OF SWITCH NF DENOTES NON-FUSED AF DENOTES AMP FUSE SIZE WHERE LOCATED IN A CLOSET, INSTALL DISCONNECT SUCH THAT WHEN THE DOOR IS OPEN, THERE IS AT LEAST 42" CLEAR PER NEC		
	LIGHTING/APPLIANCE PANELBOARD		
	POWER METER		
	BRANCH CIRCUIT CONDUIT CONCEALED ABOVE CEILING OR IN WALL. CONDUIT SHALL INCLUDE PHASE, NEUTRAL AND GROUND CONDUCTORS AS REQUIRED FOR CIRCUITS		
	BRANCH CIRCUIT CONDUIT CONCEALED IN SLAB, UNDERGROUND OR UNDER FLOOR.		
	FLUORESCENT STRIP FIXTURE		
	WALL MOUNTED FIXTURE		
	UNSWITCHED AND ALWAYS ON LIGHT FIXTURE		
	RECESSED OR SURFACE CEILING MOUNTED LIGHT FIXTURE		
	UNSWITCHED AND ALWAYS ON LIGHT FIXTURE		
	TRACK LIGHTING, NUMBER OF HEADS AS SHOWN ON DRAWING		
	SURFACE MOUNTED WRAPAROUND		
	EXIT LIGHT FIXTURE DIRECTION ARROWS AS SHOWN (SHADED QUADRANT INDICATES FACE(S) OF FIXTURE)		
	WALL MOUNTED EXIT LIGHT FIXTURE		
	EXTERIOR LIGHT FIXTURE WITH ARMS AS SHOWN ON DRAWINGS		
	BATTERY PACK WITH TWIN HEADS		
	EXTERIOR MOUNTED PHOTOCELL FACING NORTH		
	MANUAL PULL STATION		
	CEILING SMOKE DETECTOR, PHOTOELECTRIC TYPE UNLESS OTHERWISE NOTED. HARD WIRED WITH BATTERY BACKUP		
	HEAT DETECTOR		
	COMBINATION SMOKE/STROK IDENTIFICATION DEVICE, WHITE COLOR		
	VISUAL ONLY SIGNALING UNIT, WALL MOUNTED, WHITE COLOR		
	OUTLET BACK BOX WITH 1" CONDUIT		
	PHONE OUTLET MOUNTED AT 18" AFF UNLESS OTHERWISE NOTED		

SPECIFICATION NOTES:

- ALL WIRING AND CABLING SHALL BE CONCEALED.
- PROVIDE ALL LABOR AND MATERIALS FOR A COMPLETE INSTALLATION OF ALL ELECTRICAL ITEMS SHOWN ON THE DRAWINGS. COMPLY WITH ALL APPLICABLE CODES, LAWS, REGULATIONS, AND AUTHORITIES HAVING JURISDICTION FOR THIS PROJECT.
- CONTRACTOR IS RESPONSIBLE FOR ALL FEES AND PERMITS REQUIRED FOR THIS PROJECT. COORDINATE ELECTRICAL UTILITY REQUIREMENTS WITH ELECTRIC UTILITY.
- BRANCH AND FEEDER CIRCUITS SHALL BE COPPER TYPE NM CABLE WITH AN EQUIPMENT GROUND CONDUCTOR. SERVICE ENTRANCE CABLE SHALL BE ALUMINUM TYPE SE.
- SCHEDULE 40 PVC CONDUIT SHALL BE USED UNDERGROUND. PROVIDE GALVANIZED INTERMEDIATE METAL CONDUIT WHERE CONDUIT IS RUN ABOVE GROUND.
- RECEPTACLES AND SWITCHES SHALL BE 20 AMP SPECIFICATION GRADE, WHITE COLOR. PROVIDE WHITE COVERPLATES.
- ALL LIGHT FIXTURES SHALL BE FURNISHED BY CONTRACTOR.
- PROVIDE CATEGORY 5E CABLES FOR TELEPHONE OUTLETS SHOWN ON DRAWINGS. JACKS SHALL BE DUAL LINE RJ-14. PROVIDE CONNECTION TO TELEPHONE DEMARICATION POINT. COORDINATE WITH TELEPHONE SERVICE PROVIDER.
- PROVIDE RG6 70 OHM CABLES FROM TELEVISION OUTLETS SHOWN ON DRAWINGS TO CATV DEMARICATION POINT.
- PROVIDE ALL FINAL ELECTRICAL AND CONTROL CONNECTIONS TO FIXED APPLIANCES.
- LIGHT SWITCHES SHALL BE MOUNTED 48 INCHES ABOVE FINISHED FLOOR TO CENTER LINE OF DEVICE, UNLESS OTHERWISE NOTED.
- RECEPTACLES SHALL BE LOCATED 18 INCHES ABOVE FINISHED FLOOR TO CENTER LINE OF DEVICE, UNLESS OTHERWISE NOTED.
- EQUIPMENT SHALL BE OF MATERIALS SUITABLE FOR AND RATED FOR THE ENVIRONMENT IN WHICH THEY ARE TO BE INSTALLED.
- WORKING CLEARANCES FOR ELECTRICAL EQUIPMENT SHALL BE IN COMPLIANCE WITH NEC 110.
- THE EXCLUSIVELY DEDICATED SPACE EXTENDING FROM FLOOR TO STRUCTURAL CEILING WITH A WIDTH AND DEPTH OF THE PANELBOARD OR SWITCHBOARD MUST BE CLEAR OF ALL PIPING, DUCTS, EQUIPMENT FOREIGN TO THE ELECTRICAL EQUIPMENT OR ARCHITECTURAL APPURTENANCES IN ACCORDANCE WITH NEC 384.

WHEN ELECTRICAL BOXES ARE LOCATED IN VERTICAL FIRE RESISTIVE ASSEMBLIES, (CLASSIFIED AS FIRE/SMOKE AND SMOKE PARTITIONS), THEY SHALL BE INSTALLED WITHOUT AFFECTING THE FIRE CLASSIFICATION. ALL OF THE FOLLOWING CONDITIONS SHALL BE MET:

- THE OPENING IN THE GYPSUM BOARD FACING SHALL BE CUT NOT TO EXCEED 1/8 INCH BETWEEN THE EDGES OF THE OUTLET BOX AND THE EDGES OF THE OPENING.
- BOX OPENING SHALL OCCUR ONLY ON ONE SIDE OF FRAMING SPACE.
- BOX OPENING SHALL NOT EXCEED 16 SQUARE INCHES.
- ALL CLEARANCES BETWEEN OUTLET BOX AND GYPSUM BOARD SHALL BE COMPLETELY FILLED WITH JOINT COMPOUND.
- PROVIDE A WALL AROUND OUTLETS LARGER THAN 16 SQUARE INCHES. THE INTEGRITY OF THE WALL RATING SHALL BE MAINTAINED.
- THE TOTAL AGGREGATE SURFACE AREA OF THE BOXES SHALL NOT EXCEED 100 SQUARE INCHES PER 100 SQUARE FEET.
- OUTLET BOXES LOCATED ON OPPOSITE SIDES OF FIRE RESISTIVE ASSEMBLIES SHALL BE SEPARATED BY A MINIMUM HORIZONTAL DISTANCE OF 24 INCHES. FOR OUTLET BOXES LESS THAN 24 INCHES APART, SEE DETAIL FOR UL SYSTEM NO. CUJ.
- OUTLET BOXES SHALL BE SECURELY FASTENED TO WALL FRAMING MEMBERS.

- ALL DEVICES SHALL BE MOUNTED VERTICAL, UNLESS OTHERWISE NOTED.
- ALL RECEPTACLES SHALL BE MOUNTED SUCH THAT THE GROUND PIN IS MOUNTED UP.
- WHERE TWO OR MORE SMOKE ALARMS ARE WITHIN A DWELLING UNIT, THEY SHALL BE ARRANGED SO THAT OPERATION OF ANY SMOKE ALARM SHALL CAUSE THE ALARM IN ALL SMOKE ALARMS WITHIN THE DWELLING UNIT TO SOUND.

LIGHTING FIXTURE SCHEDULE					
TYPE	DESCRIPTION	MANUFACTURER AND CATALOG NO.	VOLTAGE	LAMPS	REMARKS
A	1X4 LED SURFACE MOUNT TROFFER	ORACLE LIGHTING 14-OSMT-LED-3400L-DIM10-MVOLT-35K-85-A12	120	35W LED	
B	BATHROOM SCONCE	KICHLER LIGHTING 10799NILED	120	48.7W LED	
C	LED FLUSH MOUNT DISK LIGHT	WAC LIGHTING FM-306-940-BN	120	15W LED	
D	TRACK LIGHT	EGLO LIGHTING 83049A	120	(4) 50W GU10	REFER TO ARCH. FOR MOUNTING HEIGHT
E	WALL LANTERN	FEISS LIGHTING 0L680RSZ-LED	120	14W LED	
F	9" FLUSH MOUNT LED FIXTURE	NUVO LIGHTING S9337	120	18.5W LED	
G	2' UNDER COUNTER LIGHT	LITHONIA LIGHTING UCLD-24W-30K-90CRI-BY	120	24W LED	
H	4' FLUORESCENT WRAP	HOWARD LIGHTING CW44-4-32-E-MV	120	(4) 32W T8	
J	4' LED STRIP FIXTURE	CONTECH LIGHTING SS-4-35-MV-30K	120	40W LED	
J1	2' STRIP FIXTURE WET LOCATION LED	LITHONIA LIGHTING LW2-L24-4000L-ACL-MD-MVOLT-35K-90CRI	120	40W LED	
K	CLEAR JELLY JAR	ACE LIGHTING 10191	120	(1) 60W INC	
L	LED CHANDELIER	ELK LIGHTING 72073-4-LED	120	(4) 13.5W LED	
M	LED PENDANT CEILING LIGHT	ELK LIGHTING 72072-1-LED	120	(1) 13.5W LED	
P	WALL MOUNTED SCONCE	LITHONIA #MPCW 280TT 120 DOB LPI OR EQUAL TO BE SELECTED BY OWNER	120	(1) 28W CF.	REFER TO ARCH. FOR MOUNTING HEIGHT
R	WALL PACK WITH PHOTOCELL	RAB LIGHTING SLM-18-Y-BZ/WH-PC	120	18W LED	REFER TO ARCH. FOR MOUNTING HEIGHT
R1	WALL PACK WITHOUT PHOTOCELL	RAB LIGHTING SLM-18-Y-BZ/WH	120	18W LED	REFER TO ARCH. FOR MOUNTING HEIGHT
T	LED WET LOCATION VAPOR TIGHT	ORACLE LIGHTING 4-OWTIP-LED-4000L-DIM10-MVOLT-35K-85	120	36W LED	
U	WET LOCATION VAPOR TIGHT	CONTECH LIGHTING VW65-150	120	(1) 150W INC	
V	MINI PENDANT	HD SUPPLY 224279	120	(1) 60W INC	
W	CEILING FAN	MINKA AIRE F556L-BN/DW	120	84W LED	
W1	EXTERIOR CEILING FAN	MINKA AIRE F753L-KA	120	64W LED	
Y	WALL SCONCE	NUVO LIGHTING 62-104	120	4.8W LED	
	TWIN HEAD BATTERY PACK	HOWARD LIGHTING HL02025W-W	120	(2) 5.4W LED	
	UNIVERSAL MOUNT EXIT SIGN WITH BATTERY PACK, RED LETTERS	ISOLITE RL-EM-R-WW	120	2.4W LED	
EM	EMERGENCY EGRESS LIGHTING	ISOLITE ELED-EM-WW-CD/ELED-EM-BZ-CD	120	11W LED	

PUCCIANO & ENGLISH, INC.
ARCHITECTS, AIA
 3084 MERCER UNIVERSITY DRIVE, SUITE 110
 ATLANTA, GA 30341
 PH 770-457-0823 FAX 770-451-0092
 denglish@pucciano-english.com



JOB No: 1701
DRAWN BY:
CHECK BY:
JOB PROGRESS:
ITEM DATE
PRICING SET 07-14-2017
PERMIT SET 02-28-2018

REVISIONS:
 DATE NO

This drawing, as an instrument of service, is and shall remain the property of the Architect and shall not be reproduced, published or used in any way without the permission of the Architect.

Legacy at Jones Farm Phase 2
 HUNTSVILLE, ALABAMA
 AN APARTMENT COMMUNITY FOR
RBJ BAILEY, LLC

SYMBOL LEGEND,
 LTG. FIXTURE SCHED.
 SHEET NO.

E-1