

ALL PANELBOARDS, TRANSFORMERS, TRANSFER SWITCH KIT AND DISCONNECTS WILL BE SUPPLIED BY THE OWNER (O'REILLY). ELECTRICAL GEAR SHALL BE DIRECT ORDERED AND/OR RELEASED FROM THE LISTED ELECTRICAL EQUIPMENT DISTRIBUTOR. SEE 'ELECTRIC SERVICE RESPONSIBILITIES' FOR ADDITIONAL CLARIFICATION.




GRAYBAR ELECTRIC CO. INC. 11885 LACKLAND ROAD ST. LOUIS, MO. 63146

GRAYBAR O'REILLY TEAM EMAIL: oreilly@graybar.com TOLL FREE: (314) 573-2080

MP PANELBOARD SCHEDULE table with columns for Mains (225A MIN LUGS ONLY), Voltage (208), Accessories, and a grid of circuit descriptions and load values.

PLP PANELBOARD SCHEDULE table with columns for Mains (225A MIN LUGS ONLY), Voltage (208), Accessories, and a grid of circuit descriptions and load values.

PANELBOARD SCHEDULE - MDP table with columns for Amps (400A MIN BREAKER), Voltage (120/208V, 3 PHASE 4 WIRE), and a grid of breaker sizes, wire sizes, and loads.



E TRANSFER SWITCH SCHEDULE table with columns for Position, Circuit Breaker, Load Description, (kVA), and Breaker.

NOTE: ALL BRANCH CIRCUITS SHALL HAVE AN EQUIPMENT GROUNDING CONDUCTOR ROUTED WITH THE CIRCUIT CONDUCTORS...

WIRING & LABELING OF EXIT & EMERGENCY LIGHT CIRCUITS. 1. SEE DETAIL 1/E1 FOR WIRING OF EXIT & EMERGENCY LIGHTS ON THESE CIRCUITS...


GENERATOR POWER INLET LABEL. WARNING: FOR CONNECTION OF A NONSEPARATELY DERIVED (FLOATING NEUTRAL) SYSTEM ONLY (MAX. 6,000 WATT GENERATOR)

EQUIPMENT LABELS CHART table with columns for Equipment and checkboxes for Service Disconnect, Standby Source, Series Rating, Generator Power Inlet, and Panel Current.

OPTIONAL STANDBY SOURCE LABEL. CAUTION: STANDBY POWER SOURCE: PORTABLE 6kW GENERATOR. LOCATION: OVERHEAD DOOR.

SERVICE DISCONNECT LABEL. THE SERVICE DISCONNECTING MEANS SHALL BE PROPERLY MARKED 'SERVICE DISCONNECT'.

Series Ratings NQ Panelboards table showing Maximum System Voltage, Maximum Short Circuit Current Rating, and Square D Breaker Ratings for various load types.



PROJECT: NEW O'REILLY AUTO PARTS STORE 915 AZALEA DRIVE WAYNESBORO, MISSISSIPPI

mtec Malcom Finkle Eckhardt & Collins, Inc. 3333 E. Battlefield Rd., Suite 1000 Springdale, Missouri 65804

DRAWN BY: MVS CHECKED BY: JEE DATE: 01/12/18 REVISION: PROJECT NUMBER: WSB SHEET NUMBER: E3