

ITEM #	QTY	DESCRIPTION	FLOW PTS (TOTAL)
1W	4	DUCT NOZZLES	4
1N	4	PLENUM NOZZLES	4
230	2	APPLIANCE NOZZLES	4
3N	9	APPLIANCE NOZZLES	27
280	2	APPLIANCE NOZZLES	4
TOTAL FLOW POINTS -			43

ITEM #	QTY	DESCRIPTION
#200	14	SERIES DETECTORS W/ FUSIBLE LINKS
#201	2	TERMINAL DETECTOR W/ FUSIBLE LINKS
#202	2	3 GALLON REGULATED RELEASE W/ DOUBLE POLE MICRO SWITCH
#203	1	SINGLE TANK ENCLOSURE
#204	1	DOUBLE TANK ENCLOSURE
#205	5	3 GALLON TANKS
#206	2	REMOTE PULL STATION



ANSUL R-102 FIRE SYSTEM LAYOUT

Order Plans

FUSIBLE LINK RATINGS

ITEM	TEMP
OPEN FRYERS	450°
2 BURNER / FLAT TOP	450°
PRESSURE FRYERS	450°
GRILL	450°
EXHAUST COLLARS	450°

ANSUL R-102 FIRE SYSTEM NOTES



THREE TANK SYSTEM MOUNTED ON TOP OF (H-1)
MAXIMUM FLOW POINTS = 33

ANSUL R-102 FIRE SYSTEM NOTES

TWO TANK SYSTEM MOUNTED ON TOP OF (H-3)
MAXIMUM FLOW POINTS = 22

ANSUL R-102 FIRE SYSTEM

- 1. FINAL INSTALLATION IS TO BE MADE IN ACCORDANCE WITH ALL APPLICABLE CODES
- 2. ALL ELECTRICAL COMPONENTS FOR EQUIPMENT SHUT DOWN TO BE PROVIDED BY THE ELECTRICIAN
- 3. MICRO-SWITCH INSTALLED IN REGULATED RELEASE BY ANSUL INSTALLER
- 4. REMOTE PULL STATION LOCATED PER MECHANICAL DRAWINGS



CHICK-FILA
SAR South Cobb Drive FSR
JACOBI UNIT 3100 South Cobb Dr SE Smyrna, GA 30080
JAWM: JTY: JAL: September 08, 2017
SCALE: NTS
TO: JAW: U16-875-01 PROTOTYPICAL

HALTON CO. (CANADA)
101 WARDEN AVE. #42164
SCOTTSBURGH, ON M1V 3J7
1-905-674-0301

WWW.HALTON.COM

MA - A-11-00-01 - JAWM MS 10 A-11-00-01 - JAL: -AC 1004 31-000-
HALTON CO. (USA)
101 WARDEN AVE. #42164
SCOTTSBURGH, ON M1V 3J7
1-905-674-0301

Sheet
MH-101