

**LUMINAIRE SCHEDULE**

CALLOUT	SYMBOL	LAMP	DESCRIPTION	MOUNTING	MODEL	INPUT WATTS	NOTE 1	NOTE 2
A		45W LED	LED ACRYLIC LENSED TROFFER - 2x4	RECESSED	COLUMBIA #LJT24-35MLG-FSA12-EU-C388	45		
AE		45W LED	LED ACRYLIC LENSED TROFFER - 2x4	RECESSED	SAME AS FIXTURE "A", ON BATTERY BACKUP	45		
D		13W LED	6" LED DOWNLIGHT	RECESSED	PRESCOLITE #SL6LED1K-35K-BL/DBXQL	13		
DE		13W LED	6" LED DOWNLIGHT	RECESSED	SAME AS FIXTURE "D", ON BATTERY BACKUP	13		
E		4W LED	EXIT SIGN/EGRESS COMBO, ON BATTERY BACKUP	WALL	DUAL LITE #LTU-R-W	4	ON EXTERIOR EXITS, TO PROVIDE POWER TO "EG" FIXTURES	CONNECT TO UNSWITCHED "LIFE SAFETY" CIRCUIT
EM		(2) 3W LED (MR-16)	(2)-HEAD EMERGENCY EGRESS FIXTURE	WALL	DUAL LITE #LZ-25-N-12V-03L, OR APPROVED EQUAL 1FC AVG = 32' SPACING @7.5' AFF	12	CONNECT TO UNSWITCHED "LIFE SAFETY" CIRCUIT	PROVIDE LIGHTING MANUFACTURER RECOMMENDED EMERGENCY BATTERY BACKUP CAPABLE OF 90 MINUTE RUNTIME
F		14W LED	6" DECORATIVE PENDANT	PENDANT	ACCESS LIGHTING #28011-1R-ORB /RUSKY	14		
G		16W LED	EMERGENCY EGRESS FIXTURE	WALL	DUAL LITE #PG-Z	16		
N		27W LED	SCONCE	WALL	LITHONIA #OLLWU	27		
P		(1) 81W LED	POLE MTD. SITE LIGHTING FIXTURE	POLE	TECH LIGHT #LSBR2C8T3C1-BZ	81	PROVIDE FIXTURE WITH HOUSE SIDE SHIELD	PROVIDE WITH 20' SQUARE STEEL POLE
V		72W LED	LED CANOPY FIXTURE	SURFACE	LITHONIA #ZL2M-148-5000LM-ZSD-MVOLT-40K-80CRI-WH	72		
VE		72W LED	LED CANOPY FIXTURE	SURFACE	SAME AS FIXTURE "V", ON BATTERY BACKUP	72		
W		33W LED	LED WALL PACK	WALL	LITHONIA #OLW-23	33		

**GENERAL LIGHTING NOTES:**

- PROVIDE 4100' KELVIN TEMPERATURE LAMPS WITH MINIMUM 85 CRI, UOI.
- ALL EXIT FIXTURES SHALL BE CENTER MTD. ON WALL ABOVE DOOR HEADER, UOI. CONNECT TO UNSWITCHED "LIFE SAFETY" CIRCUIT. PROVIDE LIGHTING MANUFACTURER RECOMMENDED EMERGENCY BATTERY BACKUP CAPABLE OF 90 MINUTE RUNTIME.
- "EM" DENOTES FIXTURE FURNISHED WITH FACTORY INSTALLED EMERGENCY LIGHTING BATTERY PACK.
- REFER TO ELECTRICAL SPECIFICATIONS FOR FURTHER INFORMATION REGARDING LIGHTING FIXTURES AND LAMPS.
- LIGHTING FIXTURES SHALL BE AS SPECIFIED ABOVE OR AN APPROVED EQUAL. SUBSTITUTIONS MUST BE SUBMITTED FOR REVIEW BY OWNER.

**SWITCH SCHEDULE**

CALLOUT	SYMBOL	NOTE 1	NOTE 2	NOTE 3
Occ Sensor - Ceiling Mount Line Voltage		CEILING MOUNTED, DUAL TECHNOLOGY, LINE VOLTAGE OCCUPANCY SENSOR	MODEL WATTSTOPPER DT-35S, OR APPROVED EQUAL	
Switch		WALL MOUNTED SWITCH	COLOR IVORY	MTD AT 48" AFF, UOI
Switch-Dimmer		WALL MOUNTED 1200W DIMMER SWITCH	COLOR IVORY	MTD AT 48" AFF, UOI
Switch-Weather Proof				MTD AT 48" AFF, UOI

**Fire Alarm Schedule**

CALLOUT	SYMBOL	NOTE 1	NOTE 2	NOTE 3
Audio Alarm		FIRE ALARM AUDIBLE INDICATOR ALARM, WALL MTD	CONNECTED TO BUILDING FACP	

1 S d  
NONE

**EQUIPMENT SCHEDULE**

CALLOUT	SYMBOL	VOLTS	AMPS	KVA	HP	BREAKER	CIRCUIT	CUSTOM PANEL DESCRIPTION
AHU-1		120V 1P 2W	9.8	1.18	1/2 HP	20/1	MDP-25	AHU-1
AHU-2		120V 1P 2W	9.8	1.18	1/2 HP	20/1	MDP-27	AHU-2
AHU-3		120V 1P 2W	9.8	1.18	1/2 HP	20/1	MDP-29	AHU-3
AHU-4		120V 1P 2W	9.8	1.18	1/2 HP	20/1	MDP-31	AHU-4
BT		208V 2P 2W	12.5	2.6		20/2	C-12,14	BUN TOASTER
CEF		208V 2P 2W	8.7	1.8		20/2	B-19,21	COOLER EVAPORATOR
CK		208V 3P 4W	3.7	1.33		20/3	MDP-26,28,30	CHILL KING
CU-1		208V 3P 3W	18	6.5		30/3	MDP-32,6	CU-1
CU-2		208V 3P 3W	18	6.5		30/3	MDP-8,12	CU-2
CU-3		208V 3P 3W	18	6.5		30/3	MDP-14,16,18	CU-3
CU-4		208V 3P 3W	18	6.5		30/3	MDP-19,21,23	CU-4
EF-1		120V 1P 2W	1.66	0.7	3/4 HP	20/1	MDP-20	EF-1
EF-2		120V 1P 2W	13.8	1.66	3/4 HP	20/1	MDP-22	EF-2
FEF		208V 2P 2W	18.3	6.8		20/2	B-23,25	FREEZER EVAPORATOR FAN
H-1		208V 2P 2W	4.8	1.7		20/2	MDP-33,35	H-1
H-2		208V 2P 2W	9.6	2		20/2	MDP-37,39	H-2
ICM		208V 3P 4W	17.2	6.12		20/3	B-18,20,22	ICE CREAM MACHINE
ICM		208V 3P 4W	17.2	6.2		20/3	C-27,29,31	ICE CREAM MACHINE
IM		208V 2P 2W	12.5	2.6		20/2	B-11,13	ICE MACHINES
IM		208V 2P 2W	12.5	2.6		20/2	B-15,17	ICE MACHINES
MAU-1		208V 3P 3W	9.7	3.5		20/3	MDP-32,34,36	MAU-1
PS		120V 1P 2W	10	1.2		20/1	B-4	POLE SIGN
PW		208V 2P 2W	30.3	6.3		40/2	B-7,9	POWER WASH WITH SHELF
RBS		208V 2P 2W	18.8	3.9		30/2	B-6,8	READER BOARD SIGN
S		208V 2P 2W	16.3	3.4		20/2	C-22,24	STEAMER
S		208V 2P 2W	16.3	3.4		20/2	C-26,28	STEAMER
SD		208V 2P 2W	22.6	4.7		30/2	C-5,7	SLUSH DRINK MACHINE
SD		208V 2P 2W	22.6	4.7		30/2	C-15,17	SLUSH DRINK MACHINE
SF-1		120V 1P 2W	13.8	1.66	3/4 HP	20/1	MDP-24	SF-1

**RECEPTACLE SCHEDULE**

CALLOUT	SYMBOL	VOLTS	NOTE 1	NOTE 2
Data		120V 1P 2W	3/4" CONDUIT STUB UP TO ABOVE CEILING FOR CABLE	PROVIDE CABLE JACK W/ WHITE COVER PLATE AND RUN CAT 5E CABLE TO TELEPHONE/MDEO PANEL.
Duplex Outlet		120V 1P 2W	DUPLEX RECEPTACLE, MTD AT 18" AFF TO BOTTOM, UOI	
Duplex Outlet-GFCI		120V 1P 2W	GFCI PROTECTED DUPLEX RECEPTACLE, MTD AT 18" AFF TO BOTTOM, UOI	
Duplex Outlet-GFCI Above Counter		120V 1P 2W	GFCI PROTECTED DUPLEX RECEPTACLE, MTD AT 4" ABOVE BACKSPLASH TO BOTTOM, UOI	COORDINATE WITH CASEWORK CONTRACTOR
Duplex Outlet-GFCI/WP		120V 1P 2W	GFCI PROTECTED DUPLEX RECEPTACLE, WITH WEATHER-PROOF IN-USE COVER, MTD AT 18" AFF TO BOTTOM, UOI	
Duplex Outlet-TV		120V 1P 2W	DUPLEX RECEPTACLE FOR TV, MTD AT 72" AFF TO BOTTOM, UOI	
J-Box		120V 1P 2W	JUNCTION BOX, USE AS INDICATED	
Quad Outlet		120V 1P 2W	QUAD RECEPTACLE, MTD AT 18" AFF TO BOTTOM, UOI	
Tele & Data		120V 1P 2W	EMPTY 3/4" CONDUIT STUB UP TO ABOVE CEILING FOR TELEPHONE & DATA	MTD AT 18" AFF TO BOTTOM, UOI



STORE #6679

6808 SIEGEN LANE  
BATON ROUGE, LA 70809

PROJ. NO.: 1122

DATE: 01/22/2018

SHEET TITLE:  
SCHEDULES -  
ELECTRICAL

DRAWING SHEET IS FULL SIZE AT 22" x 34"  
REDUCED 11" x 17" SHEET IS HALF SIZE

SHEET NO.: E3.01

Order Plans @ WWW.WADSWORTH.COM