



TOWN OF PEMBROKE UTILITY NOTES:

- 2 INCH TAP TO EXISTING WATER MAIN TO BE MADE USING 2" SADDLE AND CORPORATION VALVE. SADDLE SHALL HAVE A BRASS BODY CONFORM TO THE OUTSIDE DIMENSIONS OF THE MAIN. RING SHALL BE RUBBER GASKET TO PROVIDE WATER TIGHT JOINT. WELDED DOUBLE BOTTOM STRAP DESIGN. THREADED OUTLET SHALL BE LOCATED ON CORPORATION VALVE. CORPORATION VALVE SHALL BE THE SAME AS THE SERVICE LINE. INLET THREADED SHALL BE 1/2" NPT. INLET THREADED SHALL BE AS REQUIRED FOR THE PIPE.
- METER BOXES SHALL BE CONCRETE WITH TRAFFIC RATED STEEL LIDS AND SIZES APPROPRIATE TO ACCOMMODATE PROPOSED METERS.
- METER SERVICE SHALL BE MADE OF COPPER AND INCLUDE A METER VALVE ON THE PUBLIC SIDE OF METER WHICH SHALL BE SEALED AND CAPABLE OF BEING LOCKED TO THE CURB STOP.
- METERS SHALL BE MANUFACTURED BY ELSTER AND BE COMPATIBLE WITH METERS CURRENTLY BEING UTILIZED BY THE TOWN.
- IF EXISTING SANITARY SEWER MAIN IS CONSTRUCTED OF MATERIAL OTHER THAN DUCTILE IRON OR PVC, CONNECTION SHALL BE ACHIEVED BY REMOVING SECTION OF MAIN AND INSTALLING A MAIN-LINE WYE (SLEEVED TO THE MAIN).
- CLEANOUTS INSTALLED IN GRASS AREAS SHALL BE PROTECTED BY CONCRETE RING INSTALLED AROUND CAP AT GRADE.

TOWN OF PEMBROKE UTILITY NOTES:

- TRENCHES REQUIRING SHORING AND BRACING, DIMENSIONS SHALL BE TAKEN FROM THE INSIDE FACE OF THE SHORING AND BRACING.
- NO ROCKS OR Boulders 4" OR LARGER TO BE USED IN INITIAL BACKFILL.
- ALL BACKFILL MATERIAL SHALL BE SUITABLE NATIVE MATERIAL.
- BACKFILL SHALL BE TAMPED IN 8" LIFTS IN TRAFFIC AREAS, 12" IN NON-TRAFFIC AREAS.
- ACHIEVE 90% COMPACTION IN NON-TRAFFIC AREAS, AND 95% COMPACTION IN TRAFFIC AREAS.
- IF IN EXISTENT 4" TOPSOIL, AND 12" CLEAN SELECT FILL MAY BE REQUIRED.
- NO Boulders 6" IN DIAMETER OR GREATER ALLOWED IN FINAL BACKFILL.

TOWN OF PEMBROKE UTILITY NOTES:

- FOR TRENCHES REQUIRING SHORING AND BRACING, DIMENSIONS SHALL BE TAKEN FROM THE INSIDE FACE OF THE SHORING AND BRACING.
- NO ROCKS OR Boulders 4" OR LARGER TO BE USED IN INITIAL BACKFILL.
- ALL BACKFILL MATERIAL SHALL BE SUITABLE NATIVE MATERIAL.
- BACKFILL SHALL BE TAMPED IN 8" LIFTS IN TRAFFIC AREAS, 12" IN NON-TRAFFIC AREAS.

TOWN OF PEMBROKE UTILITY NOTES:

- FOR TRENCHES REQUIRING SHORING AND BRACING, DIMENSIONS SHALL BE TAKEN FROM THE INSIDE FACE OF THE SHORING AND BRACING.
- NO ROCKS OR Boulders 4" OR LARGER TO BE USED IN INITIAL BACKFILL.
- ALL BACKFILL MATERIAL SHALL BE SUITABLE NATIVE MATERIAL.
- BACKFILL SHALL BE TAMPED IN 8" LIFTS IN TRAFFIC AREAS, 12" IN NON-TRAFFIC AREAS.

TOWN OF PEMBROKE UTILITY NOTES:

- FOR TRENCHES REQUIRING SHORING AND BRACING, DIMENSIONS SHALL BE TAKEN FROM THE INSIDE FACE OF THE SHORING AND BRACING.
- NO ROCKS OR Boulders 4" OR LARGER TO BE USED IN INITIAL BACKFILL.
- ALL BACKFILL MATERIAL SHALL BE SUITABLE NATIVE MATERIAL.
- BACKFILL SHALL BE TAMPED IN 8" LIFTS IN TRAFFIC AREAS, 12" IN NON-TRAFFIC AREAS.

COOKOUT FRESH HANDLES

601 WEST 3RD STREET
PEMBROKE, NORTH CAROLINA

DETAILS

811 Know what's below. Call before you dig. nc811.org or 1-800-632-4949

24 HOUR CONTACT
DAVID SHOTWELL
CONSTRUCTION MANAGER
TELEPHONE: (336) 807-0101

NO.	DATE	DESCRIPTION
1	07-05-17	TOWN COMMENTS
2	07-24-17	TOWN COMMENTS #2

COMMERCIAL SITE DESIGN
802 CREEDMOOR ROAD
RALEIGH, NORTH CAROLINA 27605
(919) 686-6321, FAX: (919) 686-3741
WWW.CSDESIGN.COM

CLIENT:
COOK OUT
15 LAURA LANE SUITE 300
THOMASVILLE, NC 27380
TELEPHONE: (336) 215-7025
FAX: (336) 474-1849

COOKOUT FRESH HANDLES
601 WEST 3RD STREET
PEMBROKE, NORTH CAROLINA

PROJECT NO. OUT-1715
FILENAME: OUT1715-DTL3a
DRAWN BY: DDH
SCALE: N.T.S.
DATE: 05-19-17
SHEET NO. C-7a

811 Know what's below. Call before you dig. nc811.org or 1-800-632-4949