



SYMBOLS:

LIGHTING

FOR LIGHTING SEE LIGHTING FIXTURE SCHEDULE

WIRING DEVICES

- S SINGLE POLE TOGGLE SWITCH 20A/120V ARCHED PART 1991-48" AFF
- St TIME OVERRIDE SWITCH 24 HOUR TIME CLOCK
- Ss OCCUPANCY SENSOR SWITCH 1200VA/120V MT 48" AFF
- DS DIMMER SWITCH 20A/120V ROTARY--CLICK 2000W. INSTALLED IN SINGLE BOX NO DELAYING. MT 48" AFF.
- RO ROTARY SWITCH 20A/120V
- DUPL GROUND OUTLET AS NOTED
- DUPL RECEPTACLE--20A/120V 24" AFF UNLESS NOTED OTHERWISE
- DUPL RECEPTACLE--20A/120V 48" AFF UNLESS NOTED OTHERWISE
- FOURPLEX ELECTRICAL OUTLETS 18" AFF MEASURED TO THE CENTER OF THE OUTLET.
- GFCI DUPL RECEPTACLE 20A/120V 48" AFF UNLESS NOTED OTHERWISE
- DUPL RECEPTACLE/USB PORT 20A/120V 34" AFF UNLESS NOTED OTHERWISE
- DUPL RECEPTACLE/DATA OUTLET 20A/120V 42" AFF UNLESS NOTED OTHERWISE
- JUNCTION BOX -- CEILING MOUNTED
- JUNCTION BOX -- WALL MOUNTED

POWER

- CONDUIT AND WIRE CONCEALED IN CEILING AN/ OR WALL
- CONDUIT AND WIRE CONCEALED IN FLOOR AN/ OR UNDERGARADE
- CONDUIT AND WIRE EXPOSED
- FLEXIBLE CONDUIT
- NEW PANELBOARD 208Y/ 120V 30 4W.
- MOTOR
- DISCONNECT SWITCH 30A/ 3P UNLESS NOTED OTHERWISE
- MOTOR CONTROLLER
- ABOVE FINISHED FLOOR
- NEMA 3R ENCLOSURE
- EXHAUST FAN -- 120V.

FIRE ALARM

- HORN OR SPEAKER WITH STROBE MT 80"/TO TOP OF DEVICE

LEGEND	
[Symbol]	2x4 LED DIFFUSED LENS TROFFER
[Symbol]	TRACK LIGHT
[Symbol]	WALL MOUNTED LIGHT
[Symbol]	RECESSED LIGHT
[Symbol]	LED STRIP
[Symbol]	PENDANT
[Symbol]	EXIT SIGN
[Symbol]	RESTROOM EXHAUST FAN
[Symbol]	CEILING FAN

ELECTRICAL NOTES
 ① RESTROOM EXHAUST FAN, REFER TO M1.0 FOR DETAILS, TYP.

1 LIGHTING PLAN
 E2.1

LAPEER
 ALPHARETTA, GEORGIA
ELECTRICAL PLAN

M. Christopher Baldwin, Architect
 6017 Sandy Springs Circle
 Sandy Springs, Georgia 30328
 (404) 406-9041

Copyright Ownership
 This drawing is the property of M-CINEERS, LLC, and may not be used, copied, or revised without expressed written permission.

Revision		
No.	Date	By

DATE 04/03/2018
 DRAWN CC
 CHECKED SCH

JOB NO.

SHEET NO.
E2.1