



- H FIRE PROTECTION CODED NOTES**
- REUSE AS MUCH AS POSSIBLE FROM THE EXISTING SPRINKLER SYSTEM AND ALARM SYSTEM. MODIFY SYSTEM AS REQUIRED TO MEET CODE. SPRINKLER HEADS IN THE STORE FRONT AND SALES AREA ARE TO BE CONCEALED. FIELD COORDINATE ALL REQUIREMENTS WITH LANDLORD, EXISTING CONDITIONS AND AUTHORITY HAVING JURISDICTION.
  - SPRINKLER HEADS SHOWN FOR REFERENCE ONLY. LICENSED FIRE PROTECTION PROFESSIONAL TO DETERMINE ACTUAL AMOUNT AND LOCATION OF HEADS. ALIGN SPRINKLER HEAD LOCATIONS WITH LIGHTS AND OTHER CEILING ELEMENTS. COORDINATE WITH LANDLORD AND TENANT.
  - CONCEALED SPRINKLER HEAD TO BE MOUNTED IN LOWER DRYWALL CEILING BELOW PLATFORM, WITH PIPING EXTENDED THROUGH JOIST SPACE AND UP IN WALL ABOVE PLATFORM. UPRIGHT SPRINKLER HEAD TO BE MOUNTED ABOVE PLATFORM AREA. COORDINATE ALL PIPING AND HEAD LOCATIONS WITH PLATFORM ACCESS.

OWNER:  
**UNTUCKIT**  
 SHIRTS DESIGNED TO BE WORN UNTUCKED.  
 110 GREENE STREET  
 SUITE 400  
 YORK, NY, 10012

ARCHITECT / ENGINEER:  
**SHREMSHOCK**  
 North Carolina Firm  
 License Number #C-3048  
 www.shremshock.com  
 919.545.9550

Shremshock Architects & Engineers, Inc.  
 7400 W. Clampus Rd. Ste. 150 New Albany, OH 43054  
 1-614-545-9550 | F: 614-545-9555



- G FIRE PROTECTION GENERAL NOTES**
- FINISH AND INSTALL FIRE RATED GYPSUM SLEEVES AND SEAL ON ALL PIPING THAT PENETRATES A FIRE RATED PARTITION.
  - FIRE PROTECTION PLANS MUST BE ENGINEERED AND WET SIGNED AND SEALED BY A LANDLORD APPROVED, LICENSED REGISTERED FIRE PROTECTION CONTRACTOR IN THE LOCAL JURISDICTION. FIRE PROTECTION CONTRACTOR SHALL FIELD VERIFY AND COORDINATE REQUIREMENTS WITH LANDLORD PRIOR TO BID AND INCLUDE THE COST OF THIS WORK IN THIS BID.
- FIRE PROTECTION CONTRACTOR SHALL MODIFY SPRINKLER HEADS AND PIPING FOR NEW OWNER STORE LAYOUT. RUN HYDRAULIC CALCULATIONS AS REQUIRED. REFER TO SPECIFICATIONS. DESIGN PER LAYOUT TO MEET NFPA 13, LOCAL AUTHORITY HAVING JURISDICTION AND LANDLORD REQUIREMENTS.

STORE NO: -

PROJECT LOCATION:  
 THE STREETS AT SOUTHPOINT  
 6910 FAYETTEVILLE RD  
 SPACE#: 1140  
 DURHAM, NC 27713

DESIGN TYPE: -

REVISIONS:  
 REQUIRED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

\*INDICATES NO REVISION TO THIS SHEET

DRAWN BY: CMH  
 CHECKED BY: JTP

Bid Set  
 TRCI  
 04.10.18

DRAWING TITLE:  
**FIRE PROTECTION PLAN, NOTES & DETAILS**

DATE ISSUED:  
 03/30/2018

PROJECT NO:  
 180088

DRAWING NO:  
**FP1.0**

**Order Plans @**

