


| Egress Width | |
|---|--|
| Per Section 1005.3.2: 0.15 inches per occupant required. Minimum width of one exit is 36" | |
| Total Occupant Load: 170 Occupants (per I.100) | |
| Required Width of Egress: 25.5 Inches | |
| Egress Width Provided: 476 Inches | |



FIRE & LIFE SAFETY PLAN

3/16" = 1'-0"



REVISIONS

| NO. | DATE | REMARKS |
|-----|----------|----------------------|
| 2 | 03.27.18 | BLDG. DEPT. COMMENTS |
| 1 | 03.07.18 | FIRE DEPT. COMMENTS |



RAINBOW CHILD CARE CENTER
C - PROTOTYPE
2609 W. LAKE MARY BLVD.
LAKE MARY, FL 32746

PROJECT NO: 2017.0250
DATE: 12.22.17

T.101
FIRE & LIFE SAFETY PLAN

CHECKED: RC DRAWN: JC

Order Plans

WWW.ONLINE.COM