



KEYED NOTES

1. NEW DUAL TECHNOLOGY WALL SWITCH OCCUPANCY SENSOR FROM SENSOR SWITCH MODEL WSD-PDT.
2. WALL MOUNT EMERGENCY FIXTURE MIN 6" BELOW CEILING. EMERGENCY LIGHTING TO BE CONNECTED TO LOCAL CIRCUIT AND AHEAD OF ANY SWITCHING.
3. PROVIDE CONNECTION TO EXTERIOR SIGN. PROVIDE UNLESS REQUIRED DISCONNECT SWITCH IF NOT PROVIDED WITH SIGN. COORDINATE EXACT LOCATION AND HEIGHT WITH OWNER. IF THE INSTALLATION OF AN INTERNALLY ILLUMINATED SIGN IS NOT PERMITTED BY THE AUTHORITIES HAVING JURISDICTION PROVIDE AND INSTALL A GOOSENECK FIXTURE ABOVE THE SIGN. LOCATE GOOSENECK AS REQUIRED FOR PROPER ORIENTATION OF THE SIGN. SIGN FURNISHED BY OWNER, INSTALLED BY CONTRACTOR. GOOSENECK FIXTURE MODEL BARNLIGHT #G-WHS20-PC-600-615.

Order Plans

ELECTRICAL PLAN - LIGHTING

3/16" = 1'-0"



NO.	DATE	REVISIONS	REMARKS



RAINBOW CHILD CARE CENTER

C - PROTOTYPE
2609 W. LAKE MARY BLVD.
LAKE MARY, FL 32746

PROJECT NO: 2017.0250
DATE: 12.22.17

E.100
ELECTRICAL PLAN - LIGHTING

CHECKED: AG DRAWN: DMS

COPYRIGHT © 2017 INTERPLAN. REVERSE COPYRIGHT & OTHER RIGHTS RESTRICTING THESE DOCUMENTS TO THE ORIGINAL SET OR PURPOSE FOR WHICH THEY WERE PREPARED. REPRODUCTIONS, CHANGES OR ASSIGNMENTS ARE PROHIBITED.