



LIGHTING CONTROL

LIGHTING CONTROL SYSTEM SCHEMATIC:



LIGHTING CONTROL SYSTEM SCHEMATIC PLAN NOTES:


- 1. MASTER LIGHTING CONTROL PANEL. SEE PLANS FOR EXACT LOCATION. REFER TO MASTER LIGHTING CONTROL PANEL SCHEDULE FOR MORE INFORMATION. PROVIDE 120V POWER AS REQUIRED. DO NOT USE LIGHTING BRANCH CIRCUIT FOR CONTROL PANEL POWER.



VERRIDE AND LOCAL SWITCH FACEPLATE DETAIL NOTES:

- 1. STANDARD OVERRIDE SWITCH FACEPLATES/BUTTONS SHALL BE ACUITY BRIGHTON DIGITAL SWITCH.
- 2. CATALOG NUMBERS AS FOLLOWS:
 2-BUTTON - BR2 BWH PWH
 4-BUTTON - BR4 BWH PWH
 6-BUTTON - BR6 BWH PWH
- 3. SUBSCRIPT INDICATES SWITCH LEG.
- 4. CONNECT DIGITAL SWITCHES TO BLUE BOX VIA CAT5 PATCH CORDS WITH RJ45 CONNECTORS.

DIGITAL SWITCH DETAIL



LIGHTING CONTROL PANEL SCHEDULE - LCP

ACCOUNTING	EXTERIOR PHOTO CELL	COMM. MEDIA	DPCS / IDCS INTERFACE	BMS INTERFACE	NETWORK INTERFACE	MODEM	AVAILABLE FAULT CURRENT SEE FAULT CURRENT NOTE ON SHEET E-4.0	REMARKS			
	YES	COPPER	-	-	-	-	ACUITY BLUE BOX GR1419 LT				
PANEL#	CKT#	RELAY	DESCRIPTION	LOCAL SWITCH	OVERRIDE SWITCH	ZONE NUMBER	MISCELLANEOUS				
A	2	1	Lighting - Dining - Track and Pendant	-	-	a	-				
A	2 / 6	2	Lighting - Dining - 2x2 Fixtures	-	-	b	-				
A	2	3	Lighting - POS Sales	-	-	c	-				
D	40	4	Digital Menu Boards	-	-	c	-				
EXISTING	EXISTING	5	Show Window Receptacles	-	-	c	-				
A	38	6	Restroom Exhaust Fan	-	-	c	-				
A	4	7	Lighting - Back of House	-	-	d	-				
EXISTING	EXISTING	8	Lighting - Exterior	-	-	e	-				
EXISTING	EXISTING	9	Lighting - Exterior	-	-	f	-				
EXISTING	EXISTING	10	Lighting - Exterior	-	-	g	-				
A	20 / 23	11	Lighting - Building Signs	-	-	h	-				
EXISTING	EXISTING	12	Lighting - Parking Lot and Directional	-	-	i	-				
B	31	13	Drive Through Menu Canopy	-	-	j	-				
-	-	14	Spare	-	-	-	-				
-	-	15	Spare	-	-	-	-				
-	-	16	Spare	-	-	-	-				
ZONE NUMBER	TIME ON	TIME OFF	PHOTO ON	PHOTO OFF	DESCRIPTION	ZONE NUMBER	TIME ON	TIME OFF	PHOTO ON	PHOTO OFF	DESCRIPTION
1	-	-	-	-	-	5	-	-	-	-	-
2	-	-	-	-	-	6	-	-	-	-	-
3	-	-	-	-	-	7	-	-	-	-	-

BLUE BOX LIGHTING CONTROL PANEL SHALL BE PROVIDED BY NATIONAL ACCT. WITH VILLA LIGHTING, UON CONTACT DEANNA MCCLANAHAN AT 314-633-0508 OR DEANNA.MCCLANAHAN@VILLALIGHTING.COM

Order Plans

WWW.LDILine.com

THESE PLANS ARE CONFIDENTIAL PROPERTY OF DUNKIN' BRANDS, INC. UNDER RESTRICTED ACCESS

dunkin'
brands

PROJECT NO.: 17229

NRD national restaurant architects & engineers
3005 Carrington Mill Blvd., Morrisville, NC 27560
ph: 919 544 7251 fax: 919 544 9399
A Division of LMHT Associates

PROFESSIONAL SEAL
COMMISSION OF VETERINARY MEDICINE
HEALTH CARE REGULATORY BOARD
JULY 12, 2022

DATE	SCALE	DRAWN	CKD	APPD
3-18-18				

SET REVISIONS

NO	DESCRIPTION	DATE

SHEET REVISIONS

--	--

DD FRESH BREW 1.0
DUNKIN DESIGN GUIDELINES

**ELECTRICAL
AUTOMATIC CONTROL PANEL**

PC NUMBER

E-5.1