

GENERAL SHEET NOTES

A. ALL VISUAL DEVICE CANDELA RATINGS TO BE 75cd UNLESS OTHERWISE NOTED.

B. ALL CEILING MOUNTED SMOKE DETECTORS SHALL BE INSTALLED A MINIMUM OF 3 FEET AWAY FROM ANY HVAC SUPPLY AND RETURN DIFFUSERS.

SHEET KEYNOTES


1. PROVIDE PULL STATION WITH KEY-OPERATED COVER.
2. SMOKE DETECTOR AND FIRE ALARM RELAY TO OPERATE COORDINATION FIRE/SMOKE DAMPER. RELAY CAN BE A PART OF THE SMOKE DETECTOR BASE. DUCT DETECTOR MUST BE INSTALLED IN DUCT WITHIN 5' OF DAMPER.

COORDINATION DRAWINGS

SEE COVER SHEET FOR COORDINATION NOTES.

SYMBOLS LEGEND

	EXISTING WALL, DOOR, WINDOW, MILLWORK, FIXTURE OR OTHER FIXTURE OR ASSEMBLY TO REMAIN
	NEW WALL
	SMOKE TIGHT WALL
	2-HOUR FIRE/ SMOKE RATED WALL
	1 HOUR FIRE RATED WALL
	1 HOUR SMOKE BARRIER WALL
	NO PIPING OR DUCTWORK SHALL BE ROUTED THROUGH ELECTRICAL AND/OR DATA ROOMS.
	EXISTING CONCRETE COLUMN




E1 "F" WING SECOND FLOOR OVERALL FIRE ALARM FLOOR PLAN
SCALE: 1/8" = 1'-0"

three inches = one foot
one and one half inches = one foot
one inch = one foot
three quarters inch = one foot
one half inch = one foot
one eighth inch = one foot
one quarter inch = one foot
one eighth inch = one foot

REVISIONS	DESCRIPTION	DATE

Department of Veterans Affairs
Charlie Norwood
VA Medical Center
1 Freedom Way
Augusta, Ga. 30904



Architect/Engineer Address

Harrell, Saltrick & Hopper

Design & Management Solutions for the Built Environment
 1015 TOWNE POINT DRIVE
 CHARLOTTE, NC 28227
 WWW.HSRPC.COM
 P 704.521.1320
 F 704.521.0833
 COPYRIGHT © 2012 HARRELL, SALTRICK & HOPPER, P.C.
 HIGH PROJECT # 12015

Recommended Approvals:

1. MEDICAL CENTER DIRECTOR	6. OPERATIONS SERVICE LINE MANAGER
2. ASSISTANT DIRECTOR	7. INFECTION CONTROL MANAGER
3. CHIEF OF STAFF	8. SAFETY MANAGER
4. ASSOC. DIRECTOR	9. GENERAL ENGINEER
5. SERVICE LINE MGRS.	10. COR

Drawing Title

"F" WING OVERALL FIRE ALARM FLOOR PLAN

100% CONSTRUCTION DOCUMENTS

FULLY SPRINKLERED

Project Title

RENOVATE MENTAL HEALTH UNITS

Drawn	Building Number	AutoCAD File Name
Checked	Reviewed	Const. Contract No.

Date

February 10, 2017

Project Number

509-12-104

DRAWING No.

FA101

