

GENERAL SHEET NOTES

- A. MECHANICAL CONTRACTOR SHALL COORDINATE SHUTDOWNS OF EXISTING SYSTEMS WITH COR A MINIMUM OF 14 DAYS PRIOR.
- B. EXISTING EXHAUST FANS, EF-1F4, EF-2F4 AND EF-3F4 SHALL REMAIN IN OPERATION DURING CONSTRUCTION. SEE RISER DIAGRAM ON SHEET M503.
- C. UPON DIRECTION OF THE COR, MECHANICAL CONTRACTOR SHALL REMOVE ALL MECHANICAL SYSTEMS TO BE DEMOLISHED. EQUIPMENT, DUCTWORK, PIPING, CONTROLS AND ASSOCIATED HANGERS AND APPURTENANCES BACK TO POINTS INDICATED ON DRAWING.
- D. MECHANICAL CONTRACTOR SHALL PROTECT ALL EXISTING EQUIPMENT OR DUCTWORK SHOWN TO REMAIN DURING CONSTRUCTION. MECHANICAL CONTRACTOR SHALL REPAIR OR REPLACE ALL EQUIPMENT DAMAGED DURING DEMOLITION AND CONSTRUCTION.

SHEET KEYNOTES

- 1. REMOVE EXISTING EXHAUST DUCTWORK BACK TO POINT INDICATED.
- PROVIDE COVER OVER OPENING TO PREVENT DEBRIS FROM ENTERING EXHAUST SYSTEM DURING DEMOLITION AND CONSTRUCTION.
- 3. PROVIDE BALANCING DAMPER AND BALANCE EXHAUST TO 1,055 CFM DURING DEMOLITION AND CONSTRUCTION. SEE SHEET MH101 FOR NEW EXHAUST CONNECTION.
- 4. PROVIDE BALANCING DAMPER AND BALANCE EXHAUST TO 1,015 CFM DURING DEMOLITION AND CONSTRUCTION. SEE SHEET MH101 FOR NEW EXHAUST CONNECTION.
- 5. PROVIDE BALANCING DAMPER AND BALANCE EXHAUST TO 705 CFM DURING DEMOLITION AND CONSTRUCTION. SEE SHEET MH101 FOR NEW EXHAUST CONNECTION.

DEMOLITION LEGEND

- EXISTING DUAL DUCT TERMINAL TO BE REMOVED
- EXISTING SLOT DIFFUSER TO BE REMOVED
- EXISTING DUCT TO BE REMOVED


COORDINATION DRAWINGS

SEE COVER SHEET FOR COORDINATION NOTES.

SYMBOLS LEGEND

- EXISTING WALL, DOOR, WINDOW, MILLWORK, FIXTURE OR OTHER FIXTURE OR ASSEMBLY TO BE REMOVED.
- EXISTING WALL, DOOR, WINDOW, MILLWORK, FIXTURE OR OTHER FIXTURE OR ASSEMBLY TO REMAIN.
- NEW WALL
- SMOKE TIGHT WALL
- 2-HOUR FIRE/ SMOKE RATED WALL
- 1 HOUR FIRE RATED WALL
- 1 HOUR SMOKE BARRIER WALL
- PROJECT LIMITS OF WORK
- NO PIPING OR DUCTWORK SHALL BE ROUTED THROUGH ELECTRICAL AND/OR DATA ROOMS.
- EXISTING CONCRETE COLUMN


KEY PLAN



F1 "F" WING MECHANICAL DUCTWORK PLAN - DEMOLITION
SCALE: 1/8" = 1'-0"

| REVISION | DESCRIPTION | DATE |
|----------|-------------|------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

Department of Veterans Affairs
Charlie Norwood
VA Medical Center
 1 Freedom Way
 Augusta, Ga. 30904



Architect/Engineer Address
Harrell, Saltrick & Hopper
 Design & Management Solutions for the Built Environment
 8018 TOWER POINT DRIVE
 CHARLOTTE, NC 28227
 WWW.HSHPC.COM
 P 704.841.1330
 F 704.350.0833
 COPYRIGHT © 2012 HARRELL, SALTRICK & HOPPER, PC
 NEW PROJECT # 12015

| Recommended Approvals: | |
|----------------------------|------------------------------------|
| 1. MEDICAL CENTER DIRECTOR | 6. OPERATIONS SERVICE LINE MANAGER |
| 2. ASSISTANT DIRECTOR | 7. INFECTION CONTROL MANAGER |
| 3. CHIEF OF STAFF | 8. SAFETY MANAGER |
| 4. ASSOC. DIRECTOR | 9. GENERAL ENGINEER |
| 5. SERVICE LINE MGRS. | 10. COR |

| |
|--|
| Drawing Title "F" WING MECHANICAL DUCTWORK PLAN - DEMOLITION |
| 100% CONSTRUCTION DOCUMENTS |
| FULLY SPRINKLERED |

| | |
|--|------------------------------|
| Project Title RENOVATE MENTAL HEALTH UNITS | Date February 10, 2017 |
| Drawn ows | Project Number 509-12-104 |
| Building Number | AutoCAD File Name |
| Checked | Const. Contract No. |
| Reviewed | |

| |
|-----------------------------|
| DRAWING No. MD101 |
|-----------------------------|

