



1 Aboveground - Plumbing Plan
3/32" = 1'-0"

- GENERAL NOTE:**
- NO CONDENSATE SHALL BE ROUTED TO THE SANITARY SEWER.
- KEYED NOTES:**
- HUB OUTLET COORDINATE FINAL INSTALLED LOCATION WITH REFRIGERATION EQUIPMENT SUPPLIER AND LOCAL CODE REQUIREMENTS.
 - 2" SANITARY VENT DOWN IN/ALLON WALL REFER TO DRAWING P1-01 FOR CONTINUATION.
 - 2" SANITARY VENT UP TO 3" SANITARY VENT THROUGH ROOF. INSTALL A MINIMUM OF 10' AWAY FROM ANY ROOFTOP UNIT'S OUTDOOR AIR INTAKE OPENING.
 - FLOOR SINK COORDINATE LOCATION WITH EQUIPMENT ABOVE.
 - EXISTING RAIN CONDUCTOR AND OVERFLOW RAIN CONDUCTOR PIPING UP TO ROOF SUMP AND OVERFLOW ROOF SUMP ABOVE.
 - EXISTING RAIN CONDUCTOR PIPING ROUTED DOWN WALL TO UNDERGROUND.
 - EXISTING OVERFLOW RAIN CONDUCTOR PIPE ROUTED DOWN EXTERIOR WALL TO DOWNSPOUT NOZZLE.
 - NATURAL GAS METER. METER SHALL BE SIZED BY THE LOCAL UTILITY PROVIDER FOR 2,070 CFH WITH A GAS PRESSURE OF 7" WC. ALL PIPING HAS BEEN SIZED BASED ON A MAXIMUM DEVELOPED PIPE LENGTH OF 300 FEET WITH A PRESSURE DROP OF 0.5" WC.
 - STAINLESS STEEL TRENCH DRAIN CENTERED AND 12" OUTSIDE OF COOLER/FREEZER DOOR.
 - CONDENSATE DRAIN LINE BY REFRIGERATION CONTRACTOR.
 - CONDENSATE DRAINS TO SPILL TO HUB OUTLET BELOW WITH AIR GAP.
 - 2" PUMPED CONDENSATE TO TIE INTO EXISTING 6" RAIN CONDUCTOR PIPING.
 - 2" SUMP PUMP VENT UP ALONG WALL TO 3" VENT THROUGH ROOF.
 - 3/4" CONDENSATE FROM DUCTLESS SPLIT UNIT. ROUTE DOWN WALL AND SPILL TO HUB OUTLET UNDER REFRIGERATION EQUIPMENT.

Order Plans @

WWW.LDILine.com