



1 Aboveground - Plumbing Plan  
3/32" = 1'-0"

GENERAL NOTE:

1. NO CONDENSATE SHALL BE ROUTED TO THE SANITARY SEWER.

KEYED NOTES: (A)

1. HUB OUTLET COORDINATE FINAL INSTALLED LOCATION WITH REFRIGERATION EQUIPMENT SUPPLIER AND LOCAL CODE REQUIREMENTS.
2. 2" SANITARY VENT DOWN IN/ALLON WALL REFER TO DRAWING P1-01 FOR CONTINUATION.
3. 2" SANITARY VENT UP TO 3" SANITARY VENT THROUGH ROOF. INSTALL A MINIMUM OF 10' AWAY FROM ANY ROOFTOP UNIT'S OUTDOOR AIR INTAKE OPENING.
4. FLOOR SINK COORDINATE LOCATION WITH EQUIPMENT ABOVE.
5. EXISTING RAIN CONDUCTOR AND OVERFLOW RAIN CONDUCTOR PIPING UP TO ROOF SUMP AND OVERFLOW ROOF SUMP ABOVE.
6. EXISTING RAIN CONDUCTOR PIPING ROUTED DOWN WALL TO UNDERGROUND.
7. EXISTING OVERFLOW RAIN CONDUCTOR PIPE ROUTED DOWN EXTERIOR WALL TO DOWNSPOUT NOZZLE.
8. NATURAL GAS METER, METER SHALL BE SIZED BY THE LOCAL UTILITY PROVIDER FOR 2,070 CFH WITH A GAS PRESSURE OF 7" WC. ALL PIPING HAS BEEN SIZED BASED ON A MAXIMUM DEVELOPED PIPE LENGTH OF 300 FEET WITH A PRESSURE DROP OF 0.5" WC.
9. STAINLESS STEEL TRENCH DRAIN CENTERED AND 12" OUTSIDE OF COOLER/FREEZER DOOR.
10. CONDENSATE DRAIN LINE BY REFRIGERATION CONTRACTOR.
11. CONDENSATE DRAINS TO SPILL TO HUB OUTLET BELOW WITH AIR GAP.
12. 2" PUMPED CONDENSATE TO TIE INTO EXISTING 6" RAIN CONDUCTOR PIPING.
13. 2" SUMP PUMP VENT UP ALONG WALL TO 3" VENT THROUGH ROOF.
14. 3/4" CONDENSATE FROM DUCTLESS SPLIT UNIT, ROUTE DOWN WALL AND SPILL TO HUB OUTLET UNDER REFRIGERATION EQUIPMENT.

Order Plans @ WWW.LDILine.com