

Order Plans

WWW.LDLINE.COM@

PANEL: A (SECT. 1)

VOLTAGE & PHASE: 120/208Y-3Ø  
MOUNTING: SURFACE

AC RATING: 50KVA  
AMPERAGE: 400A  
MAIN: MLO

DESCRIPTION	KVA	BKR	PHASE	BKR	KVA	DESCRIPTION
EMERGENCY LIT	0.1	20/1	1	A	2	RTU-01
EXTERIOR LIGHT	0.1	20/1	3	B	4	-----
CONTRACTOR	0.1	20/1	5	C	6	-----
OT REC- SERVICE ON ROOF	0.4	20/1	7	A	8	RTU-02
AIR CURTAIN	0.5	20/1	9	B	10	-----
REC- EXTERIOR	0.4	20/1	11	C	12	-----
SPACE			13	A	14	SPACE
SPACE			15	B	16	SPACE
SPACE			17	C	18	SPACE
SPACE			19	A	20	SPACE
SPACE			21	B	22	SPACE
SPACE			23	C	24	SPACE
SPACE			25	A	26	SPACE
SPACE			27	B	28	SPACE
SPACE			29	C	30	SPACE
SPACE			31	A	32	SPACE
SPACE			33	B	34	SPACE
SPACE			35	C	36	SPACE
SPACE			37	A	38	SPACE
SPACE			39	B	40	SPACE
SPACE			41	C	42	SPACE

EXISTING LOAD	CONNECTED	D.F.	DEMAND	KVA LOAD PER PHASE:
COOLING:	0.0	x	1.00	0.0
HEATING:	26.4	x	1.00	26.4
KITCHEN:	0.0	x	0.00	0.0
LIGHTING:	0.0	PER NEC 220.56	0.0	PHASE A: 99.6%
MOTORS:	0.2	x	1.25	0.3
LARGEST MOTOR:	0.5	x	1.00	0.5
OTHER:	0.0	PER NEC 220.18(A)	0.0	PHASE B: 101.1%
RECEPTACLES:	0.1	x	1.00	0.1
	0.7	PER NEC 220.44	0.7	PHASE C: 99.3%
	27.9	DEMAND KVA:	28.0	HIGHEST PHASE LOAD
	77.8	DEMAND AMPS:	77.7	78.5 AMPERES

NOTES:  
(1) - ROUTE THRU CONTACTOR FOR TIMELOCK ON/TIMELOCK OFF OPERATION.

NOTE: CONTRACTOR SHALL PROVIDE SEPARATE NEUTRALS OR HANDLE TIES ON MULTIWIRE BRANCH CIRCUITS [NEC 210.4 (B)]

PANEL: A (SECT. 2)

VOLTAGE & PHASE: 120/208Y-3Ø  
MOUNTING: SURFACE

AC RATING: 50KVA  
AMPERAGE: 400A  
MAIN: MLO

DESCRIPTION	KVA	BKR	PHASE	BKR	KVA	DESCRIPTION
SPACE			43	A	44	SPACE
SPACE			45	B	46	SPACE
SPACE			47	C	48	SPACE
SPACE			49	A	50	SPACE
SPACE			51	B	52	SPACE
SPACE			53	C	54	SPACE
SPACE			55	A	56	SPACE
SPACE			57	B	58	SPACE
SPACE			59	C	60	SPACE
SPACE			61	A	62	SPACE
SPACE			63	B	64	SPACE
SPACE			65	C	66	SPACE
SPACE			67	A	68	SPACE
SPACE			69	B	70	SPACE
SPACE			71	C	72	SPACE
SPACE			73	A	74	SPACE
SPACE			75	B	76	SPACE
SPACE			77	C	78	SPACE
SPACE			79	A	80	SPACE
SPACE			81	B	82	SPACE
SPACE			83	C	84	SPACE

EXISTING LOAD	CONNECTED	D.F.	DEMAND	KVA LOAD PER PHASE:
COOLING:	0.0	x	0.00	0.0
HEATING:	0.0	x	0.00	0.0
KITCHEN:	0.0	PER NEC 220.56	0.0	PHASE A: 0.0%
LIGHTING:	0.0	x	1.25	0.0
MOTORS:	0.0	x	1.00	0.0
LARGEST MOTOR:	0.0	PER NEC 220.18(A)	0.0	PHASE B: 0.0%
OTHER:	0.0	x	1.00	0.0
RECEPTACLES:	0.0	PER NEC 220.44	0.0	PHASE C: 0.0%
	0.0	DEMAND KVA:	0.0	0.0 AMPERES
	0.0	DEMAND AMPS:	0.0	

NOTES:  
(1) - ROUTE THRU CONTACTOR FOR TIMELOCK ON/TIMELOCK OFF OPERATION.

NOTE: CONTRACTOR SHALL PROVIDE SEPARATE NEUTRALS OR HANDLE TIES ON MULTIWIRE BRANCH CIRCUITS [NEC 210.4 (B)]

PANEL: A (SECT. 3)

VOLTAGE & PHASE: 120/208Y-3Ø  
MOUNTING: SURFACE

AC RATING: 50KVA  
AMPERAGE: 400A  
MAIN: MLO

DESCRIPTION	KVA	BKR	PHASE	BKR	KVA	DESCRIPTION
SPACE			85	A	86	SPACE
SPACE			87	B	88	SPACE
SPACE			89	C	90	SPACE
SPACE			91	A	92	SPACE
SPACE			93	B	94	SPACE
SPACE			95	C	96	SPACE
SPACE			97	A	98	SPACE
SPACE			99	B	100	SPACE
SPACE			101	C	102	SPACE
SPACE			103	A	104	SPACE
SPACE			105	B	106	SPACE
SPACE			107	C	108	SPACE
SPACE			109	A	110	SPACE
SPACE			111	B	112	SPACE
SPACE			113	C	114	SPACE
SPACE			115	A	116	SPACE
SPACE			117	B	118	SPACE
SPACE			119	C	120	SPACE
SPACE			121	A	122	SPACE
SPACE			123	B	124	SPACE
SPACE			125	C	126	SPACE

EXISTING LOAD	CONNECTED	D.F.	DEMAND	KVA LOAD PER PHASE:
COOLING:	0.0	x	0.00	0.0
HEATING:	0.0	x	0.00	0.0
KITCHEN:	0.0	PER NEC 220.56	0.0	PHASE A: 0.0%
LIGHTING:	0.0	x	1.25	0.0
MOTORS:	0.0	x	1.00	0.0
LARGEST MOTOR:	0.0	PER NEC 220.18(A)	0.0	PHASE B: 0.0%
OTHER:	0.0	x	1.00	0.0
RECEPTACLES:	0.0	PER NEC 220.44	0.0	PHASE C: 0.0%
	0.0	DEMAND KVA:	0.0	0.0 AMPERES
	0.0	DEMAND AMPS:	0.0	

NOTES:  
(1) - ROUTE THRU CONTACTOR FOR TIMELOCK ON/TIMELOCK OFF OPERATION.

NOTE: CONTRACTOR SHALL PROVIDE SEPARATE NEUTRALS OR HANDLE TIES ON MULTIWIRE BRANCH CIRCUITS [NEC 210.4 (B)]

PANEL: HP (NEMA 3R)

VOLTAGE & PHASE: 120/208Y-3Ø  
MOUNTING: SURFACE

AC RATING: 35KVA  
AMPERAGE: 100A  
MAIN: MCB

DESCRIPTION	KVA	BKR	PHASE	BKR	KVA	DESCRIPTION
EXTERIOR LIGHTING (1)	0.7	20/1	1	A	2	20/1 0.1 LIS-RISER ROOM
EXTERIOR LIGHTING (1)	0.5	20/1	3	B	4	20/2 1.5 EWH-01
CONTRACTOR	0.1	20/1	5	C	6	-----
SPACE			7	A	8	SPACE
SPACE			9	B	10	SPACE
SPACE			11	C	12	SPACE
SPACE			13	A	14	SPACE
SPACE			15	B	16	SPACE
SPACE			17	C	18	SPACE

EXISTING LOAD	CONNECTED	D.F.	DEMAND	KVA LOAD PER PHASE:
COOLING:	0.0	x	0.00	0.0
HEATING:	0.0	x	0.00	0.0
KITCHEN:	0.0	PER NEC 220.56	0.0	PHASE A: 65.4%
LIGHTING:	1.3	x	1.25	1.7
MOTORS:	0.0	x	1.00	0.0
LARGEST MOTOR:	0.0	PER NEC 220.18(A)	0.0	PHASE B: 133.9%
OTHER:	3.1	x	1.00	3.1
RECEPTACLES:	0.0	PER NEC 220.44	0.0	PHASE C: 100.8%
	4.4	DEMAND KVA:	4.8	17.7 AMPERES
	12.3	DEMAND AMPS:	13.2	

NOTES:  
(1) - ROUTE THRU CONTACTOR FOR PHOTOCELL ON/TIMELOCK OFF OPERATION.

NOTE: CONTRACTOR SHALL PROVIDE SEPARATE NEUTRALS OR HANDLE TIES ON MULTIWIRE BRANCH CIRCUITS [NEC 210.4 (B)]



Hoskins Engineering, LLC  
1357 Dalesford Drive  
Alpharetta, GA 30004  
Phone/Fax: (878) 463-5074

ZANARDO ARCHITECTS, P.C.  
3675 CRESTWOOD PARKWAY  
SUITE 500  
DUBLIN, GA 30134  
770.806.1031

CREEKSIDE RETAIL  
1211 FRIENDSHIP RD.  
BRASELTON, GA

date 5/22/18  
drawn MH  
checked MH  
proj# 18029

ELECTRICAL  
PANEL SCHEDULES

© This drawing is copyrighted and the property of the engineer. It shall not be reproduced, published, or used in any way without the expressed written permission of the engineer.

FOR CONSTRUCTION

18029

DATE	REVISION	BY	DATE
5/22/18	PERMIT REVIEW		
	REVISION #5		
	REVISION #4		
	REVISION #3		
	REVISION #2		
	REVISION #1		

18029