

15: Heating, Ventilating, and Air Conditioning:

GENERAL INSTRUCTIONS

GENERAL REQUIREMENTS

REQUIREMENTS UNDER DIVISION ONE AND THE GENERAL AND SUPPLEMENTARY CONDITIONS OF THESE SPECIFICATIONS SHALL BE A PART OF THIS SECTION.

DEFINITIONS

FURNISH: THE TERM "FURNISH" IS USED TO MEAN "SUPPLY AND DELIVER TO THE PROJECT SITE, READY FOR UNLOADING, UNPACKING, ASSEMBLY, INSTALLATION AND SIMILAR OPERATIONS."

INSTALL: THE TERM "INSTALL" IS USED TO DESCRIBE OPERATIONS AT THE PROJECT SITE INCLUDING THE ACTUAL UNLOADING, UNPACKING, ASSEMBLY, ERECTION, PLACING, ANCHORING, APPLYING, WORKING TO DIMENSION, FINISHING, CURING, PROTECTING, CLEANING, AND SIMILAR OPERATIONS."

PROVIDE: THE TERM "PROVIDE" MEANS "TO FURNISH AND INSTALL, COMPLETE AND READY FOR THE INTENDED USE."

FURNISHED BY OWNER OR FURNISHED BY OTHERS: THE ITEM WILL BE FURNISHED BY THE OWNER OR OTHERS. IT IS TO BE INSTALLED AND CONNECTED UNDER THE REQUIREMENTS OF THIS DIVISION, COMPLETE AND READY FOR OPERATION, INCLUDING ITEMS INCIDENTAL TO THE WORK, INCLUDING SERVICES NECESSARY FOR PROPER INSTALLATION AND OPERATION.

ENGINEER: WHERE REFERENCED IN THIS DIVISION, "ENGINEER" IS THE ENGINEER OF RECORD AND THE DESIGN PROFESSIONAL FOR THE WORK UNDER THIS DIVISION, AND IS A CONSULTANT TO, AND AN AUTHORIZED REPRESENTATIVE OF, THE ARCHITECT, AS DEFINED IN THE GENERAL AND/OR SUPPLEMENTARY CONDITIONS. WHEN USED IN THIS DIVISION, IT MEANS INCREASED INVOLVEMENT BY, AND OBLIGATIONS TO, THE ENGINEER, IN ADDITION TO INVOLVEMENT BY, AND OBLIGATIONS TO, THE ARCHITECT.

AHJ: THE LOCAL CODE AND/OR INSPECTION AGENCY (AUTHORITY) HAVING JURISDICTION OVER THE WORK.

THE TERMS "APPROVED EQUAL," "EQUIVALENT," OR "EQUAL" ARE USED SYNONYMOUSLY AND ACCEPTABLE TO THE ARCHITECT AS EQUIVALENT TO THE ENGINEER AS EQUIVALENT TO THE ITEM OR MANUFACTURER SPECIFIED. THE TERM "APPROVED" SHALL MEAN LABELED, LISTED, OR BOTH, BY A NATIONALLY RECOGNIZED TESTING LABORATORY (E.G. UL, ETL, CSA), AND ACCEPTABLE TO THE AHJ OVER THIS PROJECT.

PREBID SITE VISIT

PRIOR TO SUBMITTING BID, VISIT THE SITE OF THE PROPOSED WORK AND BECOME FULLY INFORMED AS TO THE CONDITIONS UNDER WHICH THE WORK IS TO BE DONE. FAILURE TO DO SO WILL NOT BE CONSIDERED SUFFICIENT JUSTIFICATION TO REQUEST OR OBTAIN EXTRA COMPENSATION OVER AND ABOVE THE CONTRACT PRICE.

MATERIAL AND WORKMANSHIP

PROVIDE NEW MATERIAL, EQUIPMENT, AND APPARATUS UNDER THIS CONTRACT UNLESS OTHERWISE SPECIFIED. DESIGN OR MATERIAL FOR A PERIOD OF 12 MONTHS FROM DATE OF SUBSTANTIAL COMPLETION, UNLESS SPECIFIC ITEMS ARE NOTED TO CARRY A LONGER WARRANTY IN THE CONSTRUCTION DOCUMENTS OR MANUFACTURER'S STANDARD WARRANTY EXCEEDS 12 MONTHS.

THE COMPLETE INSTALLATION SHALL FUNCTION AS DESIGNED AND INTENDED WITH RESPECT TO EFFICIENCY, CAPACITY, NOISE LEVEL, ETC. ABNORMAL NOISE CAUSED BY RATTLING EQUIPMENT, VIBRATIONS, AND SHAKES IN ROTATING COMPONENTS WILL NOT BE ACCEPTABLE. IN GENERAL, MATERIALS AND EQUIPMENT SHALL BE OF COMMERCIAL SPECIFICATION GRADE IN QUALITY. LIGHT DUTY AND RESIDENTIAL TYPE EQUIPMENT WILL NOT BE ACCEPTED.

REPAIR OR REPLACE PUBLIC AND PRIVATE PROPERTY DAMAGED AS A RESULT OF WORK PERFORMED UNDER THIS CONTRACT TO THE SATISFACTION OF AUTHORITIES AND REGULATIONS HAVING JURISDICTION.

COORDINATION

COORDINATE WORK WITH THAT OF OTHER TRADES SO THAT THE VARIOUS COMPONENTS OF THE SYSTEMS WILL BE INSTALLED AT THE PROPER TIME, WILL FIT THE AVAILABLE SPACE, AND WILL ALLOW PROPER SERVICE ACCESS TO THOSE ITEMS REQUIRING MAINTENANCE. COMPONENTS WHICH ARE INSTALLED WITHOUT REGARD TO THE ABOVE SHALL BE RELOCATED AT NO ADDITIONAL COST TO THE OWNER.

UNLESS OTHERWISE INDICATED, THE GENERAL CONTRACTOR WILL PROVIDE CHASES AND OPENINGS IN BUILDING CONSTRUCTION REQUIRED FOR INSTALLATION OF THE SYSTEMS SPECIFIED HEREIN. THE CONTRACTOR SHALL FURNISH THE GENERAL CONTRACTOR WITH INFORMATION WHERE CHASES AND OPENINGS ARE REQUIRED. KEEP INFORMED AS TO THE WORK OF OTHER TRADES ENGAGED IN THE CONSTRUCTION OF THE PROJECT, AND EXECUTE WORK IN A MANNER AS TO NOT INTERFERE WITH OR DELAY THE WORK OF OTHER TRADES.

FIGURED DIMENSIONS SHALL BE TAKEN IN PREFERENCE TO SCALE DIMENSIONS. CONTRACTOR SHALL TAKE HIS OWN MEASUREMENTS AT THE BUILDING, AS VARIATIONS MAY OCCUR. CONTRACTOR WILL BE HELD RESPONSIBLE FOR ERRORS THAT COULD HAVE BEEN AVOIDED BY PROPER CHECKING AND INSPECTION.

PROVIDE MATERIALS WITH TRIM THAT WILL PROPERLY FIT THE TYPES OF CEILING, WALL, OR FLOOR FINISHES ACTUALLY INSTALLED. MODEL NUMBERS LISTED IN THE SPECIFICATIONS OR SHOWN ON THE DRAWINGS ARE NOT INTENDED TO DESIGNATE THE REQUIRED TRIM.

ORDINANCES AND CODES

WORK PERFORMED UNDER THIS CONTRACT SHALL, AT A MINIMUM, BE IN CONFORMANCE WITH APPLICABLE NATIONAL, STATE AND LOCAL CODES HAVING JURISDICTION. EQUIPMENT FURNISHED AND ASSOCIATED INSTALLATION WORK PERFORMED UNDER THIS CONTRACT SHALL BE IN STRICT COMPLIANCE WITH CURRENT APPLICABLE CODES ADOPTED BY THE LOCAL AHJ INCLUDING ANY AMENDMENTS AND STANDARDS AS SET FORTH BY THE NATIONAL FIRE PROTECTION ASSOCIATION (NFPA), UNDERWRITERS LABORATORIES (UL), OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION (OSHA), AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME), AMERICAN SOCIETY OF HEATING, REFRIGERATION, AND AIR CONDITIONING ENGINEERS (ASHRAE), AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI), AMERICAN SOCIETY OF TESTING MATERIALS (ASTM) AND OTHER NATIONAL STANDARDS AND CODES WHERE APPLICABLE. WHERE THE CONTRACT DOCUMENTS EXCEED THE REQUIREMENTS OF THE REFERENCED CODES, STANDARDS, ETC., THE CONTRACT DOCUMENTS SHALL TAKE PRECEDENCE.

PROTECTION OF EQUIPMENT AND MATERIALS

STORE AND PROTECT FROM DAMAGE EQUIPMENT AND MATERIALS DELIVERED TO JOB SITE. COVER WITH WATERPROOF, TEAR-RESISTANT, HEAVY TARP OR POLYETHYLENE PLASTIC AS REQUIRED TO PROTECT FROM PLASTER, DIRT, PAINT, WATER, OR PHYSICAL DAMAGE. EQUIPMENT AND MATERIAL THAT HAS BEEN DAMAGED BY CONSTRUCTION ACTIVITIES WILL BE REJECTED, AND CONTRACTOR IS OBLIGATED TO FURNISH NEW EQUIPMENT AND MATERIAL OF A LIKE KIND.

PLUG OR CAP OPEN ENDS OF DUCTWORK AND PIPING SYSTEMS WHILE STORAGE IS INSTALLED DURING CONSTRUCTION WHEN NOT IN USE TO PREVENT THE ENTRY OF DEBRIS INTO THE SYSTEMS.

SUBSTITUTIONS

THE BASIC BID SHALL INCLUDE ONLY THE PRODUCTS AND MANUFACTURERS SPECIFICALLY NAMED IN THE DRAWINGS AND SPECIFICATIONS. ANY SUBSTITUTION WILL BE CONSIDERED PRIOR TO RECEIPT OF BIDS UNLESS THE REQUEST FOR APPROVAL TO BID HAS BEEN RECEIVED BY THE ENGINEER. LEAST 15 BUSINESS DAYS PRIOR TO THE DATE FOR RECEIPT OF BIDS, EACH SUCH REQUEST SHALL INCLUDE THE NAME OF THE MATERIAL OR EQUIPMENT FROM WHICH IT IS TO BE SUBSTITUTED AND COMPLETE DESCRIPTION OF THE PROPOSED SUBSTITUTE INCLUDING CUTS, PERFORMANCE DATA, AND OTHER INFORMATION NECESSARY FOR AN EVALUATION. A STATEMENT SETTING FORTH CHANGES IN MATERIALS, EQUIPMENT OR OTHER WORK SHALL BE SUBMITTED TO THE ARCHITECT AND ENGINEER. REQUIREMENTS SHALL BE INCLUDED IN THE PROPOSAL TO BE THE MERIT OF THE PROPOSAL. SUBSTITUTION IS UP TO THE ENGINEER'S DECISION OF APPROVAL OR DISAPPROVAL TO BID OF ANY PROPOSED SUBSTITUTION SHALL BE FINAL.

THE TERMS "APPROVED," "APPROVED EQUAL," AND "EQUAL" REFER TO APPROVAL BY THE ENGINEER AS AN ACCEPTABLE ALTERNATE BID. NO SUBSTITUTIONS WILL BE CONSIDERED IF NOT BID AS AN ALTERNATE. NO MATERIAL SUBSTITUTIONS SHALL BE CONSIDERED FOR APPROVAL PRIOR TO AWARD OF CONTRACT.

COORDINATE AND VERIFY WITH OTHER TRADES WHETHER OR NOT THE SUBSTITUTED EQUIPMENT CAN BE INSTALLED AS SHOWN ON THE CONSTRUCTION DRAWINGS WITHOUT MODIFICATION TO ASSOCIATED SYSTEMS AND/OR ENGINEERING DESIGN. INCLUDE ADDITIONAL COSTS FOR ARCHITECTURAL AND ENGINEERING DESIGN FEES IN BID IF DRAWING MODIFICATIONS ARE REQUIRED BECAUSE OF SUBSTITUTED EQUIPMENT.

SHOP DRAWINGS

UPON BEING AWARDED A CONTRACT, SUBMIT TO THE ARCHITECT FOR APPROVAL, SIX (6) COPIES OF MANUFACTURER'S SHOP DRAWINGS FOR EQUIPMENT TO BE FURNISHED UNDER THIS CONTRACT. ITEMS REQUIRING COORDINATION BETWEEN CONTRACTORS AND SHEET METAL DUCTWORK FABRICATION DRAWINGS. BEFORE SUBMITTING SHOP DRAWINGS AND MATERIAL LISTS, VERIFY THAT EQUIPMENT SUBMITTED IS MUTUALLY COMPATIBLE AND SUITABLE FOR THE INTENDED USE, AND WILL FIT THE AVAILABLE SPACE AND ALLOW AMPLE ROOM FOR MAINTENANCE. HIGHLIGHT, MARK, LIST OR INDICATE THE MATERIALS, PERFORMANCE CRITERIA AND ACCESSORIES THAT ARE BEING PROPOSED. SUBMIT SHOP DRAWINGS AS EARLY AS REQUIRED TO SUPPORT THE PROJECT SCHEDULE. ALLOW FOR TWO WEEKS ENGINEER REVIEW TIME PLUS MAILING TIME PLUS A DUPLICATION OF THIS TIME FOR RESUBMITAL, IF REQUIRED.

THE ENGINEER'S CHECKING AND SUBSEQUENT APPROVAL OF SUCH SHOP DRAWINGS WILL NOT RELIEVE THE CONTRACTOR FROM RESPONSIBILITY FOR ERRORS IN DIMENSIONS, DETAILS, SIZE OF MEMBERS, QUANTITIES, OMISSIONS OF COMPONENTS OR FITTINGS; COORDINATION OF ELECTRICAL REQUIREMENTS; OR FOR COORDINATING ITEMS WITH ACTUAL BUILDING CONDITIONS. PROCEED WITH THE PROCUREMENT AND INSTALLATION OF EQUIPMENT ONLY AFTER RECEIVING APPROVED SHOP DRAWINGS RELATIVE TO EACH ITEM.

CATALOG DATA SHALL BE PROPERLY BOUND, IDENTIFIED, INDEXED AND TABBED IN A 3-RING BINDER. LABEL CATALOG DATA WITH THE EQUIPMENT CONTRACTORS AND ACRONYM OR NUMBER AS USED ON THE DRAWINGS AND INCLUDE PERFORMANCE CURVES, CAPACITIES, SIZES, WEIGHTS, MATERIALS, FINISHES, WIRING DIAGRAMS, ELECTRICAL REQUIREMENTS AND DEVIATIONS FROM SPECIFIED EQUIPMENT OR MATERIALS. FOR EQUIPMENT WITH MOTOR STARTERS OR VFDs, INCLUDE SHORT CIRCUIT CURRENT RATINGS. MARK OUT INAPPLICABLE ITEMS. SHOP DRAWINGS WILL BE RETURNED WITHOUT REVIEW IF THE ABOVE MENTIONED REQUIREMENTS ARE NOT MET.

OPERATION AND MAINTENANCE INSTRUCTIONS

DURING THE COURSE OF CONSTRUCTION, COLLECT AND COMPILE A COMPLETE BROCHURE OF EQUIPMENT FURNISHED ON THE PROJECT. THIS BROCHURE SHOULD INCLUDE OPERATIONAL AND MAINTENANCE INSTRUCTIONS, MANUFACTURER'S CATALOG SHEETS, WIRING DIAGRAMS, PARTS LISTS, APPROVED SHOP DRAWINGS, AND DESCRIPTIVE LITERATURE AS FURNISHED BY THE EQUIPMENT MANUFACTURER. INCLUDE AN INSIDE COVER SHEET THAT LISTS THE PROJECT NAME, DATE, OWNER, ARCHITECT, CONSULTING ENGINEER, GENERAL CONTRACTOR, SUB-CONTRACTOR, AND AN INDEX OF CONTENTS.

SUBMIT THREE COPIES OF LITERATURE BOUND IN APPROVED BINDERS WITH INDEX AND TAB SEPARATING THE EQUIPMENT TYPES TO THE ARCHITECT AT THE TERMINATION OF THE WORK. PAPER CLIPS, STAPLES, RUBBER BANDS, AND MAILING ENVELOPES ARE NOT CONSIDERED APPROVED BINDERS. FINAL APPROVAL OF MECHANICAL SYSTEMS INSTALLED UNDER THIS CONTRACT WILL BE WITHHELD UNTIL THIS EQUIPMENT BROCHURE IS SUBMITTED AND DEEMED COMPLETE BY THE ARCHITECT AND ENGINEER. INSTRICT WORKMEN TO SAVE REQUIRED LITERATURE SHIPPED WITH THE EQUIPMENT ITSELF, FOR INCLUSION IN THIS BROCHURE.

WARRANTIES

WARRANT EACH SYSTEM AND EACH ELEMENT THEREOF AGAINST ALL DEFECTS DUE TO OTHERWISE STATED DESIGN OR MATERIAL FOR A PERIOD OF 12 MONTHS FROM DATE OF SUBSTANTIAL COMPLETION, UNLESS SPECIFIC ITEMS ARE NOTED TO CARRY A LONGER WARRANTY IN THE CONSTRUCTION DOCUMENTS OR MANUFACTURER'S STANDARD WARRANTY EXCEEDS 12 MONTHS. REMEDY ALL DEFECTS, OCCURRING WITHIN THE WARRANTY PERIOD(S), AS STATED IN THE GENERAL CONDITIONS AND DIVISION 1.

WARRANTIES SHALL INCLUDE LABOR AND MATERIAL. MAKE REPAIRS OR REPLACEMENTS WITHOUT ANY ADDITIONAL COSTS TO THE OWNER.

PERFORM THE REMEDIAL WORK PROMPTLY, UPON WRITTEN NOTICE FROM THE ENGINEER OR OWNER.

AT THE TIME OF SUBSTANTIAL COMPLETION, DELIVER TO THE OWNER ALL WARRANTIES, IN WRITING AND PROPERLY EXECUTED, INCLUDING TERM LIMITS FOR WARRANTIES AND CONDITIONS BEYOND THE ONE YEAR PERIOD, EACH WARRANTY INSTRUMENT BEING ADDRESSED TO THE OWNER AND STATING THE COMMENCEMENT DATE AND TERM.

SPARE PARTS

FURNISH TO OWNER, WITH RECEIPT, THE FOLLOWING SPARE PARTS FOR THE EQUIPMENT FURNISHED FOR THIS PROJECT:

- A. ONE SET OF SPARE FILTERS OF EACH TYPE REQUIRED FOR EACH UNIT. IN ADDITION TO THE SPARE SET OF FILTERS, INSTALL NEW FILTERS PRIOR TO TESTING, ADJUSTING, AND BALANCING WORK AND BEFORE TURNING SYSTEM OVER TO OWNER.
B. FURNISH ONE COMPLETE SET OF BELTS FOR EACH FAN.
C. FURNISH THREE OPERATING KEYS FOR EACH TYPE OF AIR OUTLET AND INLET THAT REQUIRE THEM.

CUTTING AND PATCHING

PERFORM CUTTING OF WALLS, FLOORS, CEILINGS, ETC. AS REQUIRED TO INSTALL WORK UNDER THIS SECTION, OBTAIN PERMISSION FROM THE ARCHITECT PRIOR TO CUTTING. DO NOT CUT OR DISTURB STRUCTURAL MEMBERS WITHOUT PRIOR APPROVAL FROM THE ARCHITECT. CUT HOLES AS SMALL AS POSSIBLE. GENERAL CONTRACTOR SHALL PATCH WALLS, FLOORS, ETC. AS REQUIRED BY WORK UNDER THIS SECTION. PATCHING SHALL MATCH THE ORIGINAL MATERIAL AND CONSTRUCTION. REPAIR AND REFINISH AREAS DISTURBED BY WORK TO THE CONDITION OF ADJOINING SURFACES IN A MANNER SATISFACTORY TO THE ARCHITECT.

ACCESS DOORS

PROVIDE ACCESS DOORS IN CEILINGS, WALLS, ETC. WHERE INDICATED OR REQUIRED FOR ACCESS OR MAINTENANCE TO CONCEALED VALVES AND EQUIPMENT INSTALLED UNDER THIS SECTION. PROVIDE CONCEALED HINGES, SCREWDRIVERS AND ANCHOR STRAPS, MANUFACTURED BY MILCOR, ZURM, OR EQUIVALENT, AS APPROVED BY ARCHITECT'S APPROVAL OF TYPE, SIZE, LOCATION AND COLOR BEFORE ORDERING.

PENETRATIONS

PROVIDE PREFABRICATED ROOF CURB MANUFACTURED BY CURB, INC., PATE COMPANY, THYCEUR, APPROVED EQUAL, PROVIDE ROOF CURB WITH FACTORY INSTALLED WOOD NAILED WELDED 1/8 GA. GALVANIZED STEEL SHELL, BASE PLATE AND FLASHING. 1-1/2" THICK, 3/4" RADIUS, FULLY MITERED 3-INCH RAISED CANT. WEATHER RESISTANT WEATHER PROOF MATERIAL AND PIPE COLLAR OF WEATHER RESISTANT MATERIAL WITH STAINLESS STEEL PIPE CLAMPS.

SEAL ELEVATED FLOOR, EXTERIOR WALL AND ROOF PENETRATIONS WATER TIGHT AND WEATHER TIGHT WITH NON-SOLUBLE NON-HARDENING COMMERCIAL SEALANT. PACK WITH MINERALS WOOL AND SEAL BOTH SIDES WITH MINIMUM OF 1/2" OF SEALANT. SEAL PENETRATIONS OF RATED WALLS AND TRANSVERSE JOINTS WELDED OR SEALED TO MEET FIRE RATING AND LOCATIONS WITH THE ARCHITECTURAL DRAWINGS. REFER TO ARCHITECTURAL SPECIFICATIONS FOR FIRE STOPPING. PROVIDE A PRODUCT SCHEDULE WITH UL LISTING, LOCATION, WALL OR FLOOR RATING AND INSTALLATION DRAWING FOR EACH PENETRATION FIRE STOP SYSTEM.

PROVIDE BOB FRAMES FOR RECTANGULAR OPENINGS WELDED 12 GAUGE GALVANIZED STEEL ATTACHED TO FORMS AND OF A MAXIMUM DIMENSION ESTABLISHED BY THE ARCHITECT. NOTIFY THE GENERAL CONTRACTOR OF ANY CHANGES IN DRAWINGS. ANY BOX OPENINGS NOT SHOWN ON THE ARCHITECTURAL OR STRUCTURAL DRAWINGS.

AIR FILTERS

PROVIDE FARR 30/30, FLEATED, THROWAWAY TYPE FILTERS, OR SIMILAR AS MANUFACTURED BY AMERICAN AIR FILTER, FLANDERS OR APPROVED EQUAL, UNLESS OTHERWISE INDICATED. AIR UNITS SHALL HAVE NEW FILTERS INSTALLED WHEN THEY ARE OPERATED BEFORE FINAL ACCEPTANCE.

ELECTRICAL WIRING

LINE VOLTAGE WIRING SHALL BE PROVIDED BY DIVISION 16. LINE VOLTAGE CONTROL AND INTERLOCK WIRING FOR MECHANICAL SYSTEMS SHALL ALSO BE PROVIDED BY DIVISION 16 CONTRACTOR. LOW VOLTAGE CONTROL WIRING SHALL BE PROVIDED BY THE DIVISION 15 CONTRACTOR. FURNISH WIRING DIAGRAMS TO THE DIVISION 16 CONTRACTOR AS REQUIRED FOR PROPER EQUIPMENT HOOKUP. COORDINATE WITH THE DIVISION 16 CONTRACTOR THE ACTUAL WIRE SIZING AMPS FOR MECHANICAL EQUIPMENT (FROM THE EQUIPMENT NAMEPLATE) TO ENSURE PROPER INSTALLATION.

REFRIGERANT AND OIL

PROVIDE FULL REFRIGERANT AND OIL CHARGE IN NEW AIR CONDITIONING REFRIGERATION SYSTEMS, AND MAINTAIN IT FOR FULL TERM OF THE GUARANTEE.

FINAL TESTING AND ADJUSTMENTS

FINAL SYSTEM TESTING, BALANCING AND ADJUSTMENTS SHALL BE PERFORMED BY A CONTRACTOR CERTIFIED BY THE NATIONAL ENVIRONMENTAL BALANCING BUREAU (NEBB) OR ASSOCIATED AIR BALANCE COUNCIL (AABC). PERFORM TEST READINGS ON FANS, UNITS, COILS, ETC. AND ADJUST EQUIPMENT TO DELIVER SPECIFIED AMOUNTS OF AIR. PREPARE TESTING AND BALANCING REPORT LOG SHOWING AIR SUPPLY QUANTITIES, AIR ENTERING AND LEAVING TEMPERATURES AND PRESSURES, FAN AIR FLOW, TEST READINGS, MOTOR VOLTAGE AND AMP DRAWS, ETC., AND SUBMIT SIX COPIES OF THE FINAL COMPILATION OF DATA TO THE ARCHITECT FOR EVALUATION AND APPROVAL BEFORE FINAL INSPECTION OF THE PROJECT. BALANCE AIR SYSTEMS TO WITHIN PLUS OR MINUS 10 PERCENT FOR TERMINAL DEVICES AND BRANCH LINES AND PLUS OR MINUS 5 PERCENT FOR MAIN DUCTS AND AIR HANDLING EQUIPMENT OF THE AMOUNT OF AIR SHOWN ON THE DRAWINGS. FURTHER ADJUSTMENTS SHALL BE MADE TO OBTAIN UNIFORM TEMPERATURE IN SPACES. ADJUST EQUIPMENT TO OPERATE AS INTENDED BY THE SPECIFICATION. ALIGN BEARINGS AND TRANSVERSE DUCTWORK JOINTS AIR TIGHT OR FOREIGN MATERIAL IN THEM WITH NEW BEARINGS WITHOUT ADDITIONAL COST TO THE OWNER. BALANCE CONTRACTOR SHALL INCLUDE IN THE REPORT ANY IMPROPERLY INSTALLED OR MISSED, AND CEILING PENETRATIONS. PROVIDE ADDITIONAL WIRING WITH HEAVY LIQUID SEALANT APPLIED ACCORDING TO MANUFACTURER'S INSTRUCTIONS.

ADJUST THERMOSTATS AND CONTROL DEVICES TO OPERATE AS INTENDED. ADJUST BURNERS, PUMPS, FANS, ETC. FOR PROPER AND EFFICIENT OPERATION. CERTIFY TO ARCHITECT THAT ADJUSTMENTS HAVE BEEN MADE AND THAT SYSTEM IS OPERATING SATISFACTORILY. FURTHER ADJUSTMENTS SHALL BE MADE TO OBTAIN UNIFORM TEMPERATURE IN SPACES. CALIBRATE, SET, AND ADJUST AUTOMATIC TEMPERATURE CONTROL. VERIFY PROPER SEQUENCING OF INTERLOCK SYSTEMS, AND OPERATION OF SAFETY CONTROLS.

BUILDING OPERATION

COMPLY WITH THE SCHEDULE OF OPERATIONS AS OUTLINED IN THE ARCHITECTURAL PORTIONS OF THIS SPECIFICATION. BUILDING SHALL BE IN CONTINUOUS OPERATION. ACCOMPLISH WORK REQUIRING INTERRUPTION OF BUILDING OPERATION AT A TIME WHEN THE BUILDING IS NOT IN OPERATION, AND ONLY WITH WRITTEN APPROVAL OF BUILDING OWNER AND/OR TENANT. COORDINATE INTERRUPTION OF BUILDING OPERATION WITH THE OWNER AND/OR TENANT A MINIMUM OF SEVEN DAYS IN ADVANCE OF WORK.

MECHANICAL IDENTIFICATION

PROVIDE MANUFACTURER'S STANDARD PRE-PRINTED, SEMI-RIGID SNAP-ON OR PERMANENT ADHESIVE, PRESSURE-SENSITIVE VINYL PIPE MARKERS.

PROVIDE MANUFACTURER'S STANDARD LAMINATED PLASTIC, COLOR CODED EQUIPMENT MARKERS, CONFORM TO THE FOLLOWING COLOR CODE: GREEN FOR HEATING, YELLOW FOR HEATING, YELLOW/GREEN FOR COMBINATION COOLING AND HEATING, BROWN FOR ENERGY RECLAMATION; BLUE FOR OTHER EQUIPMENT TYPES. CONFORM TO ANSI A13.1 FOR HAZARDOUS EQUIPMENT.

PROVIDE STENCILED SIGNS FOR EQUIPMENT IDENTIFICATION AT CONTRACTOR'S OPTION OR WHERE DISTANCE OF REQUIRED IDENTIFICATION REQUIRES LETTERING LARGER THAN 1 INCH HEIGHT. STENCIL PAINT SHALL BE EXTERIOR TYPE, OIL-BASED, ALKYD ENAMEL, MINIMUM 1/4 INCH HEIGHT OR GREATER AS REQUIRED FOR LONG DISTANCE IDENTIFICATION. WHITE OR BLACK COLOR FOR BEST CONTRAST.

PROVIDE DUCT MARKERS OR PROVIDE STENCILED SIGNS AND ARROWS INDICATING FAN/WORKMANSHIP, DESIGN OR FLOW DIRECTION IN BLACK OR WHITE LETTERING FOR BEST CONTRAST WITH DUCT OR INSULATION COLOR. LOCATE MARKERS MAXIMUM 50 FEET ALONG EACH DUCT SIDE AND WITHIN 5 FEET OF ALL CONTROL AND BALANCING DAMPERS OR BRANCH DUCTS MORE THAN 25 FEET LENGTH AND WITHIN 5 FEET ON EACH SIDE OF WALL, FLOOR, AND CEILING PENETRATIONS. PROVIDE ADDITIONAL MARKERS IN CONGESTED AREAS OR AT MULTIPLE DUCT RUNS AS REQUIRED FOR CLARITY.

DUCT INSULATION, DUCTWORK, ACCESSORIES AND FANS

DUCT INSULATION

PROVIDE DUCT LINER IN RECTANGULAR SUPPLY AND RETURN AIR DUCTWORK. LINER SHALL BE 1.5" THICK, 1-1/2" POUND DENSITY FIBERGLASS, MINIMUM R-5.0. CERTAINTED CORP. "TOUGHGUARD" OR EQUIVALENT OWENS-CORNING OR KNAUF LONG FIBER DUCT LINER. LINER SURFACE SHALL SERVE AS A BARRIER AGAINST INFILTRATION OF DUST AND DIRT, SHALL MEET ASTM SPEC FOR FUMIGANT AND BE CLEANABLE AND CLEANABLE USING DUCT CLEANING METHODS AND EQUIPMENT PROVIDED BY AMERICAN INSULATION MANUFACTURERS ASSOCIATION (AIMA) DUCT CLEANING GUIDE. INSTALL WITH LINER ADHESIVE AND MECHANICAL FASTENERS IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS AND RECOMMENDATIONS. DUCTWORK SHOWN ON DRAWINGS ARE INSIDE CLEAR DIMENSIONS. INCREASE SHEET METAL DUCT WALL THICKNESS IN BOTH DIRECTIONS WHERE LINER IS INSTALLED.

COVER CONCEALED, RIGID DUCTWORK WITH 1/2" THICK, 3.4 POUND DENSITY, MINIMUM R-5.0 DUCT WRAP, CEILING DUCT OR EQUIVALENT OWENS-CORNING OR KNAUF WITH HEAVY-DUTY FOIL-SCRM-KNAUF FINISHING, AND WHERE DUCTS TAPED WITH 3" WIDE FOIL TAPE AS FOLLOWS:

- A. ROUND SUPPLY AND RETURN AIR DUCTWORK.
B. RECTANGULAR AND RECTANGULAR EXHAUST AIR DUCTWORK WITHIN 10 FEET OF EXTERIOR DISCHARGE.

INSULATING MATERIALS, ADHESIVES, COATINGS, ETC., SHALL NOT EXCEED FLAME SPREAD RATING OF 25 AND SMOKE DEVELOPED RATING OF 50 PER ASTM E 84. CONTAINERS FOR MASTICS AND ADHESIVES SHALL HAVE U.L. LABEL.

FLEXIBLE DUCTWORK IS LOCATED EXTERIOR TO THE BUILDING AND INSTALLED WITH SEAMS SEALED WITH SEALANT, PROVIDE 2" (MINIMUM R-8.0) THICK, 3 POUND DENSITY LINER, FIBERGLASS DUCTWORK THAT IS EXTERIOR TO THE BUILDING, INSULATE WITH 2" (MINIMUM R-8.0) THICK FIBROUS BOARD INSULATION AND PROVIDE MINIMUM 20 GAUGE ALUMINUM JACKET.

DUCTWORK

PROVIDE GALVANIZED STEEL DUCTWORK AND HOUSINGS AS SHOWN ON DRAWINGS. CONSTRUCT DUCTWORK INCLUDING FITTINGS AND TRANSITIONS IN CONFORMANCE WITH CURRENT SMACNA STANDARDS RELATIVE TO GAUGE, BRACING, JOINTS, ETC. MINIMUM THICKNESS OF DUCTWORK SHALL BE 26-GAUGE SHEET METAL. HANGERS AND DUCTWORK OVER 30" WITH 1-1/4" ANGLES NOT LESS THAN 5'-6" ON CENTERS, AND CLOSER IF REQUIRED FOR SUFFICIENT RIGIDITY TO PREVENT VIBRATION. SUPPORT HORIZONTAL RUNS OF DUCT FROM STRAP IRON HANGERS ON CENTERS NOT TO EXCEED 8'-0". DO NOT SUPPORT CEILING GRID, CONDUITS, PIPES, EQUIPMENT, ETC. FROM DUCTWORK. COORDINATE ROUTING OF DUCTWORK WITH OTHER CONTRACTORS SUCH THAT PIPING, ELECTRICAL CONDUIT, AND ASSOCIATED SUPPORTS ARE NOT ROUTED THROUGH THE DUCTWORK.

CONSTRUCT SUPPLY DUCTS TO MEET SMACNA POSITIVE PRESSURE OF 2" W.G. CONSTRUCT RETURN, OUTDOOR AND EXHAUST DUCTWORK UPSTREAM OF FANS TO MEET SMACNA NEGATIVE PRESSURE OF 2" W.G. CONSTRUCT EXHAUST DUCTWORK DOWNSTREAM OF FANS TO MEET SMACNA POSITIVE PRESSURE OF 2" W.G.

DUCTWORK ABOVE ROOF OR OTHERWISE EXTERIOR TO BUILDING SHALL BE MINIMUM #18 GAUGE WITH WEATHERPROOF ELBOWS AND TRANSVERSE JOINTS WELDED OR SEALED AIR TIGHT WITH WEATHERPROOF ELBOWS AND TRANSVERSE JOINTS AIR TIGHT WITH HEAVY LIQUID SEALANT APPLIED ACCORDING TO MANUFACTURER'S INSTRUCTIONS.

SEAL DUCTWORK WITH HEAVY LIQUID SEALANT, HARDCAST IRONGRIP 601, DESIGN POLYMER DP 1010, UNITED MCGILL DUCT SEALER OR APPROVED EQUAL, APPLIED ACCORDING TO SEALANT MANUFACTURER'S INSTRUCTIONS. FOR DUCTS WITH PRESSURE CLASSIFICATION LESS THAN 2" W.G. SEAL TRANSVERSE JOINTS AIR TIGHT TO MEET SMACNA C. TAPES AND MASTICS SHALL BE LISTED AND LABELED IN ACCORDANCE WITH UL 181A.

PROVIDE RADIUS ELBOWS, TURNS, AND OFFSETS WITH A MINIMUM CENTERLINE RADIUS OF 1-1/2 TIMES THE DUCT SPACING DOES NOT PERMIT 90 DEGREE RADIUS ELBOWS, PROVIDE SHORT RADIUS ELBOWS WITH A MINIMUM OF TWO CONTINUOUS SPLITTER VANES. VANES SHALL BE THE ENTIRE LENGTH OF THE BEND, PROVIDE MITERED ELBOWS WHERE SPACE DOES NOT PERMIT RADIUS ELBOWS, WHERE SHOWN ON THE DRAWINGS, OR AT THE OPTION OF THE CONTRACTOR WITH THE ENGINEER'S APPROVAL. MITERED ELBOWS LESS THAN 45 DEGREES SHALL NOT REQUIRE TURNING VANES. MITERED ELBOWS 45-DEGREES AND GREATER SHALL HAVE SINGLE THICKNESS TURNING VANES OF SAME GAUGE AS DUCTWORK, RIGIDLY FASTENED WITH GUIDE STRIPS IN DUCTWORK. VANES FOR MITERED ELBOWS SHALL BE PROVIDED IN ALL SUPPLY AND EXHAUST DUCTWORK AND IN RETURN AND OUTSIDE AIR DUCTWORK THAT HAS AN AIR VELOCITY EXCEEDING 1000 FPM. DO NOT INSTALL VANES IN GREASE DUCTWORK.

DUCTS SHALL BE CONNECTED TO FANS, FAN CASINGS AND FAN PLENUMS BY MEANS OF FLEXIBLE CONNECTORS. FLEXIBLE CONNECTORS SHALL BE NEOPRENE COATED GLASS CLOTH CANVAS CONNECTIONS, DURABLE DYED ELBOW, VENTILATOR OR EQUAL. FLEXIBLE CONNECTORS SHALL HAVE A FLAME SPREAD OF 25 OR LESS AND SMOKE DEVELOPED RATING NOT HIGHER THAN 50. MAKE AIR TIGHT JOINTS AND INSTALL WITH MINIMUM 1-1/2" SLACK.

PROVIDE BALANCING DAMPERS, MANUFACTURED BY RUSKIN, GREENHECK, NALOR INDUSTRIES, GESCO, LOUVERS & DAMPERS, POTTOFF OR APPROVED EQUAL, WHERE SHOWN ON DRAWINGS AND WHEREVER NECESSARY FOR COMPLETE CONTROL OF AIR FLOW. SPLITTER DAMPERS SHALL BE BUTTERFLY TYPE CONSISTING OF CIRCULAR FLOW REGULATOR OR VENTLOK END BEARINGS FOR THE DAMPER ROD. RECTANGULAR VOLUME DAMPERS SHALL BE OPPOSED BLADE INTERLOCKING TYPE. ROUND VOLUME DAMPERS SHALL BE BUTTERFLY TYPE CONSISTING OF CIRCULAR BLADE MOUNTED TO A SHAFT. DAMPER LEAKAGE FOR OUTSIDE AIR DAMPERS SHALL NOT EXCEED 4.0 CFM/SQUARE FOOT IN FULL CLOSED POSITION AT 1" WG PRESSURE DIFFERENTIAL ACROSS DAMPER. REFERENCE MANUFACTURER AND MODEL NUMBER FOR OUTSIDE AIR DAMPERS IS RUSKIN MODEL CD-50. PROVIDE FLEXMASTER MODEL STO OR EQUAL 45 DEGREE RECTANGULAR/ROUND SIDE TAKEOFF FITTING WITH MODEL SLBO DOUBLE BEARING DAMPER WITH INSULATION BUILD OUT FOR ROUND DUCTWORK BRANCH TAKEOFFS TO INDIVIDUAL AIR DEVICES. OAKF DAMPER AT TAKEOFF FITTING WHEN DAMPER IS LOCATED DOWNSTREAM OF TAKEOFF.

LOW PRESSURE (DUCT PRESSURE CLASS UP TO AND INCLUDING 2" W.G.) FITTINGS 24" IN DIAMETER AND LESS SHALL BE PREFABRICATED, SPOTWELDED AND INTERNALLY SEALED. SEAL LONGITUDINAL AND TRANSVERSE DUCTWORK JOINTS AIR TIGHT WITH HEAVY LIQUID SEALANT APPLIED ACCORDING TO MANUFACTURER'S INSTRUCTIONS.

FLEXIBLE DUCT

LOW PRESSURE (DUCT PRESSURE CLASS UP TO AND INCLUDING 2" W.G.) FLEXIBLE DUCT SHALL BE FLEXMASTER TYPE 8B, THERMAFLEX TYPE G-KM, M-KE, OR EQUAL (FIRE RETARDANT POLYETHYLENE) PROTECTIVE VAPOR BARRIER, UL181 CLASS 1, ACOUSTICAL INSULATED DUCT, R-5.0 FIBERGLASS INSULATION, PROVIDE CPE LINER WITH STEEL WIRE HELIX MECHANICALLY LOCKED OR PERMANENTLY BONDED TO THE LINER.

FLEXIBLE DUCT RUNS SHALL NOT EXCEED 6 FEET IN LENGTH, AND SHALL BE INSTALLED FULLY EXTENDED AND STRAIGHT AS POSSIBLE AVOIDING TIGHT TURNS. INSTALL FLEXIBLE DUCT IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS. SUPPORT FLEXIBLE DUCT AT MAXIMUM 5 FEET ON CENTER AND WITHIN 6 INCHES OF BENDS. BENDS SHALL NOT EXCEED A CENTERLINE RADIUS OF ONE DUCT DIAMETER. DUCT SAG SHALL NOT EXCEED 1/2 INCH. SUPPORTING MATERIAL IN DIRECT CONTACT WITH THE DUCT SHALL NOT BE LESS THAN 1-1/2 INCHES IN WIDTH.

CONNECT FLEXIBLE DUCT TO RIGID METAL DUCT OR AIR DEVICES AS RECOMMENDED BY THE MANUFACTURER. AT A MINIMUM, INSTALL TWO WRAPS OF DUCT TAPE AROUND THE INNER CORE CONNECTION AND A METALLIC OR NON-METALLIC CLAMP OVER THE WRAP AND TWO WRAPS OF DUCT TAPE OR A CLAMP OVER THE OUTER JACKET. DUCT CLAMP SHALL BE LABELED IN ACCORDANCE WITH UL 181B AND MARKED 181B-C. DUCT TAPE SHALL BE LABELED IN ACCORDANCE WITH UL 181B AND MARKED 181B.

AIR DEVICES

PROVIDE AIR DEVICES AS SCHEDULED ON DRAWINGS, MANUFACTURED BY CARNES, E.H. PRICE, KRUEGER, NALOR INDUSTRIES, TITUS, OR TUTTLE. SELECT AIR DEVICES TO LIMIT ROOM NOISE LEVEL TO NO HIGHER THAN 45 DBA UNLESS OTHERWISE SHOWN. PROVIDE DEVICES WITH A SOFT PLASTIC GASKET TO MAKE AN AIR TIGHT SEAL AGAINST THE MOUNTING SURFACE. COORDINATE FINAL LOCATION, FACE, AND MOUNTING TYPE OF AIR DEVICES WITH ARCHITECTURAL REFLECTED CEILING PLANS.

PROVIDE CEILING SUPPLY AIR DIFFUSERS AND RETURN AIR GRILLES OR DIFFUSERS IN A SURFACE MOUNTED TYPE AS REQUIRED TO BE COMPATIBLE WITH CEILING FINISH. FINISH UNLESS NOTED OTHERWISE. PROVIDE CEILING DIFFUSERS AND GRILLES WITH WHITE ENAMEL FINISH UNLESS NOTED OTHERWISE.

EXHAUST SYSTEMS

PROVIDE CEILING MOUNTED EXHAUST FANS AS SCHEDULED ON THE DRAWINGS, OR EQUAL CODE, GREENHECK, CARNES, TWIN CITY FANS, ACME OR PENNBARRY. COMPLETE WITH MINIMUM HOUSING, ALUMINUM CENTRIFUGAL WHEEL, MOTOR WITH INTEGRAL THERMAL OVERLOAD PROTECTION, DISCONNECT SWITCH MOUNTED INSIDE THE HOUSING, DRAIN TROUGH, BIOSCREEN AND PATE PREFABRICATED ROOF CURB WITH MINIMUM HEIGHT OF 12 INCHES FOR ROOFS WITH NO INSULATION, 15" FOR ROOFS WITH INSULATION OR AS SCHEDULED ON THE DRAWINGS. EXHAUST FANS SERVING TYPE I KITCHEN EXHAUST HOODS SHALL DISCHARGE A MINIMUM OF 40' ABOVE THE ROOF SURFACE. SHALL HAVE HINGED ACCESS INCLUDING ACCESS FOR BLADE INSPECTION AND CLEANING PER NFPA 96 GREASE DRAIN TROUGH WITH CUP AND INSULATED CURB, AND SHALL BE INSTALLED IN ACCORDANCE WITH NFPA 96 AND LOCAL CODES.

PROVIDE CEILING MOUNTED UPRAST EXHAUST FANS AS SCHEDULED ON THE DRAWINGS, OR EQUAL CODE, GREENHECK, CARNES, TWIN CITY FANS, ACME OR PENNBARRY. COMPLETE WITH MINIMUM HOUSING, ALUMINUM CENTRIFUGAL WHEEL, MOTOR WITH INTEGRAL THERMAL OVERLOAD PROTECTION, DISCONNECT SWITCH MOUNTED INSIDE THE HOUSING, DRAIN TROUGH, BIOSCREEN AND PATE PREFABRICATED ROOF CURB WITH MINIMUM HEIGHT OF 12 INCHES FOR ROOFS WITH NO INSULATION, 15" FOR ROOFS WITH INSULATION OR AS SCHEDULED ON THE DRAWINGS. EXHAUST FANS SERVING TYPE I KITCHEN EXHAUST HOODS SHALL DISCHARGE A MINIMUM OF 40' ABOVE THE ROOF SURFACE. SHALL HAVE HINGED ACCESS INCLUDING ACCESS FOR BLADE INSPECTION AND CLEANING PER NFPA 96 GREASE DRAIN TROUGH WITH CUP AND INSULATED CURB, AND SHALL BE INSTALLED IN ACCORDANCE WITH NFPA 96 AND LOCAL CODES.

HVAC EQUIPMENT

ROOFTOP UNITS (GAS FIRED HEAT)

PROVIDE ELECTRIC COOLING, GAS HEATING ROOFTOP UNITS AS SCHEDULED ON THE DRAWINGS, MANUFACTURED BY TRANE, CARRIER, AOD, LENNOX, JOHNSON CONTROLS, MCQUAY, OR YORK; COMPLETE WITH FACTORY INSTALLED DIRECT-DRIVE HERMETIC COMPRESSORS WITH INTERNAL SPRING VIBRATION ISOLATION, BUILT-IN MOTOR THERMAL OVERLOAD PROTECTION, CRANKCASE HEATER, AND LOW PRESSURE SWITCHES; DIRECT EXPANSION COOLING AND CONDENSING COILS; MINIMUM SEER OR SEER RATING (COOLING) AS REQUIRED BY THE APPLICABLE ENERGY CODE OR GREATER IF SCHEDULED ON THE DRAWINGS, CENTRIFUGAL EVAPORATOR BLOWER; AIR FILTER RACK WITH 2" THICK THROWAWAY FILTERS, PROPELLER TYPE CONDENSER FAN; ALUMINIZED STEEL HEAT EXCHANGER; 80 PERCENT MINIMUM AFUE RATING (HEATING); FORCED COMBUSTION AIR BLOWER; COMPLETE FACTORY INSTALLED MICRO-PROCESSOR CONTROLS INCLUDING ANTI-SHORT CYCLE TIMERS, TIME DELAY RELAYS AND MINIMUM "ON" TIME CONTROLS; 100 PERCENT SAFETY GAS SHUTOFF, DIRECT SPARK IGNITION SYSTEM, BUILT-IN THERMAL OVERLOAD PROTECTION ON MOTORS AND COMPRESSORS; 100 PERCENT OUTDOOR AIR (DRY-BULB) ECONOMIZER WITH BAROMETRIC RELIEF; FACTORY INSTALLED LOW AMBIENT CONTROLS DOWN TO 0°F; WEATHERTIGHT HOUSING CONSTRUCTED OF ZINC COATED, HEAVY GAUGE, GALVANIZED STEEL WITH WEATHER-RESISTANT BAKED ENAMEL FINISH; MINIMUM INSULATED DOWNFLOW STANDARD ROOF CURB WITH MINIMUM HEIGHT OF 12 INCHES FOR ROOFS WITH NO INSULATION, 14" FOR ROOFS WITH INSULATION OR AS SCHEDULED ON THE DRAWINGS; SINGLE POINT ELECTRICAL POWER CONNECTION. PROVIDE SLOPE ROOF CURB AS REQUIRED TO MATCH SLOPE OF ROOF STRUCTURE TO THAT UNIT IS INSTALLED LEVEL. PROVIDE GUARDS OR LOUVERED PANELS TO PROTECT THE CONDENSER COIL FROM HAIL OR OTHER DAMAGE. PROVIDE 125 VAC, 20 AMP DUPLEX CONVENIENCE RECEPTACLE MOUNTED TO UNIT READY FOR WIRING WITH COVER UL LISTED FOR WET AND DAMP LOCATIONS. PROVIDE HONEYWELL OR EQUAL ELECTRONIC PROGRAMMABLE TYPE THERMOSTAT, SETPOINT WHEEL, MANUAL CHANGEOVER, SWITCHING SUBBASE, MINIMUM STAGE 2 REQUIRED FOR EACH UNIT COOLING/HEATING STAGING. DIVISION 16 CONTRACTOR SHALL PROVIDE WIRE UL LISTED DUCT TYPE SMOKE DETECTORS AS REQUIRED BY CODE TO SHUT DOWN ROOFTOP UNIT UPON DETECTION OF SMOKE. PROVIDE 1 YEAR COMPLETE WITH MANUFACTURER'S ONE YEAR GUARANTEE ON COMPONENTS PLUS AN ADDITIONAL FOUR YEAR WARRANTY ON THE COMPRESSORS AND EXCHANGERS.

TEMPERATURE CONTROLS

GENERAL REQUIREMENTS

PROVIDE A SYSTEM OF TEMPERATURE CONTROLS INCLUDING THERMOSTATS, TIME SWITCHES, OVERHEAD TIME, DAMPER MOTORS, AND RELAYS REQUIRED TO PROVIDE THE DESIRED SEQUENCE OF OPERATION. PROVIDE INTEGRATED WIRING DIAGRAMS SHOWING INTERLOCKS BETWEEN FIELD INSTALLED EQUIPMENT AND PACKAGING. PROVIDE WIRING WITH THE HVAC EQUIPMENT. CONTROL WIRING SHALL BE SIZED TO ACCOMMODATE THE VOLTAGE DROP ASSOCIATED WITH THE DISTANCE BETWEEN THE CONTROLLER DEVICE AND THE CONTROLLER.

TEMPERATURE CONTROLS

GENERAL REQUIREMENTS