

ELECTRICAL SYMBOLS LEGEND	
SYMBOLS	DESCRIPTION
	FLUORESCENT FIXTURE, WITH FIXTURE DESIGNATED BY LETTER.
NL	NIGHT LIGHT - NOT SWITCHED
	CEILING OR WALL MOUNTED FIXTURE
⊕	JUNCTION BOX
⊕	SINGLE/DOUBLE FACED EXIT SIGN - NOT SWITCHED
⊕	DOUBLE HEAD EMERGENCY LIGHT WITH BATTERY BACK UP.
S	SINGLE POLE SWITCH, +48" A.F.F.
S ₃	THREE WAY SWITCH, +48" A.F.F.
S ₀	OUTLET CONTROL INDICATOR
S _D	DIMMER SWITCH
S _{OS}	OCCUPANCY SENSOR SWITCH
S _T	THERMAL OVERLOAD SWITCH
⊕	DUPLEX RECEPTACLE, +18" A.F.F.
⊕	DUPLEX RECEPTACLE ABOVE COUNTER, VERIFY HEIGHT
⊕	250 VOLT RECEPTACLE PER UNIT REQUIREMENTS
⊕	FOURPLEX RECEPTACLE, +18" A.F.F.
⊕	HALF SWITCHED DUPLEX RECEPTACLE
⊕	POWER/PHONE/DATA FLUSH FLOOR OUTLET
⊕	TELEPHONE/DATA SYSTEM OUTLET, 4" SQUARE BOX AND COVERPLATE, 3/4"C. TO CEILING SPACE UNLESS SHOWN WITH HOMERUN, +18" A.F.F.
⊕	TELEVISION OUTLET PLASTER RING AT +18" A.F.F. (U.N.O.) HUBBELL COVERPLATE. 3/4"C. TO CEILING SPACE UNLESS SHOWN WITH HOMERUNS.
⊕	CONDUIT BELOW FLOOR OR UNDERGROUND
⊕	CONDUIT IN WALL OR ABOVE CEILING
LA 1,3	HOMERUN TO PANEL (SEE GROUNDING NOTE)
	MOTOR CONNECTION
	DISCONNECT SWITCH
⊕	DUCT SMOKE DETECTOR

*** ALL SYMBOLS ON LEGEND MAY NOT APPLY TO DRAWING(S). ***

ELECTRICAL SPECIFICATION

- PRIOR TO SUBMITTING BID, CONTRACTOR SHALL EXAMINE ALL GENERAL CONSTRUCTION DRAWINGS AND VISIT THE CONSTRUCTION SITE TO BECOME FAMILIAR WITH EXISTING CONDITIONS UNDER WHICH HE WILL HAVE TO OPERATE, WHICH IN ANY WAY AFFECTS THE WORK UNDER HIS CONTRACT. NO SUBSEQUENT ALLOWANCE WILL BE MADE IN BEHALF OF THE CONTRACTOR FOR AN ERROR OR NEGLIGENCE ON HIS PART.
- THE CONTRACTOR SHALL BE HELD FULLY RESPONSIBLE FOR THE PROPER REPAIRS OF ALL EXISTING SURFACES REQUIRING PATCHING, PLASTERING, PAINTING AND /OR OTHER REPAIR DUE TO THE INSTALLATION OF ELECTRICAL WORK UNDER THE TERMS OF THE CONTRACT. CLOSE ALL OPENINGS, REPAIR ALL SURFACES, ETC., AS REQUIRED.
- SEE ARCHITECTURAL DRAWINGS FOR ALL DIMENSIONS, ELEVATIONS AND BUILDING DETAILS. VERIFY LOCATION OF ALL OUTLETS, SWITCHES, AND WALL MOUNTED LIGHTING FIXTURES WITH ARCHITECTURAL DRAWINGS AND EXISTING CONDITIONS. SEE ARCHITECTURAL REFLECTED CEILING PLAN FOR EXACT LOCATION OF LIGHTING FIXTURES. VERIFY ALL CEILING TYPES WITH ARCHITECTURAL DRAWINGS BEFORE ORDERING FIXTURES.
- PRIOR TO ROUGH-IN AND FINAL CONNECTION, VERIFY ELECTRICAL CHARACTERISTICS AND EXACT LOCATION OF EQUIPMENT.
- GROUT AND SEAL ALL CONDUIT PENETRATIONS OF WALLS AND FLOOR SLABS TO PRESERVE FIRE RATING AND WATERTIGHT INTEGRITY.
- ALL WIRING TO BE INSTALLED IN 4" RAYS. TYPE OF RACEWAY SHALL BE AS REQUIRED BY CODE. MINIMUM CONDUIT SIZE SHALL BE 1/2". MC CABLE WILL BE ALLOWED WHERE APPROVED BY LOCAL AUTHORITY AND BUILDING OWNER. RACEWAYS RUN ACROSS ROOF SHALL BE MINIMUM 4" ABOVE ROOF.
- BRANCH CIRCUIT WIRING SHALL BE THHN, UNLESS EXTERIOR WIRING SHALL BE THWN-2. PANEL FEEDERS, SHALL BE TYPE XHHW. ALL WIRE SHALL BE COPPER. MINIMUM WIRE SIZE SHALL BE #12. PER NEC SEPARATE NEUTRALS ARE TO BE PROVIDED FOR EACH CIRCUIT OR PROVIDE MULTIPLE POLE HANDLE TIE FOR EACH MULTI-WIRE CIRCUIT
- PROVIDE CORRECT SIZED AND WIRE IN ALL CONDUITS.
- ALL ELECTRICAL EQUIPMENT SHALL BE NEW, U.L. APPROVED AND COMMERCIAL GRADE.
- ALL ELECTRICAL WORK SHALL BE INSTALLED IN ACCORDANCE WITH THE LATEST NATIONAL CODE, (N.E.C.), AND ALL APPLICABLE FEDERAL, STATE AND LOCAL CODES.
- IT SHALL BE THE ELECTRICAL CONTRACTOR'S RESPONSIBILITY TO PROVIDE ONE (1) SET OF COMPLETE CONSTRUCTION DRAWINGS.
- PROVIDE NEW PANEL DIRECTORIES INDICATING SPECIFIC CIRCUIT INFORMATION TO DISTINGUISH EACH CIRCUIT FROM ANY OTHER PER NEC.
- ELECTRICAL CONTRACTOR IS RESPONSIBLE FOR ALL DEMOLITION OF DEVICES, WIRE & CONDUIT, WHERE THESE ITEMS ARE NO LONGER USED ALL UNUSED WIRE SHALL BE REMOVED BACK TO THE PANEL. ANY DOWNSTREAM EQUIPMENT TO REMAIN IN USE SHALL BE RECONNECTED.

ABBREVIATIONS	
E	EXISTING LIGHT OR DEVICE TO REMAIN
ER	EXISTING LIGHT OR DEVICE TO BE REMOVED OR RELOCATED
R	RELOCATED LIGHT OR DEVICE
N	NEW LIGHT OR DEVICE
A.F.F.	ABOVE FINISHED FLOOR
C	CONDUIT
E.C.	EMPTY CONDUIT WITH PULLWIRE
E.D.F.	ELECTRICAL DRINKING FOUNTAIN.
GND	GROUND
MLO	MAIN LUGS ONLY
MCB	MAIN CIRCUIT BREAKER
S.E.S.	SERVICE ENTRANCE SECTION
WP	WEATHER PROOF
WR	WATER RESISTANT
U.N.O.	UNLESS NOTED OTHERWISE

COMcheck Software Version 4.0.8.1
Interior Lighting Compliance Certificate

Section 1: Project Information

Energy Code: 2009 IECC
 Project Title: Which Wich
 Project Type: Alteration

Construction Site: 975 W Poplar Avenue, Collierville, TN 38017
 Owner/Agent: Run Run Design
 Designer/Contractor: Omid Ardebili, 8100 East Indian School Road, Suite 203, Scottsdale, AZ 85251

Section 2: Interior Lighting and Power Calculation

A Area Category	B Floor Area (ft ²)	C Allowed Watts / ft ²	D Allowed Watts (B x C)
Dining, Cafeteria/Fast Food	1756	1.4	2458
Total Allowed Watts =			2458

Section 3: Interior Lighting Fixture Schedule

Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixtures	D Fixture Watt.	E (C X D)
Design: Cafeteria/Fast Food (1756 sq.ft.)				
LED 1: A: DOWNLIGHT: Other:	1	23	11	253
LED 2: B: DOWNLIGHT: Other:	1	5	11	55
Track lighting 1: D/E: 2' TRACK: Wattage based on current limiting device capacity	0	0	60	60
Track lighting 2: D/E: 2' TRACK: Wattage based on current limiting device capacity	0	0	60	60
Track lighting 3: D/E: 2' TRACK: Wattage based on current limiting device capacity	0	0	60	60
Track lighting 4: D/E: 2' TRACK: Wattage based on current limiting device capacity	0	0	60	60
Track lighting 5: D/E: 2' TRACK: Wattage based on current limiting device capacity	0	0	60	60
Track lighting 6: D/E: 2' TRACK: Wattage based on current limiting device capacity	0	0	60	60
Linear Fluorescent 1: H: 2'X2: 48" T8 32W: Electronic	2	6	64	132
Linear Fluorescent 2: F: 2'X4: 48" T8 32W: Electronic	3	4	96	334
Total Proposed Watts =			1564	

Section 4: Requirements Checklist

Lighting Wattage:

1. Total proposed watts must be less than or equal to total allowed watts.

Allowed Watts	Proposed Watts	Complies
2458	1564	Passes

Controls, Switching, and Wiring:

2. Daylight zones under skylights more than 15 feet from the perimeter have lighting controls independent from the general lighting. Daylight zones under skylights more than 15 feet from the perimeter have lighting controls independent from the general lighting.

3. Daylight zones have individual lighting controls independent from that of the general lighting.

Exceptions:

Project Title: Which Wich
 Date: 05/17/2018
 Designer/Contractor: Omid Ardebili
 Project: 975 W Poplar Avenue, Collierville, TN 38017

4. Contiguous daylight zones spanning no more than two orientations are allowed to be controlled by a single controlling device.

Daylight spaces enclosed by walls or ceiling height partitions and containing two or fewer light fixtures are not required to have a separate switch for general area lighting.

4. Independent controls for each space (switch/occupancy sensor).

Exceptions:

Areas designated as security or emergency areas that must be continuously illuminated.

Lighting in stairways or corridors that are elements of the means of egress.

5. Master switch at entry to hotel/motel guest room.

6. Individual dwelling units separately metered.

7. Medical task lighting or ambulatory display lighting claimed to be exempt from compliance has a control device independent of the control of the nonexempt lighting.

8. Each space required to have a manual control also allows for reducing the connected lighting load by at least 50 percent by either controlling all luminaires, dual switching of alternate rows of luminaires, alternate luminaires, or alternate lamps, switching the middle lamp luminaires independently of other lamps, or switching each luminaire or each lamp.

Exceptions:

Only one luminaire in space.

An occupant-sensing device controls the area.

The area is a corridor, storeroom, restroom, public lobby or sleeping unit.

Areas that are less than 0.6 Watts/sq.ft.

9. Automatic lighting shutoff control in buildings larger than 5,000 sq. ft.

Exceptions:

Sleeping units, patient care areas, and spaces where automatic shutoff would endanger safety or security.

Photocell/astrochronometer time switch on exterior lights.

Exceptions:

Lighting intended for 24 hour use.

11. Tandem wired one-lamp and three-lamp ballasted luminaires (No single-lamp control).

Exceptions:

Electronic high-frequency ballasts; luminaires on emergency circuits or with no available ballast.

Section 5: Compliance Comment

Compliance Statement: The proposed lighting alteration project presented in this document is consistent with the building plans, specifications and other documents submitted with this permit application. The proposed lighting alteration project has been designed to meet the 2009 IECC lighting requirements in COMcheck Version 4.0.8.1 and comply with the mandatory requirements in the Requirements Checklist.

Omid Ardebili, 05/17/2018
 Name: Omid Ardebili, Signature: [Signature], Date: 05/17/2018

Project Title: Which Wich
 Date: 05/17/2018
 Designer/Contractor: Omid Ardebili
 Project: 975 W Poplar Avenue, Collierville, TN 38017

LUMINAIRE SCHEDULE								
CALLOUT	SYMBOL	QTY	MODEL	DESCRIPTION	BALLAST	MOUNTING	VOLTS	NOTE 1
A	⊕	(1)	11W LED	CREE LIGHTING LR6-10L-35K-120V-A-DR HOUSING: RC6-GU24 TRIM: LT6BB-DR	ELECTRONIC	RECESSED	120V 1P 2W	4
B	⊕	(1)	11W LED	CREE LIGHTING LR6-10L-35K-120V-A-DR HOUSING: RC6-GU24	ELECTRONIC	RECESSED	120V 1P 2W	4
C/E	⊕	(2)	8W LED PAR 20	JUNO TRACK: R2BL TRACK HEADS: R541BL LAMP: LEDP20030KNFLB CURRENT LIMITER: 0.5A-RCLF11BL/TCL0.5BL.	ELECTRONIC	TRACK	120V 1P 2W	4
EM1	⊕	(2)	6W ELP L16B	LITHONIA LIGHTING AFN-W-EXT	ELECTRONIC	WALL	120V 1P 2W	4
EX	⊕	(1)	2W INTEGRAL LED	EXITRONIX VEX-U-BP-WB-WH	ELECTRONIC	CEILING	120V 1P 2W	4
F	⊕	(3)	32W T8	COOPER METALUX LIGHTING 2GR8-332A-UNV-EBB1-U	ELECTRONIC	LAY-IN	120V 1P 2W	4
H	⊕	(2)	32W T8	COOPER METALUX LIGHTING 2GR8-2U6T8A-UNV-EBB1-U LAMP: GE-72864	ELECTRONIC	LAY-IN	120V 1P 2W	4
Y	⊕	(2)	5W INTEGRAL T5 WEDGE	EXITRONIX LED-90	ELECTRONIC	WALL	120V 1P 2W	4

- ALL FIXTURES TO HAVE WHITE FINISH.
- LUMINAIRE & LAMPS FURNISHED BY VILLA LIGHTING SUPPLY: DEREK VICKROY, 2929 CHOUTEAU AVENUE, ST. LOUIS, MO 63103, P: 214.633.0654, EMAIL: derek.vickroy@villalighting.com
 - ALL FIXTURE TYPES MAY NOT BE USED.
 - REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR FIXTURE MOUNTING HEIGHTS.
 - THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR RECEIVING, STORAGE, INSTALLATION, AND WIRING OF LIGHT FIXTURES.
 - THE ELECTRICAL CONTRACTOR SHALL REPORT ANY DAMAGED LIGHT FIXTURES OR MISSING PARTS TO VILLA LIGHTING WITHIN 48 HOURS OF RECEIPT OF LIGHT FIXTURE PACKAGE.
 - ALL FIXTURES TO HAVE WHITE FINISH.

Electrical Engineer
 Omid Ardebili P.E.
 8100 East Indian School Road Suite 203
 T 480.361.6269 C 480.626.1838
 Proj. Mgr: TME Proj. No.: 18111

RUN RUN DESIGN

PROJECT NAME AND LOCATION:

WHICH WICH?
 SUPERIOR SANDWICHES

STORE #785
 975 W. POPLAR AVENUE
 COLLIERVILLE, TN 38017

THIS DRAWING AND ITS CONTENTS ARE CONSIDERED INSTRUMENTS OF SERVICE AS SUCH THEY ARE COPYRIGHTED PROPERTY OF RUN RUN DESIGN, LLC. THE USE OF THESE DRAWINGS ARE LIMITED TO THIS SPECIFIC PROJECT AND ARE NOT TO BE OTHERWISE REPRODUCED IN ANY WAY OR USED FOR SUPPLEMENTAL LOCATIONS WITHOUT WRITTEN PERMISSION FROM RUN RUN DESIGN, LLC.

DRAWING REVISIONS:

no.	distribution	date
A	ISSUE DATE	12/21/17
B	SUBMITTAL DATE	--
no.	revision	date
1	--	--
2	--	--
3	--	--

SHEET NAME:
ELECTRICAL SPECIFICATIONS & COMCHECK

project no: 17-085
 dwg no: **E0.0**

PRELIMINARY NOT FOR CONSTRUCTION