

KITCHEN EQUIPMENT SCHEDULE

CALLOUT	SYMBOL	QTY.	EQUIPMENT	CATALOG NO.	VOLTS	AMPS	BKR SIZE	WIRE SIZE	DISCONNECT SIZE & TYPE	MOUNTING HEIGHT	MOUNTING LOCATION
E1		2	WALK-IN COOLER	NORLAKE - KAST	208V 2P 2W	6.4	20/2	3/4"C,2#12,#12G	PROVIDE 30A/2P NEMA-3R DISCONNECT SWITCH FUSED PER UNIT NAME PLATE.	VERIFY	WALL
E1a		2	WALK-IN COOLER LTG	NORLAKE	120V 1P 2W	5	20/1	3/4"C,2#12,#12G		VERIFY	VERIFY
E2		1	WALK-IN FREEZER	NORLAKE - KAST	208V 2P 2W	14.8	20/2	3/4"C,2#12,#12G	PROVIDE 30A/2P NEMA-3R DISCONNECT SWITCH FUSED PER UNIT NAME PLATE.	VERIFY	WALL
E2a		1	WALK-IN COOLER LTG	NORLAKE	120V 1P 2W	5	20/1	3/4"C,2#12,#12G		VERIFY	VERIFY
E3		1	ICE MACHINE	SCOTSMAN - N0822A-1	120V 1P 2W	25	30/1	3/4"C,2#10,#10G		VERIFY	WALL
E5a		2	REFRIGERATOR SANDWICH PREP TABLE	TRUE - TSSU-60-24M-B-ST	120V 1P 2W	7.8	20/1	3/4"C,2#12,#12G		+24" A.F.F.	WALL
E5b		2	REFRIGERATOR SANDWICH PREP TABLE	TRUE - TSSU-72-30M-B-ST	120V 1P 2W	10.3	20/1	3/4"C,2#12,#12G		+24" A.F.F.	WALL
E6		1	REFRIGERATOR MERCHANDISER	TRUE - T23DTG	120V 1P 2W	15.6	25/1	3/4"C,2#10,#10G		+24" A.F.F.	WALL
E7		1	EXHAUST HOOD	CAPTIVE AIRE-DU30HFA	120V 1P 2W	4.3	20/1	3/4"C,2#12,#12G			VERIFY
E8		2	CONVEYOR OVEN	LINCOLN - 2501-1346	208V 2P 2W	27	40/2	3/4"C,2#8,#10G		+36" A.F.F.	WALL
E9		1	MICROWAVE OVEN	MENU MASTER - MDC12A2	120V 1P 2W	20	30/1	3/4"C,2#10,#10G		+36" A.F.F.	WALL
E11		2	BLENDER	BLEND-TEC - CA172QWIC	120V 1P 2W	15	20/1	3/4"C,2#12,#12G		+44" A.F.F.	WALL
E12		1	DROP-IN ICE CREAM FREEZER	DELFIELD - N225	120V 1P 2W	5	20/1	3/4"C,2#12,#12G		+24" A.F.F.	WALL
E13		1	SLICER	HOBART - HS7-1	120V 1P 2W	5.6	20/1	3/4"C,2#12,#12G		+44" A.F.F.	WALL
E16		2	SODA DISPENSER	CORNELIUS - ENDURO 250	120V 1P 2W	3.4	20/1	3/4"C,2#12,#12G		+24" A.F.F.	WALL
E17		2	TEA DISPENSER	BUNN - ITB DD 41400	120V 1P 2W	14.8	20/1	3/4"C,2#12,#12G		+24" A.F.F.	WALL
E18		1	BAG IN THE BOX	PROVIDED BY VENDOR	120V 1P 2W	5	20/1	3/4"C,2#12,#12G			
E19		1	SODA CARBONATOR	PROVIDED BY VENDOR	120V 1P 2W	8.3	20/1	3/4"C,2#12,#12G		+60" A.F.F.	WALL
E32		1	SOUND SYSTEM AMPLIFIER	TOA - BG-1060	120V 1P 2W	1.4	20/1	3/4"C,2#12,#12G		+60" A.F.F.	WALL
E33		1	PHONE (CORDLESS)	UNIDEN - L8TRU945-2	120V 1P 2W	2.1	20/1	3/4"C,2#12,#12G		+44" A.F.F.	WALL
E34		1	BACK OFFICE PRINTER/SCANNER/FAX	BROTHER - MFC-8220	120V 1P 2W	3.5	20/1	3/4"C,2#12,#12G		+44" A.F.F.	WALL
E35		1	BACK OFFICE POS SERVER	RAIDIAN - S337	120V 1P 2W	3.3	20/1	3/4"C,2#12,#12G		+50" A.F.F.	WALL
E36		3	POS THERMAL PRINTER	EPSON - TM-T88IV	120V 1P 2W	3.3	20/1	3/4"C,2#12,#12G		+20" A.F.F.	WALL
E37		3	POS TERMINAL	RADIANT - P1222HD	120V 1P 2W	3.7	20/1	3/4"C,2#12,#12G		+20" A.F.F.	WALL
E49		1	UNDER COUNTER REFRIGERATOR	TRUE - TUC-27	120V 1P 2W	3.9	20/1	3/4"C,2#12,#12G		+24" A.F.F.	WALL
E51		1	DIPPING CABINET	CLABO - ITALIANA #G22	208V 2P 2W	14	30/2	3/4"C,2#10,#10G			
E52		2	MENU BOARD	PROVIDED BY VENDOR	120V 1P 2W	5	20/1	3/4"C,2#12,#12G			VERIFY EXACT LOCATION WITH ARCHITECT AND ELECTRICAL REQUIREMENTS WITH VENDOR PRIOR TO INSTALLATION.
E53		1	ESPRESSO MACHINE	SCHAERER USA - 040381-0002IEUS	208V 2P 2W	24	30/2	3/4"C,2#10,#10G			
E54		1	COFFEE BREWER	BUNN - CW15 - AFS	120V 1P 2W	11.4	20/1	3/4"C,2#12,#12G			
E56		1	COFFEE GRINDER	MARCUZZI HAUS	208V 2P 2W	30	40/2	3/4"C,2#8,#10G			
G1		1	PAY HERE SIGN	PROVIDED BY VENDOR	120V 1P 2W	6.5	20/1	3/4"C,2#12,#12G			VERIFY EXACT LOCATION WITH ARCHITECT AND ELECTRICAL REQUIREMENTS WITH VENDOR PRIOR TO INSTALLATION.
G2		1	PICK UP HERE SIGN	PROVIDED BY VENDOR	120V 1P 2W	6.5	20/1	3/4"C,2#12,#12G			VERIFY EXACT LOCATION WITH ARCHITECT AND ELECTRICAL REQUIREMENTS WITH VENDOR PRIOR TO INSTALLATION.
G3		1	WHICH MICH DO YOU WANT	PROVIDED BY VENDOR	120V 1P 2W	6.5	20/1	3/4"C,2#12,#12G			VERIFY EXACT LOCATION WITH ARCHITECT AND ELECTRICAL REQUIREMENTS WITH VENDOR PRIOR TO INSTALLATION.
G4		1	OPEN SIGN	PROVIDED BY VENDOR	120V 1P 2W	6.5	20/1	3/4"C,2#12,#12G			INSTALL ABOVE FRONT DOOR.
G5		1	MEDALLION SIGN	PROVIDED BY VENDOR	120V 1P 2W	6.5	20/1	3/4"C,2#12,#12G			VERIFY EXACT LOCATION WITH ARCHITECT AND ELECTRICAL REQUIREMENTS WITH VENDOR PRIOR TO INSTALLATION.
S3		2	MENU BOARD	VERIFY	120V 1P 2W	5	20/1	3/4"C,2#12,#12G			VERIFY EXACT LOCATION WITH ARCHITECT AND ELECTRICAL REQUIREMENTS WITH VENDOR PRIOR TO INSTALLATION.
X1		2	HAND DRYER	XCELERATOR - XLGR	120V 1P 2W	12.2	20/1	3/4"C,2#12,#12G			INSTALL AT AN ACCESSIBLE HEIGHT
X11		1	FLAT SCREEN T.V.	PROVIDED BY VENDOR	120V 1P 2W	3	20/1	3/4"C,2#12,#12G			VERIFY EXACT LOCATION WITH ARCHITECT AND ELECTRICAL REQUIREMENTS WITH VENDOR PRIOR TO INSTALLATION.

MECHANICAL EQUIPMENT SCHEDULE

CALLOUT	DESCRIPTION	SYMBOL	VOLTS	FLA	MCA	MOCF	CIRCUIT	WIRE CALLOUT	NOTE 1
(E)EF-1	EXISTING EXHAUST FAN		120V 1P 2W	0.67		20	D-4	3/4"C,2#12,#12G	INTERLOCK FAN OPERATION WITH RESTROOM LIGHT SWITCH.
(E)EF-2	EXISTING EXHAUST FAN		120V 1P 2W	0.67		20	D-4	3/4"C,2#12,#12G	INTERLOCK FAN OPERATION WITH RESTROOM LIGHT SWITCH.
(E)RTU-1	EXISTING ROOF TOP UNIT		208V 3P 3W	37.8	42	50	A-3,5,7	3/4"C,3#6,#10G	PROVIDE NEW HOMERUN FROM EXISTING DISCONNECT SWITCH.
KEF-1	NEW KITCHEN EXHAUST FAN		120V 1P 2W	4		20	A-20	3/4"C,2#12,#12G	INTERLOCK FAN OPERATION WITH TIMELOCK TO RUN DURING HOURS OF OPERATION. PROVIDE 30A/1P NEMA-3R DISCONNECT SWITCH FUSED PER UNIT NAMEPLATE.
RTU-2	NEW ROOF TOP UNIT		208V 3P 3W	21.6	24	30	14,16,18	3/4"C,3#10,#10G	PROVIDE 30A/3P NEMA-3R DISCONNECT SWITCH FUSED PER UNIT NAMEPLATE.

RUN RUN DESIGN

PROJECT NAME AND LOCATION :



STORE #785
975 W. POPLAR AVENUE
COLLIERVILLE, TN 38017

THIS DRAWING AND ITS CONTENTS ARE CONSIDERED INSTRUMENTS OF SERVICE AS SUCH THEY ARE COPYRIGHTED PROPERTY OF RUN RUN DESIGN, LLC. THE USE OF THESE DRAWINGS ARE LIMITED TO THIS SPECIFIC PROJECT AND ARE NOT TO BE OTHERWISE REPRODUCED IN ANY WAY OR USED FOR SUPPLEMENTAL LOCATIONS WITHOUT WRITTEN PERMISSION FROM RUN RUN DESIGN, LLC.

DRAWING REVISIONS:

no.	distribution	date
A	ISSUE DATE	12.21.17
B	SUBMITTAL DATE	--
no.	revision	date
1	--	--
2	--	--
3	--	--

SHEET NAME:
EQUIPMENT SCHEDULES

project no: 17-085
dwg no: E2.2

PRELIMINARY NOT FOR CONSTRUCTION

Electrical Engineer
Omid Ardebili P.E.
8100 East Indian School Road Suite 203
T 480.361.6269 C 480.626.1838
Proj. Mgr: TME Proj. No.: 18111

THE ELECTRICAL CONTRACTOR SHALL VERIFY ROUGH-IN REQUIREMENTS, LOCATIONS, MOUNTING HEIGHTS, VOLTAGE, PHASE, AMPS, HP, KW, ETC. FOR ALL EQUIPMENT PRIOR TO ROUGH-IN.