

PANEL SCHEDULE ERP

(Panel previously referred to as Panel ERP)

Existing to remain, 208 Volt, 3 Phase, 4 Wire, 42 Pole, 600 Amp MLO Panel.																										
#	Description	P	A	W	Cond	FLA	Watts	KwA	KwB	KwC	#	Description	P	A	W	Cond	FLA	Watts	KwA	KwB	KwC					
1	(E)Panel C2	3	(E)0		ETR	14	4840	2.3			2	(E)Panel C1	3	(E)0		ETR	20	7073	2.7							
7	Elec Room Light	1	(E)00				0	0.0			9	SPARE	3	(E)00				0	0.0							
9	Elec Room Ex Fan	1	(E)00				0	0.0			14	ACCA (Refrigeration Condensed)	3	(E)00	84	1-1/2"	64	1940	0.5							
11	SPARE	1	(E)00				0	0.0			20	SPARE	3	(E)00				0	0.0							
13	SPARE	1	(E)00				0	0.0			26	SPARE	1	(E)00				0	0.0							
15	SPARE	3	(E)00				0	0.0			28	SPARE	1	(E)00				0	0.0							
21	Mesh Room	1	(E)00				0	0.0			30	SPARE	1	(E)00				0	0.0							
23	SPARE	1	(E)00				0	0.0			32	SPARE	1	(E)00				0	0.0							
25	SPARE	1	(E)00				0	0.0			34	SPARE	1	(E)00				0	0.0							
27	SPARE	3	(E)00				0	0.0			36	SPARE	1	(E)00				0	0.0							
33	SPARE	1	(E)00				0	0.0			38	SPARE	1	(E)00				0	0.0							
35	SPARE	1	(E)00				0	0.0			40	SPARE	1	(E)00				0	0.0							
37	SPARE	1	(E)00				0	0.0			42	SPARE	1	(E)00				0	0.0							
39	SPARE	1	(E)00				0	0.0																		
41	SPARE	1	(E)00				0	0.0																		
Total KW Phase A.....								11.5	Total Connected KW.....								31	Total Connected Amps.....								87
Total KW Phase B.....								10.2	Total Connected Amps.....								87	Minimum Service Size.....								100 AMP'S
Total KW Phase C.....								9.7	Minimum Service Size.....								100 AMP'S									

PANEL SCHEDULE P1

(Panel previously referred to as Panel P1D)

Existing to remain, 208 Volt, 3 Phase, 4 Wire, 42 Pole, 200 Amp MLO Panel.																										
#	Description	P	A	W	Cond	FLA	Watts	KwA	KwB	KwC	#	Description	P	A	W	Cond	FLA	Watts	KwA	KwB	KwC					
1	PL-Soup Hot Vials (DE37)	1	(E)00	#12	3/4"	28	3300	3.5			2	Bag Light & Conv Rec BH	1	(E)00	#12	3/4"	5	720	0.7							
3	Ice Machine Rec	1	(E)00	#12	3/4"	15	1800	2.3		1.8	4	Bag Light & Conv Rec BH	1	(E)00	#12	3/4"	5	720	0.7							
5	Disp Mgr Rec	1	(E)00	#12	3/4"	6	720	0.9		0.7	6	PP Bag Light & Conv Rec	1	(E)00	#12	3/4"	5	600	0.7							
7	Office Mgr Rec	1	(E)00	#12	3/4"	9	1080	1.1			8	Doc Lt, Res, Bell, Bag Lt	1	(E)00	#12	3/4"	5	720	0.7							
9	Store Dr Rec	1	(E)00	#12	3/4"	8	960	0.9		0.9	10	Reluctator	1	(E)00	#12	3/4"	8	960	1.0							
11	Scan Rec	1	(E)00	#12	3/4"	8	960	0.9		0.7	12	Receipt - Green-Gra Case	1	(E)00	#12	3/4"	7	840	0.7							
13	Lighting Control Panel	1	(E)00	#12	3/4"	3	420	0.4			14	Receipt - Checkover	2	(E)00	#12	3/4"	2	240	0.2							
15	Employee Rm Rec	1	(E)00	#12	3/4"	8	960	0.7		0.7	16	Restroom Recp	1	(E)00	#12	3/4"	3	360	0.4							
17	SPARE	2	(E)00				0	0.0		0.0	18	Reverse Osmosis (RO2)	1	(E)00	#12	3/4"	5	600	0.7							
21	SPARE	2	(E)00				0	0.0		0.0	20	Receipt-Fan Coffee Case	1	(E)00	#12	3/4"	5	600	0.7							
26	SPARE	1	(E)00				0	0.0		0.0	22	GF-Water Fountain (BKT08)	1	(E)00	#12	3/4"	3	360	0.4							
27	Reman Pasta Cooker/hood Lts	1	(E)00	#12	3/4"	3	360	0.4		0.4	24	Shop-Vac Rice Cooker	1	(E)00	#12	3/4"	12	1440	1.4							
29	Beak-Cold Water (CE36)	1	(E)00	#12	3/4"	8	960	0.9		0.9	26	Ice Machine (P1G4)	2	(E)00	#12	3/4"	4	480	0.4							
31	Janitor Closet Recp	1	(E)00	#12	3/4"	2	240	0.2		0.2	28	Meal Wrapper (ME11)	1	(E)00	#12	3/4"	5	720	0.7							
33	Grab-N-Go Receipts	1	(E)00	#12	3/4"	3	360	0.4		0.4	30	Receipt - Gnc. Console	1	(E)00	#12	3/4"	1	120	0.1							
35	Grab-N-Go Receipts	1	(E)00	#12	3/4"	3	360	0.4		0.4	38	Receipt - Gnc. Console	1	(E)00	#12	3/4"	1	120	0.1							
37	Swish Prep Table (CE34)	1	(E)00	#12	3/4"	9	1080	1.0		0.0	39	SPARE	3	(E)00				0	0.0							
39	SPARE	2	(E)00				0	0.0		0.0																
Total KW Phase A.....								10.0	Total Connected KW.....								29	Total Connected Amps.....								87
Total KW Phase B.....								7.8	Total Connected Amps.....								87	Minimum Service Size.....								100 AMP'S
Total KW Phase C.....								7.1	Minimum Service Size.....								100 AMP'S									

PANEL SCHEDULE L1

(Panel previously referred to as Panel LPB)

Existing to remain, 208 Volt, 3 Phase, 4 Wire, 42 Pole, 200 Amp MLO Panel.																										
#	Description	P	A	W	Cond	FLA	Watts	KwA	KwB	KwC	#	Description	P	A	W	Cond	FLA	Watts	KwA	KwB	KwC					
1	Lighting - Cable Seating	1	(E)00	#12	3/4"	9	1080	1.1			2	SPARE	1	(E)00				0	0.0							
3	Lighting - Natural Living	1	(E)00	#12	3/4"	10	1200	1.4		1.2	4	SPARE	1	(E)00				0	0.0							
5	Lighting - Natural Living	1	(E)00	#12	3/4"	10	1200	1.4		1.2	6	SPARE	1	(E)00				0	0.0							
7	Lighting - Bulk/F/Beer/Wine	1	(E)00	#12	3/4"	12	1440	1.4		1.2	8	SPARE	1	(E)00				0	0.0							
9	Lighting - Check Out	1	(E)00	#12	3/4"	10	1152	1.2		1.0	10	SPARE	1	(E)00				0	0.0							
11	Lighting - Grocery	1	(E)00	#12	3/4"	11	1344	1.3		1.3	12	Lighting - Deli/Cheese Prep	1	(E)00	#12	3/4"	9	1100	1.1							
13	Lighting - Grocery	1	(E)00	#12	3/4"	11	1344	1.3		1.3	14	Lighting - Bakery Prep	1	(E)00	#12	3/4"	9	1100	1.1							
15	Lighting - Grocery	1	(E)00	#12	3/4"	11	1344	1.3		1.3	16	Lighting - Ramen Bar	1	(E)00	#12	3/4"	5	615	0.6							
17	Lighting - Produce	1	(E)00	#12	3/4"	11	1344	1.3		1.3	18	SPARE	1	(E)00				0	0.0							
19	Lighting - Cakes/Roll/Hall	1	(E)00	#12	3/4"	11	1317	1.3		1.3	20	SPARE	1	(E)00				0	0.0							
21	Lighting - Walk In Coolers/Freezer	1	(E)00	#12	3/4"	11	1296	1.3		1.3	22	SPARE	1	(E)00				0	0.0							
23	Lighting - Office/IT/Comm	1	(E)00	#12	3/4"	9	1080	1.1		1.1	24	SPARE	1	(E)00				0	0.0							
25	Lighting - Out Room	1	(E)00	#12	3/4"	3	378	0.4		0.4	26	SPARE	1	(E)00				0	0.0							
27	Lighting - Stock Rm/Elec Rms	1	(E)00	#12	3/4"	7	882	0.8		0.8	28	SPARE	1	(E)00				0	0.0							
29	Lighting - Stock Rm	1	(E)00	#12	3/4"	7	882	0.8		0.8	30	SPARE	1	(E)00				0	0.0							
31	HC-Lighting - Stock Rm Lt Lts	1	(E)00	#12	3/4"	4	486	0.5		0.5	32	SPARE	1	(E)00				0	0.0							
33	HC-Lighting - Sales Night Lts	1	(E)00	#12	3/4"	7	882	0.8		0.8	34	Rear Walk Pack Lights	1	(E)00	#12	3/4"	1	132	0.1							
35	SPARE	1	(E)00				0	0.0		0.0	36	Store Front Signs - Right	1	(E)00	#10	3/4"	10	1200	1.2							
37	SPARE	1	(E)00				0	0.0		0.0	40	Store Front Signs - Left	1	(E)00	#10	3/4"	10	1200	1.2							
39	SPARE	1	(E)00				0	0.0		0.0	42	Store Front Signs - Main	1	(E)00	#10	3/4"	17	2052	2.3							
41	SPARE	1	(E)00				0	0.0		0.0																
Total KW Phase A.....								8.3	Total Connected KW.....								27	Total Connected Amps.....								75
Total KW Phase B.....								8.9	Total Connected Amps.....								75	Minimum Service Size.....								80 AMP'S
Total KW Phase C.....								8.7	Minimum Service Size.....								80 AMP'S									

PANEL SCHEDULE P2

(Panel previously referred to as Panel LPC)

Reallocated 208 Volt, 3 Phase, 4 Wire, 42 Pole, 200 Amp MLO Panel.																						
#	Description	P	A	W	Cond	FLA	Watts	KwA	KwB	KwC	#	Description	P	A	W	Cond	FLA	Watts	KwA	KwB	KwC	
1	Cash Rm TV Rec	1	(E)00	#12	3/4"	3	360	0.4			2	Shredder Rec	1	(E)00	#12	3/4"	5	600	0.7			
3	Checkstand Rec	1	(E)00	#12	3/4"	3	360	0.4		0.4	4	Checkstand Rec	1	(E)00	#12	3/4"	3	360	0.4			
5	Checkstand Rec	1	(E)00	#12	3/4"	3	360	0.4		0.4	6	Checkstand Rec	1	(E)00	#12	3/4"	3	360	0.4			
7	Checkstand Rec	1	(E)00	#12	3/4"	3	360	0.4		0.4	8	Checkstand Rec	1	(E)00	#12	3/4"	3	360	0.4			
9	UO Ice Machine (CA05)	1	(E)00	#12	3/4"	8	960	0.9		0.9	10	Chili Reaster (DE09) Prod. Rec	1	(E)00	#12	3/4"	6	720	0.8			
11	Cash Conv Receipts	1	(E)00	#12																		