

PROVIDE TO THE CONTRACTOR THE FOLLOWING INFORMATION TO BE USED FOR THE DESIGN OF THE ROOF PENETRATIONS AND CURBED ROOF OPENINGS. THIS INFORMATION IS FOR THE CONTRACTOR'S USE ONLY AND IS NOT TO BE USED FOR ANY OTHER PURPOSE. THE CONTRACTOR SHALL BE RESPONSIBLE FOR VERIFYING THE EXACT LOCATION AND SIZE OF THE ROOF PENETRATIONS AND CURBED ROOF OPENINGS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES.

NO.	DESCRIPTION	DATE
1	ISSUED FOR PERMITTING	05.05.18
2	REVISION	
3	REVISION	
4	REVISION	
5	REVISION	
6	REVISION	
7	REVISION	
8	REVISION	
9	REVISION	
10	REVISION	

DATE: 05.05.18  
SCALE: 1/8" = 1'-0"  
DRAWN BY: N. RENTERIA  
CHK'D BY: ---  
APRV'D BY: ---  
PLAN: B2419ER1-9\_DNS1-4.dwg

**LUCKY'S MARKET  
THE PROMENADE AT NAPLES CENTRE**  
NEW STORE  
6424 NAPLES BLVD., SUITE 601, NAPLES, FL

REFRIGERATION COMPRESSOR RACK A BELOW IN REFRIGERATION MECHANICAL CENTER.  
GENERAL CONTRACTOR TO PROVIDE A CLEAR 16'-10"x5'-3" TEMPORARY ROOF OPENING FOR RACK INSTALLATION. COORDINATE LOCATION WITH REFRIGERATION CONTRACTOR, STRUCTURAL ENGINEER & ARCHITECT BEFORE PERFORMING ANY RELATED WORK. STRUCTURAL ENGINEER & ARCHITECT ARE NOT PROVIDED BY HUSSMANN.

**PENETRATION NOTE:**  
ALL PENETRATION OPENING REQUIRED FOR REFRIGERATION LINES TO BE PROVIDED BY GENERAL CONTRACTOR. ALL OPENINGS TO MEET ANY LOCAL CODE SPECIFICATIONS

**ROOF MOUNTED EQUIPMENT NOTE:**  
GEN. CONTR. TO COORDINATE THE LOCATIONS, PENETRATIONS, RAIN HOODS, PLATFORMS AND APPROVED RUNNERS WITH THE REFRIG. CONTR., STRUCTURAL ENGINEER & ALL OTHER RELATED CONTRACTORS BEFORE ANY RELATED WORK IS DONE. ALL PENETRATIONS, PLATFORMS, APPROVED RUNNERS & RAIN HOODS ARE BY THE GEN. CONTR. UNLESS NOTED OTHERWISE. ELECT. CONTR. TO WIRE AND CONNECT ALL EQUIPMENT. ALL WORK IS TO CONFORM TO ANY RELATED APPLICABLE CODES. STRUCTURAL ENGINEER IS NOT PROVIDED BY HUSSMANN.

GENERAL CONTRACTOR TO PROVIDE A CURBED ROOF OPENING WITH RAINHOOD FOR REFRIGERATION LINE PENETRATIONS. (FIELD VERIFY EXACT LOCATION)

NEW KRACK LAVF 25410M AIR COOLED CONDENSER ON ROOF FOR RACK "A"  
SIZE: 274"x90.5"x58.5"  
WEIGHT: 4,048 LBS  
GENERAL CONTRACTOR TO PROVIDE A LEVEL PLATFORM OR RUNNERS OR CODE APPROVED EQUIVALENT FOR ROOF MOUNT EQUIPMENT. VERIFY EXACT LOCATION PRIOR TO PERFORMING ANY RELATED WORK

AMBIENT TEMPERATURE SENSOR (UNDER AIR INTAKE SIDE AND OUT OF THE DIRECT SUN)

CONDENSER CONTROL PANEL  
ELECTRICAL CONTRACTOR TO WIRE & CONNECT FOR LOCAL CODES. REFRIGERATION SCHEMATIC AND WIRING SCHEMATICS FOR MORE INFORMATION.

Order Plans @ [www.LDILine.com](http://www.LDILine.com)