

ALL DESIGNS, DRAWINGS AND SPECIFICATIONS DEPICTED ON THIS SHEET ARE PROPERTY OF COAST ARCHITECTS, INC. COPYRIGHT © 2017 ANY UNAUTHORIZED USE OR REPRODUCTION IS SUBJECT TO LEGAL PROSECUTION. POSSESSION IN ANY FORM CONSTITUTES ACCEPTANCE OF THESE CONDITIONS.

SILT FENCE INSTALLATION

PLAN SYMBOL

1.25 LB./LINEAR FT. STEEL POSTS

MAXIMUM SPACING = 6 FT.

BACKFILL TRENCH WITH COMPACTED EARTH

RUNOFF

HEAVY DUTY PLASTIC TIE FOR STEEL POSTS (RESTRICT TO TOP 6-INCHES OF FABRIC)

BURY FABRIC

USE EITHER FLAT-BOTTOM OR V-BOTTOM TRENCH SEE DETAILS

SILT FENCE - GENERAL NOTES

- Do not place silt fence across channels or in other areas subject to concentrated flows. Silt fence should not be used as a velocity control BMP. Concentrated flows are any flows greater than 0.5 cfs.
- Maximum sheet or overlaid flow path length to the silt fence shall be 100-feet.
- Maximum slope steepness (normal [perpendicular] to the fence line) shall be 2:1.
- Silt fence joints, when necessary, shall be completed by one of the following options:
 - Wrap each fabric together at a support post with both ends fastened to the post, with a 1-foot minimum overlap.
 - Overlap all fence by installing 3-feet passed the support post to which the new silt fence roll is attached. Attach old roll to new roll with heavy-duty plastic ties, or
 - Overlap entire width of each silt fence roll from one support post to the next support post.
- Attach filter fabric to the steel posts using heavy-duty plastic ties that are evenly spaced within the top 6-inches of the fabric.
- Install the silt fence perpendicular to the direction of the stormwater flow and place the silt fence the proper distance from the toe of steep slopes to provide sediment storage and access for maintenance and cleanup.
- Install Silt Fence Checks (Bios-Backs) every 20-100 feet, dependent on slope, along silt fence that is installed with slope and where concentrated flows are expected or are documented along the proposed/installed silt fence.

DELINEATED AS SF ON PLANS

FLAT-BOTTOM TRENCH DETAIL

18-IN. TO 24-IN.

24-IN. (MINIMUM)

6-IN.

6-IN.

HEAVY DUTY PLASTIC TIES

COMPACTED EARTH

RUNOFF

FLITER FABRIC

V-SHAPED TRENCH DETAIL

18-IN. TO 24-IN.

24-IN. (MINIMUM)

6-IN.

6-IN.

HEAVY DUTY PLASTIC TIES

COMPACTED EARTH

RUNOFF

FLITER FABRIC

BURY FILTER FABRIC AT LEAST 12-INCHES

South Carolina Department of Health and Environmental Control

SILT FENCE

STANDARD DRAWING NO. SC-03 PAGE 1 of 2

NOT TO SCALE

FEBRUARY 2014 DATE

POST INSTALLATION DETAIL

1.25 LB./LINEAR FT. STEEL POSTS

24-IN. MIN.

3-FT. MAX. SPACING

ATTACH FILTER FABRIC TO POSTS WITH HEAVY DUTY PLASTIC TIES ALONG TOP 6-INCHES OF FABRIC

FOLD FABRIC TO OVERLAP 1 FOOT AND SECURE TO POSTS WITH HEAVY DUTY PLASTIC TIES

BURY FABRIC (SEE DETAIL)

PLAN SYMBOL

48-IN. MIN.

8-IN. MIN.

18-IN. TO 24-IN.

South Carolina Department of Health and Environmental Control

TYPE A FILTER FABRIC INLET PROTECTION

STANDARD DRAWING NO. SC-07 PAGE 1 of 2

NOT TO SCALE

FEBRUARY 2014 DATE

WIRE MESH OF SUFFICIENT STRENGTH TO PROTECT FILTER FABRIC REQUIRED

ATTACH FILTER FABRIC TO POSTS WITH HEAVY DUTY PLASTIC TIES ALONG TOP 6-INCHES OF FABRIC

FOLD FABRIC TO OVERLAP 1 FOOT AND SECURE TO POSTS WITH HEAVY DUTY PLASTIC TIES

BURY FABRIC (SEE DETAIL)

PLAN SYMBOL

South Carolina Department of Health and Environmental Control

TYPE A FILTER FABRIC INLET PROTECTION

STANDARD DRAWING NO. SC-07 PAGE 1 of 2

NOT TO SCALE

FEBRUARY 2014 DATE

STRAW BALE BARRIER CONCRETE WASHOUT

12" MIN.

STAKE (TYP.)

STAPLES #12 DIA. 4" STAPLE (2 PER BALE)

BINDING WIRE

WOOD OR METAL STAPLES (2 PER BALE)

NATIVE MATERIAL (OPTIONAL)

SECTION B-B

PLAN TYPE "ABOVE GRADE" WITH STRAW BALE

LETTERS A MINIMUM OF 5" IN HEIGHT

CONCRETE WASHOUT SIGN DETAIL

NOTES:

- ACTUAL LAYOUT DETERMINED IN FIELD.
- INSTALL CONCRETE WASHOUT SIGN (24"x24", MINIMUM) WITHIN 50' OF THE TEMPORARY CONCRETE WASHOUT FACILITY.
- TEMPORARY WASHOUT AREA MUST BE AT LEAST 50' FROM A STORM DRAIN, CREEK BANK OR PERMETER CONTROL.
- CLEAN OUT CONCRETE WASHOUT AREA WHEN FULL.
- THE KEY TO FUNCTIONAL CONCRETE WASHOUTS WEEKLY INSPECTIONS, REGULAR MAINTENANCE, AND REGULAR CLEAN OUT.
- SILT FENCE SHOULD BE INSTALLED AROUND PERIMETER OF CONCRETE WASHOUT AREA EXCEPT FOR THE SIDE UTILIZED FOR ACCESS TO WASHOUT.
- CONSTRUCTION ENTRANCE MAY BE ACCESSIBLE ALONG PERIMETER OF THE WASHOUT FROM TRUCK ACCESS.

South Carolina Department of Health and Environmental Control

CONCRETE WASHOUT STRAW BALES OR ABOVE GROUND

STANDARD DRAWING NO. RC-07 PAGE 1 of 1

NOT TO SCALE

FEBRUARY 2014 DATE

SILT FENCE - INSPECTION & MAINTENANCE

- Silt fence posts must be 48-inch long steel posts that meet, at a minimum, the following physical characteristics:
 - Composed of a high strength steel with a minimum yield strength of 50,000 psi.
 - Include a standard "T" section with a nominal face width of 1.38-inches and a nominal "T" length of 1.48-inches.
 - Weight 1.25 pounds per foot (1.85).
- Posts shall be equipped with projections to aid in fastening of filter fabric.
- Steel posts may need to have a metal soil stabilization plate welded near the bottom when installed along steep slopes or installed in loose soils. The plate should have a minimum cross section of 17-square inches and be composed of 1/2 square steel, at a minimum. The metal soil stabilization plate should be completely buried.
- Install posts to a minimum of 24-inches. A minimum height of 1- to 2-inches above the fabric shall be maintained, and a maximum height of 3 feet shall be maintained above the ground.
- Post spacing shall be at a maximum of 6-feet on center.

SILT FENCE - FABRIC REQUIREMENTS

- Silt fence must be composed of woven geotextile filter fabric that consists of the following requirements:
 - Composed of fibers consisting of long chain synthetic polymers of at least 85% by weight of polyethylene, polyesters, or polyamides that are formed into a network such that the filaments or yarns retain dimensional stability relative to each other.
 - Free of any treatment or coating which might adversely affect its physical properties after installation.
 - Free of any defects or flaws that significantly affect its physical and/or filtering properties; and
 - Have a minimum width of 36-inches.
- Use only fabric appearing on SC DOT's Qualified Products Listing (QPL), Approval Sheet #34, meeting the requirements of the most current edition of the SC DOT Standard Specifications for Highway Construction.
- 12-inches of the fabric should be placed within excavated trench and tamped in when the trench is backfilled.
- Filter fabric shall be purchased in continuous rolls and cut to the length of the barrier to avoid joints.
- Filter fabric shall be installed at a minimum of 24-inches above the ground.

South Carolina Department of Health and Environmental Control

SILT FENCE

STANDARD DRAWING NO. SC-03 PAGE 2 of 2

GENERAL NOTES

NOT TO SCALE

FEBRUARY 2014 DATE

TYPE A - FILTER FABRIC REQUIREMENTS

- Silt fence must be composed of woven geotextile filter fabric that consists of the following physical characteristics:
 - Composed of fibers consisting of long chain synthetic polymers of at least 85% by weight of polyethylene, polyesters, or polyamides that are formed into a network such that the filaments or yarns retain dimensional stability relative to each other.
 - Free of any treatment or coating which might adversely affect its physical properties after installation.
 - Free of any defects or flaws that significantly affect its physical and/or filtering properties; and
 - Have a minimum width of 36-inches.
- Use only fabric appearing on SC DOT's Qualified Products Listing (QPL), Approval Sheet #34, meeting the requirements of the most current edition of the SC DOT Standard Specifications for Highway Construction.
- 12-inches of the fabric should be placed within excavated trench and tamped in when the trench is backfilled.
- Filter fabric shall be purchased in continuous rolls and cut to the length of the barrier to avoid joints.
- Filter fabric shall be installed at a minimum of 24-inches above the ground.

TYPE A - INSPECTION & MAINTENANCE

- The key to functional inlet protection is weekly inspections, routine maintenance, and regular sediment removal.
- Regular inspections of inlet protection shall be conducted once every calendar week and, as recommended, within 24-hours after each rainfall event that produces 1/2-inch or more of precipitation.
- Attention to sediment accumulations along the filter fabric is extremely important. Accumulated sediment should be continuously monitored and removed when necessary.
- Remove accumulated sediment when it reaches 1/3 the height of the filter fabric. When a storm is included in front of the filter fabric, it should be removed when it has accumulated approximately 1/2 the depth of the filter fabric.
- Removed sediment shall be placed in a designated storage area and not spread over the disturbed area. Stabilize the removed sediment after it is relocated.
- Check for areas where stormwater runoff has eroded a channel beneath the silt fence, or where the fence has sagged or collapsed due to runoff overtopping the silt fence. Install checks/riser-blocks and/or reinstall silt fence, as necessary.
- Check for tears within the silt fence, areas where silt fence has begun to decompose, and for any other circumstance that may render the silt fence ineffective. Removed damaged silt fence and reinstall new silt fence immediately.
- Silt fence should be removed within 30 days after final stabilization is achieved and once it is removed, the resulting disturbed area shall be permanently stabilized.

South Carolina Department of Health and Environmental Control

TYPE A - POST REQUIREMENTS

- Silt fence posts must be 48-inch long steel posts that meet, at a minimum, the following physical characteristics:
 - Composed of a high strength steel with a minimum yield strength of 50,000 psi.
 - Include a standard "T" section with a nominal face width of 1.38-inches and a nominal "T" length of 1.48-inches.
 - Weight 1.25 pounds per foot (1.85).
- Posts shall be equipped with projections to aid in fastening of filter fabric.
- Install posts to a minimum of 24-inches. A minimum height of 1- to 2-inches above the fabric shall be maintained, and a maximum height of 3 feet shall be maintained above the ground.
- Post spacing shall be at a maximum of 3-feet on center.

South Carolina Department of Health and Environmental Control

TYPE A - FILTER FABRIC INLET PROTECTION

STANDARD DRAWING NO. SC-07 PAGE 2 of 2

GENERAL NOTES

NOT TO SCALE

FEBRUARY 2014 DATE

CONSTR. ENTRANCE INSPECTION & MAINTENANCE

- The key to functional construction entrances is weekly inspections, routine maintenance, and regular sediment removal.
- Regular inspections of construction entrances shall be conducted once every calendar week and, as recommended, within 24-hours after each rainfall event that produces 1/2-inch or more of precipitation.
- During regular inspections, check for mud and sediment buildup and/or debris. Inspection frequency may need to be more frequent during long periods of wet weather.
- Reshape the stone pad as necessary for drainage and runoff control.
- Wash or replace stones as needed and as directed by site inspector. The stone in the entrance should be washed or replaced whenever the entrance fails to reduce the amount of mud being carried off-site by vehicles. Frequent washing will extend the useful life of stone pad.
- Immediately remove mud and sediment tracked or washed onto adjacent impervious surfaces by brooming or sweeping. Flushing should only be used when the water can be discharged to a sediment trap or basin.
- During maintenance activities, any broken pavement should be repaired immediately.
- Construction entrances should be removed after the site has reached final stabilization. Permanent vegetation should replace areas from which construction entrances have been removed, unless areas will be converted to an impervious surface to serve post-construction.

South Carolina Department of Health and Environmental Control

CONSTRUCTION ENTRANCE

STANDARD DRAWING NO. SC-06 PAGE 1 of 2

NOT TO SCALE

FEBRUARY 2014 DATE

CONSTRUCTION ENTRANCE DETAIL

6-INCH MIN.

24-FT. MIN.

UNDERLYING NON-WOVEN GEOTEXTILE FABRIC

EDGES SHALL BE TAPERED TOWARDS ROAD TO PREVENT TRACKING OF MUD ON THE EDGE.

PLAN SYMBOL

South Carolina Department of Health and Environmental Control

CONSTRUCTION ENTRANCE

STANDARD DRAWING NO. SC-06 PAGE 2 of 2

GENERAL NOTES

NOT TO SCALE

FEBRUARY 2014 DATE

TREE BARRICADE/PROTECTION DETAIL

4" HIGH ORANGE POLYETHYLENE LAMINAR SAFETY NETTING SECURED TO POST AND CROSS BAR WITH WIRE.

6 IN. (SEE NOTE)

METAL POSTS AT 5 FOOT ON CENTER

1" DIA. METAL CROSS BAR SECURED WITH POST CAPS

4" MIN.

2" MIN.

ROOT ZONE TO BE PROTECTED

NOTES:

- ALL TREE PROTECTION BARRICADES MUST HAVE TWO HORIZONTAL CROSS BARS.
- BARRICADES SHALL BE ERRECTED AT A MINIMUM DISTANCE FROM THE BASE OF PROTECTED TREES AND GRAND TREES ACCORDING TO THE FOLLOWING STANDARDS:
 - A. FOR PROTECTED TREES TWENTY-THREE INCHES (23"-17") D.B.H. PROTECTIVE BARRICADES SHALL BE PLACED A MINIMUM DISTANCE OF TEN FEET (10') FROM THE BASE OF EACH PROTECTED TREE. 10" D.B.H. AND LESS REQUIRE EIGHT FEET (8').
 - B. FOR PROTECTED TREES GREATER THAN TWENTY-THREE INCHES (23") D.B.H. AND GRAND TREES: PROTECTIVE BARRICADES SHALL PROVIDE A DIAMETER OF PROTECTION AROUND THE TREE EQUAL IN FEET TO THE DIAMETER BREST HEIGHT FO THE TREE (i.e., A 24" DIAMETER TREE WOULD REQUIRE A 24-FOOT DIAMETER PROTECTIVE BARRICADE).

SEE CITY OF CHARLESTON ZONING ORAINANCE SEC. 54-330 TREE PROTECTION FOR ADDITIONAL REQUIREMENTS.

South Carolina Department of Health and Environmental Control

TYPE A FILTER FABRIC INLET PROTECTION

STANDARD DRAWING NO. SC-07 PAGE 2 of 2

GENERAL NOTES

NOT TO SCALE

FEBRUARY 2014 DATE

CONSTRUCTION ENTRANCE DETAIL

6-INCH MIN.

24-FT. MIN.

UNDERLYING NON-WOVEN GEOTEXTILE FABRIC

EDGES SHALL BE TAPERED TOWARDS ROAD TO PREVENT TRACKING OF MUD ON THE EDGE.

PLAN SYMBOL

South Carolina Department of Health and Environmental Control

CONSTRUCTION ENTRANCE

STANDARD DRAWING NO. SC-06 PAGE 1 of 2

NOT TO SCALE

FEBRUARY 2014 DATE

DESCRIPTION	SIZE
ROCK PAD THICKNESS	6 INCHES
ROCK PAD WIDTH	24 FEET
ROCK PAD LENGTH	100 FEET
ROCK PAD STONE SIZE	D = 2-3 INCHES

CONSTRUCTION ENTRANCE DETAIL

6-INCH MIN.

24-FT. MIN.

UNDERLYING NON-WOVEN GEOTEXTILE FABRIC

EDGES SHALL BE TAPERED TOWARDS ROAD TO PREVENT TRACKING OF MUD ON THE EDGE.

PLAN SYMBOL

South Carolina Department of Health and Environmental Control

CONSTRUCTION ENTRANCE

STANDARD DRAWING NO. SC-06 PAGE 2 of 2

GENERAL NOTES

NOT TO SCALE

FEBRUARY 2014 DATE

CONSTRUCTION ENTRANCE DETAIL

6-INCH MIN.

24-FT. MIN.

UNDERLYING NON-WOVEN GEOTEXTILE FABRIC

EDGES SHALL BE TAPERED TOWARDS ROAD TO PREVENT TRACKING OF MUD ON THE EDGE.

PLAN SYMBOL

South Carolina Department of Health and Environmental Control

CONSTRUCTION ENTRANCE

STANDARD DRAWING NO. SC-06 PAGE 2 of 2

GENERAL NOTES

NOT TO SCALE

FEBRUARY 2014 DATE

INLET SILT PROTECTION (SILT SACK)

Optional Overflow

Insert 1" Rebar For Bag Removal from Inlet (Rebar Not Included)

Silt Sack

12.166

Dump Loops (Rebar Not Included)

SEE SITE

SEE SITE

Expansion Restraint

NOTE: ACF ENVIRONMENTAL SILT SACK (TYPE B). SEE WEBSITE WWW.ACFENVIRONMENTAL.COM FOR DETAILS AND SPECIFICATIONS. CONTRACTOR MAY SUBSTITUTE WITH ENGINEER APPROVED EQUAL.

INSPECT EVERY 14 CALENDAR DAYS AND WITHIN 24-HRS. AFTER EACH RAINFALL EVENT THAT PRODUCES 1/2" OR MORE OF PRECIPITATION. CHECK FOR SEDIMENT BUILDUP. IF THE FABRIC TEARS, BEGINS TO DECOMPOSE, OR IN ANY WAY BECOMES INEFFECTIVE, REPLACE THE SECTION IMMEDIATELY. REMOVE SEDIMENT ACCUMULATED IN THE SACK WHEN IT REACHES 1/3 THE HEIGHT OF THE SACK, ESPECIALLY IF HEAVY RAINS ARE EXPECTED. REMOVE TRAPPED SEDIMENT FROM THE SITE OR STABILIZE IT ON SITE. REMOVE WITHIN 30 DAYS AFTER FINAL STABILIZATION IS ACHIEVED OR AFTER BEST MANAGEMENT PRACTICES(BMP'S) ARE NO LONGER NEEDED.

South Carolina Department of Health and Environmental Control

CONSTRUCTION ENTRANCE

STANDARD DRAWING NO. SC-06 PAGE 2 of 2

GENERAL NOTES

NOT TO SCALE

FEBRUARY 2014 DATE

South Carolina Department of Health and Environmental Control

CONCRETE WASHOUT STRAW BALES OR ABOVE GROUND

STANDARD DRAWING NO. RC-07 PAGE 1 of 1

NOT TO SCALE

FEBRUARY 2014 DATE

South Carolina Department of Health and Environmental Control

TYPE A FILTER FABRIC INLET PROTECTION

STANDARD DRAWING NO. SC-07 PAGE 2 of 2

GENERAL NOTES

NOT TO SCALE

FEBRUARY 2014 DATE

South Carolina Department of Health and Environmental Control

CONSTRUCTION ENTRANCE

STANDARD DRAWING NO. SC-06 PAGE 2 of 2

GENERAL NOTES

NOT TO SCALE

FEBRUARY 2014 DATE

coast architects

671 St. Andrews Blvd. Charleston, SC 29407
Phone: 843.763.7064 Fax: 843.763.7061
www.coastarchitects.net

FORNSBERG ENGINEERING & SURVEYING, INC.

REGISTERED PROFESSIONAL ENGINEER
No. C00343

FORNSBERG ENGINEERING & SURVEYING, INC.

REGISTERED PROFESSIONAL ENGINEER
No. C00343

FORNSBERG ENGINEERING AND SURVEYING, INC.

1587 SAVANNAH HIGHWAY SUITE B
CHARLESTON, SC 29417
(843) 571-2622 FAX (843) 571-4780
CIVIL ENGINEERING, SURVEYING AND LAND PLANNING

05/03/2018

BOATING CENTER REDEVELOPMENT SWAIN BOATING CENTER H09-9617-PG-C

CITADEL

11 HAMMOND AVENUE CHARLESTON, SC

THE UNIVERSITY COLLEGE OF SCIENCE, CAROLINA

Revisions

Rev. No.	Rev. Date

DRAWN BY: MSJ
CHECKED BY: DCF
DATE: 06-01-2018

COAST PROJECT NO: 1722.00

SWPPP NOTES AND DETAILS

0.C500

JOB# 4727-1

Order Plans

Drop Inlet Silt Protection

WATERWAY

BID DOCUMENTS