


BUILDING SINGLE LINES (CHILLER PLANT REPLACEMENT OPTION)
SCALE: NONE

KEYED NOTES (THIS SHEET ONLY)

- ① 2 RUNS OF (3#500MCM, 1#4/0 N, 4°C) EACH
- ② 3#250MCM, 1#4G, 2 1/2°C
- ③ 4#2, 1#8G, 1 1/4°C
- ④ 3#10, 1#10G, 3/4°C
- ⑤ 4#6, 1°C
- ⑥ #2/0 GRD
- ⑦ 3#4/0, 1#4G, 2 1/2°C
- ⑧ 4#4/0, 1#4G, 2 1/2°C
- ⑨ 3#500MCM, 1#2G, 3°C
- ⑩ 2 RUNS OF (3#350MCM, 1#3/0 N, 3°C) EACH
- ⑪ 2 RUNS OF (4#350MCM, 3°C) EACH
- ⑫ #2/0 GRD
- ⑬ DRY TYPE TRANSFORMER, 15KVA, 480-208Y/120V, 3#, 4W
- ⑭ #8 GRD



RECORD DRAWING DATE	01/27/84
CODE I.D. NO.	80981
DRAWING SIZE:	0
SPEC. NO.	06-88-0938
CONSTR. CONTR. NO.	162407-88-C-0838
NAVFAC DRAWING NO.	5358014
SHEET 189 OF	194
E-604	

APPROVED	DATE	BY
DESIGNED BY	DATE	BY
CHECKED BY	DATE	BY
DRAWING REVISIONS	DESCRIPTION	DATE
1	AS-BUILT WITH NO CONNECTIONS	01/27/84

CHARLESTON AIR FORCE BASE CHARLESTON, SOUTH CAROLINA
DINING FACILITY
 BUILDING SINGLE-LINES (BID OPTION)
 APPROVED: [Signature] DATE: 01/27/84

Naval Facilities Engineering Command
 Southern Division
 Charleston, South Carolina

Order Plans @ WWW.LDLINE.COM