



**BUILDING SINGLE LINES (CHILLER PLANT REPLACEMENT OPTION)**

SCALE: NONE

**KEYED NOTES (THIS SHEET ONLY)**

- ① 2 RUNS OF (3#500MCM, 1#4/0 N, 4°C) EACH
- ② 3#250MCM, 1#4G, 2 1/2°C
- ③ 4#2, 1#8G, 1 1/4°C
- ④ 3#10, 1#10G, 3/4°C
- ⑤ 4#6, 1°C
- ⑥ #2/0 GRD
- ⑦ 3#4/0, 1#4G, 2 1/2°C
- ⑧ 4#4/0, 1#4G, 2 1/2°C
- ⑨ 3#500MCM, 1#2G, 3°C
- ⑩ 2 RUNS OF (3#350MCM, 1#3/0 N, 3°C) EACH
- ⑪ 2 RUNS OF (4#350MCM, 3°C) EACH
- ⑫ #2/0 GRD
- ⑬ DRY TYPE TRANSFORMER, 15KVA, 480-208Y/120V, 3Ø, 4W
- ⑭ #8 GRD



Naval Facilities Engineering Command  
Southern Division  
Charleston, South Carolina

CHARLESTON AIR FORCE BASE CHARLESTON, SOUTH CAROLINA  
**DINING FACILITY**  
BUILDING SINGLE-LINES (BID OPTION)

Rev.	Description	By	Date	Appr.
1	AS-BUILT WITH NO CONNECTIONS	ALLEN	5/14/2014	ALLEN

RECORD DRAWING DATE	01/27/14
CODE I.D. NO.	80931
DRAWING SIZE:	0
SPEC. NO. 06-88-0938	
CONSTR. CONTR. NO.	162407-88-C-0838
NAVFAC DRAWING NO.	5358014
SHEET 189 OF 194	

**E-604**

Order Plans @

WWW.LDLINE.COM