

PANEL HMP (3)		800 AMP MAINS		SURFACE <input checked="" type="checkbox"/>			
480Y/277 V, 3 PH, 4 W, 60 HZ		800 AMP MAIN BKR		TOTAL SPACES 42			
ALL BREAKERS SHALL HAVE A MINIMUM INTERRUPTING RATING OF 22,000 AMPS. PANEL SHALL BE PROVIDED WITH SEPARATE GROUND BUS.							
CKT No.	LOAD DESCRIPTION	BREAKERS POLE	AMP	KVA	BREAKERS AMP POLE	LOAD DESCRIPTION	CKT No.
1							2
3	PANEL HK1	3	400	209.1	28.7	225 3	PANEL HA
5							6
7							8
9	PANEL HK2	3	400	166.8	60.8	225 3	PANEL HB
11							10
13							12
15	SPACE	3			124 250 3	CH-1	14
17							16
19							18
21	SPACE	3				3	20
23							22
25	SPACE	3				3	24
27							26
29	SPACE	3				3	28
31							30
33	SPACE	3				3	32
35							34
37							36
39	SPACE	3				3	38
41							40
TOTAL CONNECTED LOAD 589.4 KVA							42

PANEL HA		225 AMP MAINS		SURFACE <input checked="" type="checkbox"/>			
480Y/277 V, 3 PH, 4 W, 60 HZ		MLO		TOTAL SPACES 42			
ALL BREAKERS SHALL HAVE A MINIMUM INTERRUPTING RATING OF 14,000 AMPS. PANEL SHALL BE PROVIDED WITH SEPARATE GROUND BUS.							
CKT No.	LOAD DESCRIPTION	BREAKERS POLE	AMP	KVA	BREAKERS AMP POLE	LOAD DESCRIPTION	CKT No.
1	LIGHTS	1	20	2.6		1	SPACE
3	LIGHTS	1	20	2.6		1	SPACE
5	LIGHTS	1	20	1.2		1	SPACE
7	LIGHTS	1	20	1.4		1	SPACE
9	LIGHTS	1	20	1.8		1	SPACE
11	LIGHTS	1	20	3.7		1	SPACE
13	LIGHTS	1	20	2.1		1	SPACE
15	LIGHTS	1	20	2.3		1	SPACE
17	LIGHTS	1	20	2.0		1	SPACE
19	SPACE	1	20			1	SPACE
21	LIGHTS(EXIT)	1	20	1		1	SPACE
23	LIGHTS(PARKING)	1	30	4.7		1	SPACE
25	LIGHTS(PARKING)	1	30	4.2		1	SPACE
27	SPACE	1				1	SPACE
29	SPACE	1				1	SPACE
31	SPACE	1				1	SPACE
33	SPACE	1				1	SPACE
35	SPACE	1				1	SPACE
37	SPACE	1				1	SPACE
39	SPACE	1				1	SPACE
41	SPACE	1				1	SPACE
TOTAL CONNECTED LOAD 28.7 KVA							42


PANEL HK1 (2)		400 AMP MAINS		FLUSH <input checked="" type="checkbox"/>			
480 V, 3 PH, 3 W, 60 HZ		MLO		TOTAL SPACES 42			
ALL BREAKERS SHALL HAVE A MINIMUM INTERRUPTING RATING OF 14,000 AMPS. PANEL SHALL BE PROVIDED WITH SEPARATE GROUND BUS.							
CKT No.	LOAD DESCRIPTION	BREAKERS POLE	AMP	KVA	BREAKERS AMP POLE	LOAD DESCRIPTION	CKT No.
1							2
3	E25	3	40	22	3.1 20 3	E135	4
5							6
7	E25	3	40	22	56 90 3	E136	8
9							10
11							12
13							14
15	E25	3	40	22	40 7 3	E135	16
17							18
19							20
21	E36b	3	40	2.1	10 3	E139	22
23							24
25	SF-2	2		6.1 9.0	20 3	E140	26
27							28
29	SF-4	2		2.8		3	30
31							32
33	SPACE	3				3	34
35							36
37							38
39	SPACE	3				3	40
41							42
TOTAL CONNECTED LOAD 209.1 KVA							42

PANEL HB (3)		225 AMP MAINS		SURFACE <input checked="" type="checkbox"/>			
480 V, 3 PH, 3 W, 60 HZ		MLO		TOTAL SPACES 42			
ALL BREAKERS SHALL HAVE A MINIMUM INTERRUPTING RATING OF 14,000 AMPS. PANEL SHALL BE PROVIDED WITH SEPARATE GROUND BUS.							
CKT No.	LOAD DESCRIPTION	BREAKERS POLE	AMP	KVA	BREAKERS AMP POLE	LOAD DESCRIPTION	CKT No.
1							2
3	P-1	3	20	6.1	20 3	AHU-1	4
5							6
7							8
9	P-2	3	30	6.1	20 3	AHU-2	10
11							12
13							14
15	P-3	3	20	1.2	6.1 20 3	AHU-3	16
17							18
19							20
21	P-4	3	20	3.9	6.1 20 3	AHU-4	22
23							24
25	SPACE	3			8.8 30 3	EF-1	26
27							28
29	SPACE	3				6.1 20 3	EF-3
31							34
33	SPACE	3					36
35							38
37	SPACE	3				1.5 20. 3	EF-9
39							40
41							42
TOTAL CONNECTED LOAD 60.8 KVA							42

PANEL HK2 (2)		400 AMP MAINS		FLUSH <input checked="" type="checkbox"/>			
480 V, 3 PH, 3 W, 60 HZ		MLO		TOTAL SPACES 42			
ALL BREAKERS SHALL HAVE A MINIMUM INTERRUPTING RATING OF 14,000 AMPS. PANEL SHALL BE PROVIDED WITH SEPARATE GROUND BUS.							
CKT No.	LOAD DESCRIPTION	BREAKERS POLE	AMP	KVA	BREAKERS AMP POLE	LOAD DESCRIPTION	CKT No.
1							2
3	E56	3	40	21.6	15 30 3	E32	4
5							6
7							8
9	E64	3	30	17	15 30 3	E32	10
11							12
13							14
15	E81	3	30	17	24 40 3	E36b	16
17							18
19							20
21	E81	3	30	17	12 20 3	E37	22
23							24
25	E83	3	30	16.2	12 20 3	E37	26
27							28
29	SPACE	3				3	30
31							32
33	SPACE	3				3	34
35							36
37							38
39	SPACE	3				3	40
41							42
TOTAL CONNECTED LOAD 166.8 KVA							42

KEYED NOTES (THIS SHEET ONLY)

- ① PROVIDE BREAKER WITH ELECTRIC SHUNT TRIP FEATURE. WIRE TO TRIP BREAKER ON SIGNAL FROM FIRE ALARM CONTROL PANEL.
- ② STUB EMPTY 2" CONDUIT INTO ACCESSIBLE CEILING SPACE.
- ③ IF THE CHILLER PLANT REPLACEMENT OPTION IS ACCEPTED, USE THE PANEL SCHEDULE ON SHEET E-609 IN LIEU OF THIS ONE.



RECORD DRAWING DATE	9/27/04
CODE I.D. NO.	80081
DRAWING SIZE	D
SPEC. NO.	06-88-0839
CONSTN. CONTR. NO.	N62467-98-C-0939
NAVFAC DRAWING NO.	5336017
SHEET 192 OF 194	

E-607

Order Plans @ WWW.LDLINE.COM