

Order Plans @

SANITARY RISER  
NTS

NOTE: GAS SERVICE SHALL DELIVER  
2800 CFH AT WATER COLUMN  
TO ALL DEVICES INSIDE BUILDING.

SEE CIVIL DWGS  
FOR CONTINUATION

RISER AND GAS METER  
PER DETAILS, SHEET P501

SEE DWG C-12  
FOR CONTINUATION

AUTO GAS SHUTOFF/  
EARTHQUAKE VALVE  
ON BLDG. EXTERIOR

APPROX. 24" A.F.F. IN WALL

CIVIL/MECHANICAL/PLUMBING 247 Aberdeen Street Charleston, S.C. 29403 (803) 737-6377		DATE 9/27/24
DRAWING REVISIONS Description: DWGS. CORRECTED TO AS-BUILT Prep By: Date: 9/27/24 Drawn By: JMM Checked By: JMM Submitted By: (Per User) JMM Technical Branch:		NO. 2188 ENGINEER SOUTH CAROLINA
CHARLESTON AIR FORCE BASE DINING FACILITY SANITARY & GAS RISERS APPROVED: [Signature] DATE: 9/27/24 EPIC FOR COMMANDER, USMC		RECORD DRAWING DATE 9/27/24 CODE: 100 - 80001 DRAWING SIZE: D SPEC. NO. D6-88-0838 CONSTR. CONTR. NO. N62467-98-C-0938 NAVFAC DRAWING NO. 5357957 SHEET 132 OF 194
Naval Facilities Engineering Command Southern Division Charleston, South Carolina		P-903

