



- NOTES:
1. COIL SHALL BE PIPED COUNTERFLOW.
 2. COIL SHALL BE FURNISHED WITH MANUAL AIR VENT
 3. PROVIDE ADDITIONAL UNIONS REQUIRED FOR COIL REMOVAL WHEN INSTALLED PIPING OR DUCTWORK IMPEDES COIL REMOVAL.

1 M501 AHU CHILLED AND HOT WATER COIL PIPING DETAIL
SCALE: NONE




- NOTES:
1. COIL SHALL BE PIPED COUNTERFLOW.
 2. COIL SHALL BE FURNISHED WITH MANUAL AIR VENT
 3. PROVIDE ADDITIONAL UNIONS REQUIRED FOR COIL REMOVAL WHEN INSTALLED PIPING OR DUCTWORK IMPEDES COIL REMOVAL.

2 M501 DUCT MOUNTED HEATING COIL PIPING DETAIL
SCALE: NONE




- NOTES:
1. COIL SHALL BE PIPED COUNTERFLOW.
 2. COIL SHALL BE FURNISHED WITH MANUAL AIR VENT
 3. PROVIDE ADDITIONAL UNIONS REQUIRED FOR COIL REMOVAL WHEN INSTALLED PIPING OR DUCTWORK IMPEDES COIL REMOVAL.

3 M501 UNIT HEATER DETAIL (HORIZONTAL THROW)
SCALE: NONE




ROUTE TO FLOOR DRAIN OR TIE INTO HVAC DRAIN

4 M501 MANUAL AIR VENT DETAIL
SCALE: NONE



5 M501 AHU CONDENSATE DRAIN LINE WITH P-TRAP DETAIL
SCALE: NONE



NOTE: PROVIDE 10 GALLON CHEMICAL FEED TANK IF CPRO IS ACCEPTED.

6 M501 CHILLED AND HOT WATER CHEMICAL FEEDER DETAIL
SCALE: NONE

Order Plans

WWW.LDIDLINE.COM



| | | | |
|---------------------|-------------------------------|------------|----------------------------|
| APPROVED | DATE | BY | CHARLESTON, SOUTH CAROLINA |
| REVISIONS | DESCRIPTION | DATE | BY |
| 1 | AS-BUILT DRWG. NO CONNECTIONS | 12/19/2014 | RD |
| DRAWING REVISIONS | | | |
| Prep By | Date | App'd | DATE |
| RD | 12/19/2014 | RD | 12/19/2014 |
| DRAWING NO. 5357974 | | | |
| SHEET 149 OF 194 | | | |
| M-501 | | | |