

This document contains confidential information, is the property of TriMark, and shall not be used on other projects or for the extension of this project without TriMark's written approval.

Owner and all Contractors to check and verify existing dimensions and conditions in the field before starting construction and to notify TriMark of any material or detail changes.

ISSUANCE

DATE	NO.	DESCRIPTION
XX/XX/XXXX	-	-

Charleston AFB, SC
Project Address

DFAC - F.T.I. Project

PROJECT NUMBER: Project Number	
DATE: 19th April, 2018	
SCALE: No Scale	
DRAWN BY: ADK	APPROVED BY: RIM

SHEET TITLE:
FOODSERVICE EQUIPMENT MEP SCHEDULE

SHEET NUMBER:
FS-2.1

FIXTURE AND EQUIPMENT SCHEDULE AND MECHANICAL REQUIREMENTS

ITEM	DESCRIPTION	MAKE	MODEL	QTY.	VOLTS	HP	KW	AMPS.	PHASE	CONVENIENCE	DIRECT	REMARKS	HOT (IN)	COLD (IN)	DIRECT WASTE (IN)	FLOOR SINK (IN)	GAS (IN)	MBTUH	REMARKS			
123	MOBILE SLICER TABLE	CUSTOM	ST. STEEL	1																		
124	WORK TABLE	CUSTOM	ST. STEEL	1	120			15.0	1	X		2 EA. UTILITY OUTLETS										
125	MOBILE TRASH RECEPTACLE	N.I.C.	OWNER	3																		
126	SPARE NUMBER			-																		
127	WORK TABLE W/ SINK	CUSTOM	ST. STEEL	2	120			16.0	1	X		2 EA. UTILITY OUTLETS					FS			INDIRECT WASTE		
128	PREP. SINK FAUCET	T & S BRASS	B-0221	2									1/2	1/2								
129	UTENSIL RACK W/ OVERSHELF	CUSTOM	ST. STEEL	1																		
130	SPARE NUMBER			-																		
131	HAND SINK W/ SBT	ADVANCE T/BCO	F-PS-85	1									1/2	1/2	1-1/2							
132	DOUBLE STACK STEAMER	GROEN	HY-6E	1	208			50.0	3	X			(2) 3/4				FS				INDIRECT WASTE	
133	TILTING KETTLE	VULCAN	K40ELT	1	208			50.0	3	X			1/2	1/2								
134	DOUBLE STACK COMBI-OVEN	RATIONAL	SCC 62 E/SCC 62 E	2	208			70.0	3	X			(4) 3/4				FS				INDIRECT WASTE	
135	EXHAUST HOOD	EXISTING	REMAIN IN PLACE	1				208														
136	EXHAUST HOOD	EXISTING	REMAIN IN PLACE	1																		
137	TILTING SKILLET	VULCAN	VE40	1	480			20.0	3				1/2	1/2								
138	KETTLE STAND	VULCAN	VEKTS066	1	208			22.0	3	X			1/2	1/2								
139	FRY DUMP W/ HEAT LAMP	VULCAN	VX15	1	120			15.0	1	X											NEMA 5-15P	
140	SPARE NUMBER			-																		
141	FRYER W/ FILTER	VULCAN	2ER50AF	1	208		17.0	47.0	3	X												NEMA 5-15P
142	SPARE NUMBER			-																		
143	WORKTOP FREEZER	RANDELL	921SF-32-7	1	120			9.0	1	X												NEMA 5-15P
144	(6) HOT PLATE RANGE	VULCAN	EV36-S-6FP-480	1	480		1.7	23.5	3	X												
145	EXHAUST HOOD	EXISTING	REMAIN IN PLACE	1																		
146	EXHAUST HOOD	EXISTING	REMAIN IN PLACE	1																		
147	DOUBLE CONVECTION OVEN	VULCAN	SG44C	2	120	1/2		18.0	1	X							3/4	120				W/ QUICK DISCONNECT GAS HOSE AND RESTRAINT CABLES
148	PLATE DISPENSER	LAKESIDE	S209	4																		
149	TRAY PICK-UP COUNTER	CUSTOM	ST. STEEL	1																		
150	CONDIMENT / BNB CABINET	CUSTOM	MILLWORK	2	120			15.0	1	X		VERIFY REQUIREMENTS W/ SUPPLIER 20 AMP. CIRCUIT		1/2			FS					INDIRECT WASTE

ABBREVIATIONS

AFF ABOVE FINISH FLOOR
AMPS AMPERES
ARCH ARCHITECT
DR DOOR
BTU BRITISH THERMAL UNITS
CFM CUBIC FEET PER MINUTE
CEM CENTERLINE
CLG CEILING
CLR CLEAR
CO COIL
CON CONCRETE
CONC CONCRETE
C/W COLD WATER
DEL DOUBLE
DET DETAIL
DIA DIAMETER

DIM DIMENSION
DN DOWN
DR DOOR
DWG DRAWING
EA EACH
EC ELECTRICAL CONTRACTOR
ELEV ELEVATION
EQ EQUAL
EQP EQUIPMENT
EX EXISTING
EXH EXHAUST
FAB FABRICATION
FD FLOOR DRAIN
FIN FINISH
FF FINISH FLOOR
FLEX FLEXIBLE

FLR FLOOR
FPM FEET PER MINUTE
FRP FIBER REINFORCED PANEL
FS FLOOR SINK
FSEC FOODSERVICE EQUIPMENT CONTRACTOR
GALV GALVANIZED
GC GENERAL CONTRACTOR
GPM GALLONS PER MINUTE
GYP BD GYPSUM BOARD
HORIZ HORIZONTAL
HP HORSEPOWER
HT HEIGHT
HVAC HEATING, VENTILATION & AIR CONDITIONING CONTRACTOR

HW HOT WATER
ID INSIDE DIAMETER
INSUL INSULATION
IW J-BOX
J-BOX JUNCTION BOX
KW KILOWATT
LP LAMINATE PLASTIC
MAT'L MATERIAL
MAX MAXIMUM
MECH MECHANICAL
MFR MANUFACTURER
MIN MINIMUM
MUA MAKE-UP AIR
MTD MOUNTED
NIC NOT IN CONTRACT
NO NUMBER

NSF NATIONAL SANITATION FOUNDATION
NTS NOT TO SCALE
OC ON CENTER
OD OUTSIDE DIAMETER
PC PLUMBING CONTRACTOR
PH PHASE
PSI POUNDS PER SQUARE INCH
QTY QUANTITY
R RADIUS
REQ'D REQUIRED
REV REVISION
RM ROOM
SF SQUARE FEET
SIM SIMILAR
SHT SHEET
SP STATIC PRESSURE

SPEC SPECIFICATIONS
SQ SQUARE
SQ FT SQUARE FEET
SS STAINLESS STEEL
STD STANDARD
SW SWITCH
TEMP TEMPERATURE
TYP TYPICAL
V VOLTS
W WATTS
WD WOOD
WGT WEIGHT

Order Plans @ www.LDILine.com