

MARK	FIXTURE NAME	DESCRIPTION	CONNECTIONS			REMARKS
			WASTE	CW	HW	
P-1	WATER CLOSET	WHITE VITREOUS CHINA, 1.6 GALLONS PER FLUSH, WALL MOUNTED, MOUNTED AT 15" STANDARD HEIGHT, HEAVY MOLDED PLASTIC, WHITE, ELONGATED, OPEN FRONT SEAT LESS COVER, WITH STAINLESS STEEL, SELF SUSTAINING CHECK HINGES, FLUSH VALVE TO BE OWNER PROVIDED, CONTRACTOR INSTALLED, PROVIDE WITH CARRIER.	3	1 1/2"	-	1,2,6
P-1A	WATER CLOSET (ADA)	WHITE VITREOUS CHINA, 1.6 GALLONS PER FLUSH, WALL MOUNTED, MOUNTED AT 17" ADA HEIGHT, HEAVY MOLDED PLASTIC, WHITE, ELONGATED, OPEN FRONT SEAT LESS COVER, WITH STAINLESS STEEL, SELF SUSTAINING CHECK HINGES, FLUSH VALVE TO BE OWNER PROVIDED, CONTRACTOR INSTALLED, PROVIDE WITH CARRIER.	3	1 1/2"	-	1,2,3,6
P-1B	WATER CLOSET	WHITE VITREOUS CHINA, FLOOR MOUNTED, ELONGATED, TANK TYPE, 15" RIM HEIGHT, CLOSED FRONT TOILET SEAT WITH COVER AND STAINLESS STEEL CHECK HINGE, 1.28 GPF.	3	1	-	1,2,6
P-1C	WATER CLOSET (ADA)	WHITE VITREOUS CHINA, FLOOR MOUNTED, ELONGATED, TANK TYPE, ADA RIM HEIGHT, CLOSED FRONT TOILET SEAT WITH COVER AND STAINLESS STEEL CHECK HINGE, 1.28 GPF.	3	1	-	1,2,3,6
P-2	URINAL (ADA)	WHITE VITREOUS CHINA, 0.125 GALLONS PER FLUSH, WALL MOUNTED, FLUSH VALVE TO BE OWNER PROVIDED, CONTRACTOR INSTALLED, REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR MOUNTING HEIGHT.	2	3/4"	-	1,2,3,6
P-3	LAVATORY	20"x18" WALL HUNG, 4" CENTER FAUCET HOLES, VITREOUS CHINA, REAR OVERFLOW, PROVIDE WITH CONCEALED ARM CARRIER, PROVIDE WITH ADA TRAP, STOP, AND SUPPLY PROTECTORS, PROVIDE WITH GRID STRAINER, PROVIDE WITH POLISHED CHROME PLATED SINGLE LAVATORY, LEVER HANDLE FAUCET, 0.5 GPM VANDAL RESISTANT AERATOR, COMPLY WITH ASSE 1070, CSA CERTIFIED, REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR MOUNTING HEIGHT.	1 1/2	1/2	1/2	1,2,3,4,6
P-4	LAB SINK (SINGLE)	31"x22" SINGLE BOWL, 6.5" BOWL DEPTH, 16 GAUGE, SELF RIMMING COMPARTMENT, (18-8) NICKEL BEARING STAINLESS STEEL, WITH SATIN FINISH AND SOUND DEADENING MATERIAL ON SIDES AND BOTTOM OF SINK. PROVIDE TOP MOUNT, 5/38" CENTERLINE GOOSENECK, WRIST BLADE LEVER FAUCET, 4" CENTERS, PROVIDE STRAINER WITH REMOVABLE CRUMB CUP AND STOPPER, 1-1/2 TAILPIECE, CHROME PLATED 17 GAUGE CAST BRASS P-TRAP WITH CLEANOUT AND TUBE WASTE TO WALL. CHROME PLATED LOOSE KEY ANGLE STOP TO WALL, WITH 3/8" CHROME PLATED FLEXIBLE HOT AND COLD WATER SUPPLIES. SINK DRILLINGS SHALL ACCOMMODATE FITTING INSTALLATION, ONLY, NO OTHER CAPPED OPENINGS SHALL BE ALLOWED. PROVIDE 0.5 GPM AERATOR.	1 1/2	1/2	1/2	1,2,4,6
P-4B	LAB SINK (SINGLE)	31"x22" SINGLE BOWL, 12" BOWL DEPTH, 16 GAUGE, SELF RIMMING COMPARTMENT, (18-8) NICKEL BEARING STAINLESS STEEL, WITH SATIN FINISH AND SOUND DEADENING MATERIAL ON SIDES AND BOTTOM OF SINK. PROVIDE TOP MOUNT, 5/38" CENTERLINE GOOSENECK, WRIST BLADE LEVER FAUCET, 4" CENTERS, PROVIDE STRAINER WITH REMOVABLE CRUMB CUP AND STOPPER, 1-1/2 TAILPIECE, CHROME PLATED 17 GAUGE CAST BRASS P-TRAP WITH CLEANOUT AND TUBE WASTE TO WALL. CHROME PLATED LOOSE KEY ANGLE STOP TO WALL, WITH 3/8" CHROME PLATED FLEXIBLE HOT AND COLD WATER SUPPLIES. SINK DRILLINGS SHALL ACCOMMODATE FITTING INSTALLATION, ONLY, NO OTHER CAPPED OPENINGS SHALL BE ALLOWED. PROVIDE 0.5 GPM AERATOR.	1 1/2	1/2	1/2	1,2,4,6
P-5	BREAK RM SINK	17"x16" SINGLE BOWL COUNTERMOUNT SINK, 7" BOWL DEPTH, 18 GA. TYPE 304 STAINLESS STEEL, BAK LEDGE, PROVIDE WITH SOUND DEADENING MATERIAL ON SIDES AND BOTTOM OF SINK. PROVIDE TOP MOUNT, 5/38" CENTERLINE GOOSENECK, WRIST BLADE LEVER FAUCET, 4" CENTERS, PROVIDE STRAINER WITH REMOVABLE CRUMB CUP AND STOPPER, 1-1/2 TAILPIECE, CHROME PLATED 17 GAUGE CAST BRASS P-TRAP WITH CLEANOUT AND TUBE WASTE TO WALL. CHROME PLATED LOOSE KEY ANGLE STOP TO WALL, WITH 3/8" CHROME PLATED FLEXIBLE HOT AND COLD WATER SUPPLIES. SINK DRILLINGS SHALL ACCOMMODATE FITTING INSTALLATION, ONLY, NO OTHER CAPPED OPENINGS SHALL BE ALLOWED. PROVIDE 0.5 GPM AERATOR.	1 1/2	1/2	1/2	1,2,4,6
P-6	ICE MAKER BOX	RECESSED METAL WALL BOX CONSTRUCTED AND SUITABLE FOR FIRE RATED PARTITIONS, COMPLETE WITH FACTORY INSTALLED SHANK VALVE WITH 0" OF 1/4" O.D. SOFT COPPER TUBING WITH COMPRESSION FITTING IN TIGHT COIL, 1/4" O.D. COPPER OUTLET TESTED @ 100 P.S.I. PROVIDE APPROXIMATELY 5" ANCHOR BOX TO WALL STRUCTURE. VERIFY LOCATION AND MOUNTING HEIGHT WITH ARCHITECTURAL DRAWINGS OR MOUNT TO MANUFACTURER'S RECOMMENDATIONS.	-	1/2	-	1,6
P-7	MOP SINK	36"x36"x12" CORNER MODEL, PRECAST TERRAZZO MADE OF BLACK AND WHITE MARBLE CHIPS, S.S. STRAINER, S.S. BUMPER GUARD ON ALL CURBS. FAUCET SHALL BE CHROME PLATED, COMPLETE WITH VACUUM BREAKER, INTEGRAL STOPS, ADJUSTABLE WALL BRACE, PAIL HOOK, FOUR ARM HANDLES, HOSE THREADED SPOUT.	3	1/2	1/2	1,2,4,6
P-8	WATER COOLER	WATER FOUNTAINS WITH INTEGRAL BOTTLE FILLING STATION SHALL DELIVER 8 GPH OF 50°F DRINKING WATER AT 90°F AMBIENT AND 80°F INLET WATER. UNITS SHALL BE STAINLESS STEEL CONSTRUCTION WITH PLASTIC ABS ALCOVE. SENSOR-ACTIVATION WITH AN AUTO 20-SECOND SHUT-OFF TIMER. BOTTLE FILLER SHALL PROVIDE 1.1 GPM FLOW RATE WITH LAMINAR FLOW TO MINIMIZE SPLASHING. SHALL INCLUDE INTEGRATED SILVER ION ANTI-MICROBIAL PROTECTION IN KEY AREAS. UNIT SHALL MEET ADA GUIDELINES. UNIT SHALL BE LEAD-FREE DESIGN WHICH IS CERTIFIED TO NSF/ANSI 61 AND 372 AND MEETS FEDERAL AND STATE LOW-LEAD REQUIREMENTS. UNIT SHALL BE CERTIFIED TO UL399 AND CAN/CSA 22.2 NO. 120/V60 H21 PH. 5.0 FLA. SEE ARCHITECTURAL FOR MOUNTING ELEVATION. BASIS OF DESIGN IS ELKAY LZSTL8WSP.	1 1/4	3/4"	-	1,2,3,4,5,6
P-9	SHOWER	SHOWER WALLS AND FLOORING BY ARCHITECTURAL. PROVIDE 1.5 GPM HAND HELD SHOWER HEAD, 25" SLIDE BAR WITH ADJUSTABLE HEAD HOLDER, PRESSURE BALANCING VALVE CARTRIDGE, HOT LIMIT SAFETY STOP, INTEGRAL GUARD AND MOUNTING PLATE. PROVIDE WITH 2" SHOWER DRAIN.	2	1/2	1/2	1,2,4,6
P-10	WASHER BOX	WASHING MACHINE OUTLET BOX, STEEL FACEPLATE WITH WHITE POWDER COAT FINISH. QUARTER TURN BALL VALVE, COPPER SWEAT CONNECTIONS. 2" DRAIN PIECE.	2	1/2	1/2	1,2,4,6
P-11	LAVATORY	16"x13" UNDERCOUNTER MOUNT LAVATORY, 5-1/2" BOWL DEPTH, VITREOUS CHINA, FRONT OVERFLOW, PROVIDE WITH GRID STRAINER, PROVIDE WITH TRAP, STOP, AN SUPPLY PROTECTORS WHERE NECESSARY. PROVIDE WITH POLISHED CHROME PLATED SINGLE LAVATORY, LEVER HANDLE FAUCET, 0.5 GPM VANDAL RESISTANT AERATOR, COMPLY WITH ASSE 1070, CSA CERTIFIED.	1 1/2	1/2	1/2	1,2,3,4,6
P-12	PATIENT ROOM SINK	17"x16" SINGLE BOWL COUNTERMOUNT SINK, 7" BOWL DEPTH, 18 GA. TYPE 304 STAINLESS STEEL, BAK LEDGE, PROVIDE WITH SOUND DEADENING MATERIAL ON SIDES AND BOTTOM OF SINK. PROVIDE TOP MOUNT, 5/38" CENTERLINE GOOSENECK, WRIST BLADE LEVER FAUCET, 4" CENTERS, PROVIDE STRAINER WITH REMOVABLE CRUMB CUP AND STOPPER, 1-1/2 TAILPIECE, CHROME PLATED 17 GAUGE CAST BRASS P-TRAP WITH CLEANOUT AND TUBE WASTE TO WALL. CHROME PLATED LOOSE KEY ANGLE STOP TO WALL, WITH 3/8" CHROME PLATED FLEXIBLE HOT AND COLD WATER SUPPLIES. SINK DRILLINGS SHALL ACCOMMODATE FITTING INSTALLATION, ONLY, NO OTHER CAPPED OPENINGS SHALL BE ALLOWED. PROVIDE 0.5 GPM AERATOR.	1 1/2	1/2	1/2	1,2,4,6
P-13	LAUNDRY SINK	39"x27" 12" DEEP TUB, SINGLE BASIN UTILITY SINK, STAINLESS STEEL, 14 GAUGE TYPE 304 SUPPORTED ON TUBULAR LEGS. PROVIDE BACK MOUNT FAUCET, CHROME PLATED, COMPLETE WITH VACUUM BREAKER, INTEGRAL STOPS, ADJUSTABLE WALL BRACE, PAIL HOOK, FOUR ARM HANDLES, HOSE THREADED SPOUT. PROVIDE 1-1/2 TAILPIECE, 17 GAUGE CAST BRASS P-TRAP WITH CLEANOUT AND TUBE WASTE TO WALL. CHROME PLATED LOOSE KEY ANGLE STOP TO WALL, WITH 3/8" FLEXIBLE HOT AND COLD WATER SUPPLIES. SINK DRILLINGS SHALL ACCOMMODATE FITTING INSTALLATION, ONLY, NO OTHER CAPPED OPENINGS SHALL BE ALLOWED.	1 1/2	1/2	1/2	1,2,3,4,6
P-14	EYEFACE WASH	COMBINATION EYEFACE WASH SPRAYHEAD DECK MOUNTED ASSEMBLY UNITS SHALL BE TWIN PERFORATED DISC EYEFACE WASH HEADS WITH PROTECTIVE SPRAYHEAD COVERS. THE INTEGRAL FLOW CONTROL SHALL BE WITH CERAMIC VALVE, 1/2" NPT STAY OPEN VALVE. PROVIDE CERAMIC DISCS WITH 20 DEGREE ACTIVATION AND DEACTIVATION ANGLE. THE PIPE AND FITTINGS SHALL BE CHROME PLATED BRASS WITH A 1/2" NPT WATER SUPPLY.	-	1/2	1/2	-
P-15	EYE WASH	EYE WASH SPRAYHEAD, FAUCET MOUNTED ASSEMBLY, SHALL BE CHROME PLATED BRASS SPRAYHEAD WITH TWIN SOFT-FLOW EYEWASH HEADS AND HIGH VISIBLE RED SOFT-FLOW PLASTIC PROTECTIVE COVERS. THE INTEGRAL FLOW CONTROL PROVIDES SAFE 30-90 PSI WATER SUPPLY. PIPE AND FITTINGS SHALL BE CHROME PLATED BRASS WITH A 1/2" NPT WATER SUPPLY. INSTALL PER MANUFACTURER'S RECOMMENDATIONS.	-	1/2	1/2	-
FD	FLOOR DRAIN	DEEP SEAL, TRAP PRIMER (CONNECT TO NEAREST CW SUPPLY WITH BALL VALVE SHUT-OFF). PROVIDE INSIDE CAULK BOTTOM OUTLET OR TRAP SEAL HUB OUTLET WITH ADAPTOR. SET IRON TRAP INSTALLATION. PROVIDE CLAMPING RINGS FOR FLOORS WITH MEMBRANE. PROVIDE WITH ALL TRAPS, FITTINGS AND APPURTENANCES REQUIRED FOR A COMPLETE INSTALLATION. DEMO FLOOR AND SWEEP IN 18" RADIUS AROUND DRAIN. SET DRAIN 1/4" BELOW FINISH FLOOR AT TOP OF FLOOR DRAIN. SET FLOOR DRAIN FLUSH WITH FINISH FLOOR, NOT CONCRETE.	3	1/2	-	6
RD	ROOF DRAIN	12 DIAMETER ROOF DRAIN. DURA-COATED CAST IRON BODY WITH COMBINATION MEMBRANE FLASHING CLAMP/GRAVEL GUARD AND LOW PROFILE WHITE POLY DOME.	4	-	-	6
SD	SECONDARY DRAIN	12 DIAMETER ROOF DRAIN. DURA-COATED CAST IRON BODY WITH COMBINATION MEMBRANE FLASHING CLAMP/GRAVEL GUARD AND LOW PROFILE WHITE POLY DOME. PROVIDE WITH 2" HIGH EXTERNAL WATER DAM.	4	-	-	6
CO	FLOOR CLEANOUT	EPOXY COATED CAST IRON FLOOR CLEANOUT WITH 5-1/8" ROUND ADJUSTABLE NICKEL BRONZE TOP, AND NO HUB CONNECTION. PROVIDE WITH ALL TRAPS, FITTINGS AND APPURTENANCES REQUIRED FOR A COMPLETE INSTALLATION. SET CAP FLUSH WITH FINISH FLOOR, NOT CONCRETE. FOR CARPET INSTALLATION, PROVIDE CLEANOUT WITH STAINLESS STEEL BARN DOOR MARKER.	VARIES	-	-	-
WH	WALL HYDRANT	AUTOMATIC DRAINING, FREEZELESS, WITH HOSE CONNECTION, ANTI SIPHON VACUUM BREAKER, FLUSH MOUNTED BOX AND LEVER, LOCKS NOT OPERATED, CHROME FINISH.	-	3/4"	-	1,6
HB	HOSE BIBB	ANTI SIPHON, VACUUM BREAKER, CHROME FINISH.	-	3/4"	-	1,6
HD	HUB DRAIN	ABOVE CEILING CAST IRON BODY HUB DRAIN (HD) WITH BOTTOM OUTLET AND WATERLESS TRAP GUARD. SIZE AS INDICATED. BASIS OF DESIGN IS LEONARD TM-26-LF OR EQUAL.	2	-	-	6
MV	MIXING VALVE	THERMOSTATIC MIXING VALVE, EXPOSED WALL MOUNT, REGULATOR KNOB, 1 GPM MINIMUM FLOW, PROVIDE WITH INLET THERMOMETER, BALL VALVE WITH DIAL THERMOMETER. BASIS OF DESIGN LEONARD TM-26-LF OR EQUAL.	-	3/4"	3/4"	1,4,5,6
BFP	BACKFLOW PREVENTER	DOUBLE CHECK VALVE ASSEMBLY, ABLE TO BE INSTALLED IN VERTICAL POSITION, HEAD FREE, LISTED, UNCLASSIFIED, AWWA COMPLIANT, 175 PSI MAX. WORKING PRESSURE. COORDINATE FLANGE OR GROOVED ENDS WITH PIPING. PROVIDE WITH STRAINER.	-	3	-	1,6
SP	SUMP PUMP	SUBMERSIBLE ELEVATOR SUMP PUMP SIMILAR TO HELLER MODEL 153 @ 200 GPM @ 20' LIFT HEAD, 1/2 HP, 115/160, CAST IRON CONSTRUCTION WITH POWDER COATED FINISH AND STAINLESS STEEL FITTINGS. PROVIDE WITH HIGH WATER AND OIL SENSING ALARMS, ALARM PANEL, AUDIO AND LED ALARMS WITH CONTACTS, AND PLUG IN POWER CORD. COORDINATE POWER REQUIREMENTS WITH ELECTRICAL. ROUTE TO POINT INDICATED ON PLANS.	-	3/4"	3/4"	5


- NOTES:
- WATER SUPPLY TAPPING TO EACH FIXTURE SHALL BE FULL SIZE.
  - PROVIDE WATER HAMMER ARRESTORS ON HOT & COLD WATER SUPPLY BRANCHES. SEE WATER HAMMER ARRESTOR SCHEDULE.
  - MOUNT PLUMBING FIXTURES LABELED "ADA" IN ACCORDANCE WITH ADA REQUIREMENTS. COORDINATE WITH ARCHITECTURAL DRAWINGS.
  - PROVIDE HOT WATER TO FIXTURES WHERE INDICATED.
  - COORDINATE POWER REQUIREMENTS WITH ELECTRICAL.
  - PROVIDE WITH ALL FITTINGS AND APPURTENANCES REQUIRED FOR A COMPLETE INSTALLATION.

MARK	SERV. SIZE	TYPE	PERFORMANCE DATA				ELECTRICAL DATA			
			CAPACITY - GPM	PUMP HEAD (FT. W.C.)	OPERATING PRESSURE	MAX. SPEED (RPM)	MIN. HP	VOLTS	PHASE	Hz
CP-1	1 1/2"	IL	10.0	25.0	125 PSI	3,250	1/6	120	1	60

- NOTES:
- BRASS BRONZE CONSTRUCTION.
  - COORDINATE POWER REQUIREMENTS WITH ELECTRICAL.
  - PROVIDE SELF LUBRICATING PUMP WITH REPLACEABLE CARTRIDGE.
  - PUMP SHALL HAVE MAX. WORKING PRESSURE OF 200 PSI.
  - BASIS OF DESIGN IS TACO.
  - PROVIDE WITH AQUASTAT AND AUTOMATIC TIMER KIT.

CAPACITY (GALLON)	WATER HEATER RATINGS				RECOVERY @ 100 DEG F RISE	FUEL TYPE	COMBUSTION CONTROL	ELECTRICAL DATA		
	MIN. GAS CONSUMPTION INPUT (MBH)	MIN. GAS CONSUMPTION OUTPUT (MBH)	EFFICIENCY	EFFICIENCY				VOLTS	PHASE	Hz
GWH-1	120	300.0	285.0	95%	349	NATURAL GAS	MODULATING	120	1	60

- NOTES:
- PROVIDE GAS FRIED WATER HEATER WITH MODULATING CAPABILITY.
  - COORDINATE POWER REQUIREMENTS WITH ELECTRICAL.
  - PROVIDE WATER HEATER WITH CONDENSATE NEUTRALIZATION KIT AND ROUTE CONDENSATE TO FLOOR DRAIN.
  - INSTALL UNIT AND ITS ACCESSORIES AS PER MFG RECOMMENDATIONS.
  - PROVIDE 4" PVC CONCENTRIC VENT KIT AND STAINLESS STEEL OUTSIDE TERMINATION KIT.
  - BASIS OF DESIGN IS AO SMITH.
  - WATER HEATER SHALL HAVE SEAMLESS ASME TANK CONSTRUCTION, GLASS LINED WATER SIDE SURFACES. 160 PSI WORKING PRESSURE.
  - WATER HEATER SHALL MEET THE THERMAL EFFICIENCY AND/OR STANDBY LOSS REQUIREMENTS OF THE U.S. DEPARTMENT OF ENERGY AND CURRENT EDITION OF ASHRAE/IESNA 90.1.
  - WATER HEATER SHALL BE CERTIFIED BY UNDERWRITERS LABORATORIES (UL), INC. ACCORDING TO ANSI Z21.10.3 - CSA 4.3 STANDARDS.
  - PROVIDE WITH CSA CERTIFIED AND ASME RATED T&P RELIEF VALVES. PROVIDE WITH ASME CSD-1 GAS TRAIN.
  - UPON COMPLETION OF GAS WATER HEATER INSTALLATION, THE CONTRACTOR SHALL ARRANGE FOR THE STATE OF ALABAMA BOILER AND PRESSURE VESSEL SAFETY DIVISION INSPECTOR TO VISIT THE JOB SITE AND INSPECT THE INSTALLATION. THE CONTRACTOR SHALL FURNISH A WRITTEN REPORT TO THE STATE.



AIR COMPRESSOR SCHEDULE						
MARK	TYPE	OPERATING PRESSURE (PSIG)	RECEIVER CAPACITY (GALLONS)	MOTOR HP (MIN)	FREE AIR (SCFM)	ELECTRICAL REQUIREMENTS
AC-1	ROTARY SCREW	125	120	10	25	460/3/60

- NOTES:
- BASIS OF DESIGN IS QUINCY QGS 10.
  - PROVIDE COALESCING FILTER AT 30 SCFM AT 100 PSIG.
  - PROVIDE WITH TANK MOUNTED REFRIGERATED DRYER RATED FOR 30 SCFM AT PSIG FULL LOAD DISCHARGE PRESSURE.
  - PROVIDE HORIZONTAL TANK MOUNTED AIR COMPRESSOR. PROVIDE TANK WITH 150 PSIG WORKING PRESSURE.
  - PROVIDE PARTICULATE FILTER RATED AT 30 SCFM AT 150 PSIG.

VACUUM PUMP SCHEDULE						
MARK	TYPE	OPERATING PRESSURE (PSIG)	RECEIVER CAPACITY (GALLONS)	MOTOR HP (MIN)	FREE AIR (SCFM)	ELECTRICAL REQUIREMENTS
VP	ROTARY	125	120	(QTY. 2) 10 HP EACH	110	460/3/60

- NOTES:
- BASIS OF DESIGN IS QUINCY QVIS-10D.
  - PROVIDE DUPLEX VACUUM PUMP FACTORY MOUNTED ON HORIZONTAL RECEIVER TANK.
  - PROVIDE WITH INLET SCREEN/FILTER, DIRECT DRIVE MOTOR, FLUID LEVEL SIGHT GLASS.

WATER HAMMER ARRESTOR SCHEDULE			
P.D.I. SIZE	FIXTURE UNITS	SIZE	TYPE/MODEL NUMBER (WROUGHT COPPER SHELL)
WHA-A	1-11	1/2"	75001-S
WHA-B	12-32	3/4"	75002-S
WHA-C	33-60	1"	75003-S

- NOTES:
- REPRESENTS ARRESTOR TYPE AND ASSOCIATED MODEL NUMBER DERIVED FROM JOSAM CO. (SHOCK ABSORBERS, WROUGHT COPPER SHELL) AND IS USED AS A STANDARD FOR HELPING DETERMINE PROPER SELECTION FROM OTHER MANUFACTURERS EQUALLY COMPETENT IN THE FABRICATION OF AND USING THE SIZING METHOD ESTABLISHED IN ACCORDANCE WITH PLUMBING DRAINAGE INSTITUTE (PDI) STANDARD PDI - WH201.

ISSUE DATE	ISSUE FOR BID
2019.05.25	2019.05.25

SIMULATION LABORATORY  
 BUILDING - USA JOB #16-07  
 MOBILE, ALABAMA  
 ABC #2017372  
 GMC # AMOB160019



PLUMBING SCHEDULES  
 P0.02  
 sheet of