

**GENERAL NOTES**

1. PROVIDE ACCESS PANELS IN GYP. CIELINGS IN ORDER TO PROVIDE ACCESS TO ALL SHUTOFF VALVES. COORDINATE WITH ARCHITECT.
2. ALL CW, HW, AND HWR PIPES PENETRATING THE STORM SHELTER WALL SHALL BE OFFSET AND PROVIDED WITH METAL SHIELD TO PROTECT OPENING DURING A STORM EVENT. REFER TO DETAIL 7 ON SHEET P5.02
3. ALL COMPRESSED AIR AND VACUUM PIPING PENETRATING THE STORM SHELTER WALLS ARE 2"Ø OR SMALLER AND THUS ARE NOT REQUIRED TO BE PROTECTED PER ICC 500-2014 SECTION 306.3.

**SHEET NOTES**

- ① LOOP 3/4" CW AND HW PIPING BELOW SLAB TO SINK. NO JOINTS ARE ALLOWED BELOW SLAB. COORDINATE EXACT FIXTURE LOCATIONS WITH ARCHITECTURAL DRAWINGS.
- ② ROUTE CW AND HW DOWN IN STUD WALL TO SERVE FIXTURES.
- ③ ROUT 1/2" CA TO AND 1/2" VAC PIPE DOWN WITHIN WALL. CONNECT TO HEADWALL.

**GMC**  
2701 1st Avenue S  
Birmingham, AL 35233  
T 205.879.4462  
OMCNETWORK.COM


ISSUE DATE	ISSUE FOR BID
2016.05.25	

SIMULATION LABORATORY  
BUILDING - USA JOB #16-07  
MOBILE, ALABAMA  
ABC #2017372  
GMC # AMOB160019



LEVEL 1 - CW, HW, CA,  
V, & GAS PLAN  
**P2.01**  
Sheet of

PLAN NORTH  
**1** LEVEL 1 - DOMESTIC WATER, COMPRESSED AIR AND VACUUM PLAN  
SCALE: 3/16"=1'-0"



5/21/2016 12:26:08 PM

