SHEET NOTES

1. SIDE WALL SPRINKLERS SHALL BE PROVIDED AT THE BOTTOM OF EACH HOISTWAY AND UPRIGHT OR SIDEWALL SPRINKLERS SHALL BE PROVIDED AT THE TOP OF EACH HOISTWAY IN ACCORDANCE WITH NFPA 13.

HATCH LEGEND

- LIGHT HAZARD DENSITY
- ORDINARY HAZARD GROUP 1

CLASS III MANUAL STANDPIPE

CLASS III MANUAL STANDPIPE

6" FIRE RISER

PLAN NORTH

1 LEVEL 3 - FIRE PROTECTION PLAN

3/16" = 1'-0"

SCALE: 3/16"=1'-0"

SCHMIDT CONSULTING GROUP, INC.
MECHANICAL ELECTRICAL STRUCTURAL
COMMUNICATIONS INDUSTRIAL
ALABAMA LICENSE NUMBER 2542
901 W. Garden St. Pensacola, FL 32502
P: 850.435.0000 F: 850.432.0631
WILLIAM JOSEPH JONES P.E.
ALABAMA LICENSE NUMBER 25171
SCG PROJECT: 2016-151

2701 1st Avenue S
Birmingham, AL 35233
T 205.879.4462
@MCNETWORK.COM

ISSUE | DATE
ISSUE FOR BID | 2018.05.25

DRAWN BY: CAD
CHECKED BY: WJJ

SIMULATION LABORATORY
BUILDING - USA JOB #16-07
MOBILE, ALABAMA
ABC #2017372
GMC # AMOB160019

ALABAMA LICENSED 25171 PROFESSIONAL ENGINEER WILLIAM JOSEPH JONES

LEVEL 3 - FIRE PROTECTION PLAN

FP1.03

sheet of

5/21/2018 12:06:46 PM

Order Plans @ www.LDLine.com GMC