LIGHT FIXTURE SCHEDULE

TYPE	CATALOG NO. MANUFACTURER	MODEL	LAMP TYPE	TOTAL WATTS	VOLTAGE	MOUNTING	NOTES
PD1	TMS LIGHTING OR APPROVED EQUAL	971LU 36ID 35K 2 S PS F19 DIML	LED	102 W	277 V	PENDANT 7'-4" AFF	PROVIDE ALL REQUIRED MOUNTING HARDWARE. COORDINATE EXACT HEIGHT OF FIXTURE WITH ARCHITECT PRIOR TO ORDERING
PD2	FOCAL POINT OR APPROVED EQUAL	FNRP-44-FL50-4000L-35K-1C-UNV-OC -CLV24-PS	LED	33 W	277 V	PENDANT 8'-4" AFF	PROVIDE ALL REQUIRED HARDWARE FOR GRID MOUNTING. COORDINATE EXACT MOUNTING LOCATION WITH ARCHITECTURAL.
PD3	FOCAL POINT OR APPROVED EQUAL	FNRP-33-FL50-3000L-35K-1C-UNV-OC -CLV24-PS	LED	33 W	277 V	PENDANT 8'-10" AFF	PROVIDE ALL REQUIRED HARDWARE FOR GRID MOUNTING. COORDINATE EXACT MOUNTING LOCATION WITH ARCHITECTURAL.
L1A	LITHONIA LIGHTING OR APPROVED EQUAL	2TL2 20L A19 MVOLT EZ1 LP835	LED	35 W	277 V	RECESSED GRID	PROVIDE SOLID STATE ELECTRONIC DRIVER. PROVIDE WITH A19 ACRYLIC LENS MITERED DOOR FRAMES WITH SPRING LOADED LATCHES AND PAINTED AFTER FAB.
L2A	LITHONIA LIGHTING OR APPROVED EQUAL	2TL4 30L A19 MVOLT EZ1 LP835	LED	25 W	277 V	RECESSED GRID	PROVIDE SOLID STATE ELECTRONIC DRIVER. PROVIDE WITH A19 ACRYLIC LENS MITERED DOOR FRAMES WITH SPRING LOADED LATCHES AND PAINTED AFTER FAB.
L1ID	LITHONIA LIGHTING OR APPROVED EQUAL	2BLT2 33L ADP EZ1 LP835	LED	30 W	277 V	RECESSED GRID	PROVIDE SOLID STATE ELECTRONIC DRIVER. MITERED DOOR FRAMES WITH SPRING LOADED LATCHES AND PAINTED AFTER FAB.
L2ID	LITHONIA LIGHTING OR APPROVED EQUAL	2BLT2 40L ADP EZ1 LP835	LED	39 W	277 V	RECESSED GRID	PROVIDE SOLID STATE ELECTRONIC DRIVER. MITERED DOOR FRAMES WITH SPRING LOADED LATCHES AND PAINTED AFTER FAB.
L3ID	LITHONIA LIGHTING OR APPROVED EQUAL	2BLT4 40L ADP EZ1 LP835	LED	34 W	277 V	RECESSED GRID	PROVIDE SOLID STATE ELECTRONIC DRIVER. MITERED DOOR FRAMES WITH SPRING LOADED LATCHES AND PAINTED AFTER FAB.
L4ID	LITHONIA LIGHTING OR APPROVED EQUAL	2BLT4 60L ADP EZ1 LP835	LED	53 W	277 V	RECESSED GRID	PROVIDE SOLID STATE ELECTRONIC DRIVER. MITERED DOOR FRAMES WITH SPRING LOADED LATCHES AND PAINTED AFTER FAB.
L5ID	LITHONIA LIGHTING OR APPROVED EQUAL	2BLT4 72L ADP EZ1 LP835	LED	67 W	277 V	RECESSED GRID	PROVIDE SOLID STATE ELECTRONIC DRIVER. MITERED DOOR FRAMES WITH SPRING LOADED LATCHES AND PAINTED AFTER FAB.
LD1	LITHONIA LIGHTING OR APPROVED EQUAL	LDN4 35/10 L04 AR LSS EZ1	LED	13 W	277 V	RECESSED GRID	PROVIDE SOLID STATE ELECTRONIC DRIVER. SPECULAR SPUN ALUMINUM REFLECTOR. SHALLOW DEPTH WHITE FLANGE. INTEGRAL MOUNTING CHANNELS
LD2	LITHONIA LIGHTING OR APPROVED EQUAL	LDN4 35/15 L04 AR LSS EZ1	LED	20 W	277 V	RECESSED GRID	PROVIDE SOLID STATE ELECTRONIC DRIVER. SPECULAR SPUN ALUMINUM REFLECTOR. SHALLOW DEPTH WHITE FLANGE. INTEGRAL MOUNTING CHANNELS
LD3	LITHONIA LIGHTING OR APPROVED EQUAL	LDN4 35/20 L04 AR LSS EZ1	LED	24 W	277 V	RECESSED GRID	PROVIDE SOLID STATE ELECTRONIC DRIVER. SPECULAR SPUN ALUMINUM REFLECTOR. SHALLOW DEPTH WHITE FLANGE. INTEGRAL MOUNTING CHANNELS
LD4	GOTHAM LIGHTING OR APPROVED EQUAL	ICO 35/20 6AR LSS 60D CRI80 EZ1	LED	26 W	277 V	RECESSED GRID	PROVIDE SOLID STATE ELECTRONIC DRIVER. SPECULAR SPUN ALUMINUM REFLECTOR. SHALLOW DEPTH WHITE FLANGE. INTEGRAL MOUNTING CHANNELS. WET LOCATION RATED
SL1	GOTHAM LIGHTING OR APPROVED EQUAL	EVO 35/10 6DFR MVOLT EZ1	LED	47 W	277 V	RECESSED GYP.	PROVIDE SOLID STATE ELECTRONIC DRIVER. PROVIDE WITH REGRESSED DEAD FRONT LENS. WET LOCATION RATED
L2I	LITHONIA LIGHTING OR APPROVED EQUAL	ZL1D L48 SMR 3000LM FST MVOLT 35K 80CRI WH	LED	30 W	277 V	SURFACE	PROVIDE WITH FROSTED DROP LENS
L3I	LITHONIA LIGHTING OR APPROVED EQUAL	ZL1D L48 SMR 5000LM FST MVOLT 35K 80CRI WH	LED	54 W	277 V	SURFACE	PROVIDE WITH FROSTED DROP LENS
LB8	LITHONIA LIGHTING OR APPROVED EQUAL	WST LED P2 40K VF 277 PE DDBXD	LED	40 W	277 V	WALL @ 7'6"	UL LISTED FOR WET LOCATION. PROVIDE BODINE EMERGENCY GTD
LB1	LITHONIA LIGHTING OR APPROVED EQUAL	FMVCSL 24IN MVOLT 35K 90CRI BN	LED	8 W	277 V	WALL 6" ABOVE MIRROR	PROVIDE SOLID STATE ELECTRONIC DRIVER
LB2	SELUX LIGHTING OR APPROVED EQUAL	L1DI 1B20 IB20 35 LW LW W 05 WH UNV DIM	LED	43 W	277 V	WALL 7'-0" AFF	PROVIDE ALL REQUIRED MOUNTING HARDWARE
LB3	SELUX LIGHTING OR APPROVED EQUAL	L1DI 1B20 IB20 35 LW LW W 08 WH UNV DIM	LED	77 W	277 V	WALL 7'-0" AFF	PROVIDE ALL REQUIRED MOUNTING HARDWARE
LB4	LITHONIA LIGHTING OR APPROVED EQUAL	WL4 40L LP835 MSD7 DIM50 EL14L	LED	40 W	277 V	WASH ABOVE STAIR LANDING	PROVIDE SOLID STATE ELECTRONIC DRIVER
LB5	KENALL LIGHTING OR APPROVED EQUAL	MPWUD 48 MW FA 0/1 33L35K DCC DV SW	LED	74 W	277 V	WALL 6'-6" AFF	PATIENT HEADWALL READING FIXTURE. COORDINATE EXACT HEIGHT OF FIXTURE WITH PATIENT HEADWALL PRIOR TO ROUGH-IN. COORDINATE SWITCH REQUIREMENTS WITH PROVIDED HEADWALL.
LB6	PEERLESS LIGHTING OR APPROVED EQUAL	SQW4 STW 4FT 80CRI 35K I500LMF 400LMF ZT 277 SCT [illegible]032	LED	30 W	277 V	WALL 7'-0" AFF	PROVIDE ALL REQUIRED MOUNTING HARDWARE
LB7	PEERLESS LIGHTING OR APPROVED EQUAL	SQW4 STW 4FT 80CRI 35K I500LMF 800LMF MIN50 ZT 277 SCT [illegible]EC	LED	8 W	277 V	WALL 7'-0" AFF	PROVIDE ALL REQUIRED MOUNTING HARDWARE. PROVIDE WITH INTEGRAL MOTION SENSOR. DIM TO 50% WHEN VACANCY DETECTED AFTER 15MINS. PROVIDE WITH GENERATOR TRANSFER DEVICE
CB	SIGNAL-TECH OR APPROVED EQUAL	SBL 1212 BLUE CODE	LED	28 W	277 V	WALL @ 6" ABOVE WINDOW	SBL SERIES BLANK OUT 12"x12" BLUE LED SIGN WITH WORD "CODE" ON FACE. SIGN SHALL BE CONNECTED TO CODE BLUE ALERT SWITCH LOCATED IN PATIENT HEADWALL IN ADJACENT PATIENT SIM LAB.
EPL	LITHONIA LIGHTING OR APPROVED EQUAL	DMW2 L24 4000LM PFL WD MVOLT GZ1 35K 80CRI PS1050	LED	40 W	277 V	MOUNT IN ELEV. PIT	PROVIDE SOLID STATE ELECTRONIC DRIVER
BP	LITHONIA LIGHTING OR APPROVED EQUAL	ELM2 LED HO SD	LED	3 W	277 V	WALL @ 7'6"	PROVIDE EMERGENCY NICAD BATTERY BACKUP. PROVIDE CONNECTION TO UNSWITCHED LEG. SELF DIAGNOSTICS W/LEDS.
EX1	LITHONIA LIGHTING OR APPROVED EQUAL	[illegible]S-R-120/277ELNSD	LED	8 W	277 V	WALL OR CEILING INDICATED	PROVIDE EMERGENCY NICAD BATTERY BACKUP. ARROWS AS PER PLANS. DIE CAST ALUMINUM HOUSING WITH BRUSHED ALUMINUM FACEPLATE. SELF DIAGNOSTICS WITH LEDS. DOUBLE FACE AS INDICATED ON PLANS.
PL1	BEGA-US OR APPROVED EQUAL	77 [illegible]36	LED	58 W	277 V	POLE MOUNTED @ 17'-6"	PROVIDE WITH 17'-6" ROUND TAPERED POLE AND ALL HARDWARE REQUIRED TO MOUNT FIXTURE TO POLE.

NOTES:
1) FIXTURES WITH HALF FILLED IN CENTER SHALL BE PROVIDED WITH A BODINE GTD DEVICE. SEE DETAIL
2) PRIOR APPROVALS TO BE SUBMITTED TO THE ENGINEER 14 DAYS PRIOR TO BID DATE FOR REVIEW.

SCHMIDT CONSULTING GROUP, INC.
MECHANICAL ELECTRICAL STRUCTURAL
COMMUNICATIONS INDUSTRIAL
ALABAMA LICENSE NUMBER 3542
601 W. Garden St. Pensacola, FL 32502
P: 850.438.0050 F: 850.432.6631
TODD NICHOLSON P.E.
ALABAMA LICENSE NUMBER 29943-E
SCG PROJECT: 2016-151

GMC
2701 1st Avenue S
Birmingham, AL 35233
T 205.879.4462
GMCNETWORK.COM

ISSUE DATE
ISSUE FOR BID 2018.05.25

DRAWN BY: JTH
CHECKED BY: TAN

SIMULATION LABORATORY
BUILDING - USA JOB #16-07
MOBILE, ALABAMA
ABC #2017372
GMC # AMOB160019

ALABAMA
29943-E
PROFESSIONAL
ENGINEER
TODD ALAN NICHOLSON

ELECTRICAL LIGHTING FIXTURE SCHEDULE

E002

sheet of

5/23/2018 8:00:51 AM

Order Plans @ WWW.DILine.com