



L7 ACCESSIBILITY FIXTURE NOTES

3/8" = 1'-0"

FIRE NOTES
 INCLUDED AS A DEPARTMENT OF FIRE PREVENTION REQUIREMENT
 1. THE MAXIMUM FLAME SPREAD CLASSIFICATION OF FINISH MATERIAL USED ON INTERIOR WALLS AND CEILINGS SHALL NOT EXCEED THAT SET FORTH IN THE INTERNATIONAL BUILDING CODE (IBC)
 2. PROVIDE FIRE STOPPING TO CUT ALL CONCEALED DRAPE OPENINGS (BOTH VERTICAL AND HORIZONTAL) AT 10'-0" O.C. EVERYWAY
 3. PROVIDE A COMPLETE SUPERVISED AUTOMATIC FIRE SPRINKLER SYSTEM IN STRICT ACCORDANCE WITH THE FIRE DEPARTMENT REGULATIONS
 4. EXIT SIGNS SHALL MEET THE REQUIREMENTS OF THE BUILDING AND FIRE CODES. SEE FLOOR PLANS FOR LOCATION OF EXIT SIGNS AND APPROVAL. SIGNIFY EXITS BY PROVIDING EXITS WITH ILLUMINATED EXIT SIGNS. PROVIDE EXITS WITH ILLUMINATED EXIT SIGNS. PROVIDE EXITS WITH ILLUMINATED EXIT SIGNS. PROVIDE EXITS WITH ILLUMINATED EXIT SIGNS. PROVIDE EXITS WITH ILLUMINATED EXIT SIGNS.
 5. ALL EXIT DOORS SHALL BE OPENABLE FROM THE INSIDE WITHOUT THE USE OF TOOLS, KEYS, COIN OPERATED MECHANISMS, OR SPECIAL KNOWLEDGE.
 6. WITHIN A STRUCTURE, MAINTAIN ANGLE LEADING TO REQUIRED EXITS CONTINUOUSLY TO A PUBLIC OR COMMON AREA. PROVIDE REFLECTIVE STRIP ON THE LEADING TO REQUIRED EXITS.
 7. ONE-HOUR FIRE RATED CORRIDORS SHALL HAVE DOOR OPENINGS PROTECTED BY TIGHT-FITTING SMOKE AND FIRE RESISTANT CONTROL ASSEMBLY RATED WITH 20 MINUTE LABEL EXCEPT WHERE WALLS OF EXTERIOR EXITS OR BALCONIES OR EXITS TO EXTERIOR ARE MAINTAINED SELF-CLOSING OR AUTOMATIC CLOSING IN ACTION OF A SMOKE DETECTOR. DOORS SHALL BE GREATER THAN 5/8" (22.2%)
 8. PROVIDE FIRE DAMPERS WHERE STRUCTURE PENETRATES A FIRE RATED WALL OR CEILING ASSEMBLY
 9. DURING CONSTRUCTION OR DEMOLITION, PROVIDE PORTABLE FIRE EXTINGUISHER WITH A RATING OF NOT LESS THAN 2A OR 2A10BC WITHIN 75' TRAVEL DISTANCE OF ALL PORTABLE BUILDING EXITS
 10. AT THE TIME OF THE EMERGENCY PERIOD, THE SIZE AND TYPE REQUESTED BY THE FIRE OFFICIAL. FIRE EXTINGUISHERS SHALL BE OF THE TYPE AND TYPE REQUESTED BY THE FIRE OFFICIAL. FIRE EXTINGUISHERS SHALL BE OF THE TYPE AND TYPE REQUESTED BY THE FIRE OFFICIAL. FIRE EXTINGUISHERS SHALL BE OF THE TYPE AND TYPE REQUESTED BY THE FIRE OFFICIAL.
 11. PRIOR TO DELIVERY OF COMBUSTIBLE MATERIAL TO THE PROJECT SITE, THE CONTRACTOR SHALL PASS ALL REQUIRED TESTS AND BE CONNECTED TO THE BUILDING WATER SUPPLY SYSTEM. THE CONTRACTOR SHALL PASS ALL REQUIRED TESTS AND BE CONNECTED TO THE BUILDING WATER SUPPLY SYSTEM. THE CONTRACTOR SHALL PASS ALL REQUIRED TESTS AND BE CONNECTED TO THE BUILDING WATER SUPPLY SYSTEM.
 12. MAINTAIN GOOD HOUSEKEEPING AT ALL TIMES. ACCESSIBLE TO ALL WASTE MATERIALS IN THE BUILDING IS NOT ALLOWED
 13. CLEARLY IDENTIFY THE LOCATION OF ALL FIRE EXTINGUISHERS IN A MANNER APPROVED BY THE MARSHAL, TO PREVENT OBSTRUCTION BY PARKING AND OTHER
 14. ALL INSULATION MATERIALS, INCLUDING AS VAPOR BARRIER, BREATHER PAPER, INSTALLED WITHIN FLOOR CEILING ASSEMBLIES, ROOF-CEILING ASSEMBLIES, WALL-CORNER SPACES OR IN WALLS SHALL HAVE A FLAME-SPREAD RATING NOT TO EXCEED 25 AND SMOKE DENSITY NOT TO EXCEED 450

GENERAL NOTE
 ALL ACCESSIBILITY REQUIREMENTS LIMITED TO SCOPE OF WORK ONLY

RAMP
 NOTE: THE WIDTH OF TRAVEL SHALL BE CONSIDERED A RAMP IF ITS SLOPE IS GREATER THAN 1 FT RISE IN 20' OF HORIZONTAL RUN
 1. THE MAXIMUM SLOPE OF A RAMP IN NEW CONSTRUCTION SHALL BE 1 TO 12. THE MAXIMUM RISE FOR ANY RUN SHALL BE 30 INCHES
 2. CURB RAMPS AND INTERIOR OR EXTERIOR RAMPS TO BE CONSTRUCTED ON EXISTING BUILDINGS OR FACILITIES WHERE SPACE LIMITATIONS PROHIBIT THE USE OF A 1 TO 12 SLOPE OR LESS MAY HAVE SLOPES AND RISES AS FOLLOWS:
 (A) A SLOPE BETWEEN 1 TO 10 AND 1 TO 12 IS ALLOWED FOR A MAXIMUM RISE OF 8 INCHES
 (B) A SLOPE BETWEEN 1 TO 10 AND 1 TO 12 IS ALLOWED FOR A MAXIMUM RISE OF 8 INCHES
 (C) A SLOPE STEEPER THAN 1 TO 12 IS NOT ALLOWED
 3. THE CROSS SLOPE OF RAMP SURFACES SHALL BE NO GREATER THAN 1/8" (1/4" FT)
 4. THE MINIMUM CLEAR WIDTH OF A RAMP SHALL BE 36 INCHES
 EXCEPTION: RAMPS THAT ARE PART OF A REQUIRED MEANS OF EGRESS SHALL BE NOT LESS THAN 44 INCHES WIDE
 5. RAMPS SHALL HAVE LEVEL LANDINGS AT BOTTOM AND TOP OF EACH RAMP AND EACH RAMP RUN. LANDINGS SHALL HAVE THE FOLLOWING FEATURES:
 (A) THE LANDINGS SHALL BE AT LEAST AS WIDE AS THE RAMP RUN LEADING TO IT
 (B) ALL LANDINGS ON RAMPS SHALL BE NOT LESS THAN 60 INCHES CLEAR, AND THE BOTTOM OF EACH RAMP SHALL HAVE NOT LESS THAN 72 INCHES OF STRAIGHT AND LEVEL CLEARANCE
 (C) IF RAMPS CHANGE DIRECTION AT LANDINGS, THE MINIMUM LANDING SIZE SHALL BE 60 INCHES BY 60 INCHES
 6. IF A RAMP RUN HAS A RISE GREATER THAN 12 INCHES, PROTECTION GREATER THAN 72 INCHES, THEN IT SHALL HAVE HANDRAILS ON BOTH SIDES. HANDRAILS ARE NOT REQUIRED ON CURB RAMPS OR ADJACENT TO SEATING IN ASSEMBLY AREAS. HANDRAILS SHALL ALWAYS BE CONTINUOUS
 (A) HANDRAILS SHALL BE PROVIDED ALONG BOTH SIDES OF RAMP SEGMENTS. THE INSIDE HANDRAIL ON SWITDBACK OR DOUGLAS RAMPS SHALL ALWAYS BE CONTINUOUS
 (B) HANDRAILS ON RAMPS WHICH ARE NOT CONTINUOUS SHALL EXTEND NOT LESS THAN 18 INCHES BEYOND THE SLOPED SEGMENT AT BOTH THE TOP AND BOTTOM, AND SHALL BE PARALLEL TO THE FLOOR OR GROUND SURFACE
 (C) THE CLEAR SPACE BETWEEN THE HANDRAIL AND THE WALL SHALL BE 1.5 INCHES
 (D) GRIPPING SURFACES SHALL BE CONTINUOUS
 (E) TOP OF HANDRAIL GRIPPING SURFACES SHALL BE MOUNTED BETWEEN 24 INCHES AND 38 INCHES ABOVE RAMP SURFACES
 (F) ENDS OF HANDRAILS SHALL BE EITHER ROUNDED OR RETURNED SMOOTHLY TO FLOOR, WALL, OR POST
 (G) HANDRAILS SHALL NOT ROTATE WITHIN THEIR FITTINGS
 7. THE GRIP PORTION OF HANDRAILS SHALL NOT BE LESS THAN 1-1/4" OR GREATER THAN 1-1/2" IN CROSS SECTION, DIMENSION, OR THE SHAPE SHALL PROVIDE AN EQUIVALENT GRIPPING SURFACE, AND ALL SURFACES SHALL BE SMOOTH WITH NO SHARP CORNERS
 8. ANY WALL OR OTHER SURFACE ADJACENT TO HANDRAILS SHALL BE FREE OF SHARP OR ABRASIVE ELEMENTS. EDGES SHALL HAVE A MINIMUM RADIUS OF 1/8"

STAIRWAYS
 1. THE MAXIMUM HEIGHT OF STAIRS, ALL STEPS SHALL HAVE UNIFORM RISE HEIGHTS AND UNIFORM TREAD WIDTHS. STAIR TREADS SHALL BE NO LESS THAN 11 INCHES CLEAR, MEASURED FROM RISES TO RISES. OPEN RISERS ARE NOT PERMITTED
 2. THE MAXIMUM SLOPE OF STAIRS SHALL NOT EXCEED 1 TO 12. THE MAXIMUM RISE SHALL BE 7 INCHES. THE MAXIMUM TREAD WIDTH SHALL BE 11 INCHES. THE MAXIMUM RUN SHALL BE 17 INCHES. THE MAXIMUM RISE SHALL BE 7 INCHES. THE MAXIMUM TREAD WIDTH SHALL BE 11 INCHES. THE MAXIMUM RUN SHALL BE 17 INCHES.
 3. HANDRAILS SHALL BE PROVIDED ON BOTH SIDES OF ALL STAIRS. HANDRAILS SHALL HAVE THE FOLLOWING FEATURES:
 (A) HANDRAILS SHALL BE CONTINUOUS ALONG BOTH SIDES OF STAIRS. THE INSIDE HANDRAIL ON SWITDBACK OR DOUGLAS STAIRS SHALL ALWAYS BE CONTINUOUS
 (B) HANDRAILS ON STAIRS WHICH ARE NOT CONTINUOUS SHALL EXTEND NOT LESS THAN 18 INCHES BEYOND THE SLOPED SEGMENT AT BOTH THE TOP AND BOTTOM, AND SHALL BE PARALLEL TO THE FLOOR OR GROUND SURFACE. AT THE BOTTOM, THE HANDRAIL SHALL CONTINUE TO THE WIDTH OF THE WIDEST TREAD FROM THE BOTTOM RISER, THE REMAINDER OF THE EXTENSION SHALL BE PARALLEL TO THE WIDEST TREAD FROM THE BOTTOM RISER, THE REMAINDER OF THE EXTENSION SHALL BE PARALLEL TO THE WIDEST TREAD FROM THE BOTTOM RISER, THE REMAINDER OF THE EXTENSION SHALL BE PARALLEL TO THE WIDEST TREAD FROM THE BOTTOM RISER.
 (C) THE CLEAR SPACE BETWEEN HANDRAILS AND WALL SHALL BE 1-1/2 INCHES
 (D) GRIPPING SURFACES SHALL BE CONTINUOUS AND UNIFORM IN HEIGHT, AND OTHER CONSTRUCTION ELEMENTS OR OBSTRUCTIONS SHALL NOT BE LOCATED ON THE GRIPPING SURFACES
 (E) TOP OF HANDRAIL GRIPPING SURFACES SHALL BE MOUNTED BETWEEN 24 INCHES AND 38 INCHES ABOVE STAIR TREADS
 (F) ENDS OF HANDRAILS SHALL BE EITHER ROUNDED OR RETURNED SMOOTHLY TO FLOOR, WALL, OR POST
 (G) HANDRAILS SHALL NOT ROTATE WITHIN THEIR FITTINGS

CONTROLS & OPERATING MECHANISMS
 1. CLEAR FLOOR SPACE COMPLYING WITH SECTION 11-4.2.4 THAT ALLOWS A FORWARD OR A PARALLEL APPROACH BY A PERSON USING A WHEELCHAIR SHALL BE PROVIDED AT CONTROLS, DISPENSERS, RECEPTACLES AND OTHER OPERABLE EQUIPMENT
 2. THE HIGHEST OPERABLE PART OF CONTROLS, DISPENSERS, RECEPTACLES, AND OTHER OPERABLE EQUIPMENT SHALL BE PLACED WITHIN AT LEAST ONE OF THE REACH RANGES SPECIFIED IN SECTIONS 11-4.2.2 AND 11-4.2.6. ELECTRICAL AND COMMUNICATIONS SYSTEM RECEPTACLES ON WALLS SHALL BE MOUNTED NO LESS THAN 48 INCHES ABOVE THE FLOOR
 EXCEPTION: THESE REQUIREMENTS DO NOT APPLY WHERE THE USE OF SPECIAL EQUIPMENT DICTATES OTHERWISE OR WHERE ELECTRICAL AND COMMUNICATIONS SYSTEMS RECEPTACLES ARE NOT NORMALLY INTENDED FOR USE BY BUILDING OCCUPANTS
 3. CONTROLS AND OPERATING MECHANISMS SHALL BE OPERABLE WITH ONE HAND AND SHALL NOT REQUIRE TIGHT GRASPING, PINCHING, OR TWISTING OF THE WRIST. THE FORCE REQUIRED TO ACTIVATE CONTROLS SHALL BE NO GREATER THAN 5 LBS (22.2%)

ENTRANCES AND EXITS
 1. ENTRANCES SHALL BE CONNECTED BY AN ACCESSIBLE ROUTE TO PUBLIC TRANSPORTATION STOPS, TO ACCESSIBLE PARKING AND PASSENGER LOADING ZONES, AND TO PUBLIC STREETS OR SIDEWALKS IF AVAILABLE. THEY SHALL ALSO BE CONNECTED BY AN ACCESSIBLE ROUTE TO ALL ACCESSIBLE SPACES OR ELEMENTS WITHIN THE BUILDING OR FACILITY
 2. A SERVICE ENTRANCE SHALL NOT BE THE ONLY ACCESSIBLE ENTRANCE UNLESS IT IS THE ONLY ENTRANCE TO A BUILDING OR FACILITY (FOR EXAMPLE, IN A FACTORY OR GARAGE)
 3. ALL REQUIRED WALK THROUGH OPENINGS IN BUILDINGS SHALL HAVE AT LEAST 20 INCHES OF CLEAR WIDTH
 4. REVOLVING DOORS OR TURNSTILES SHALL NOT BE THE ONLY MEANS OF PASSAGE AT AN ACCESSIBLE ENTRANCE OR ALONG AN ACCESSIBLE ROUTE. AN ACCESSIBLE GATE OR DOOR SHALL BE PROVIDED ADJACENT TO THE TURNSTILE OR REVOLVING DOOR AND SHALL BE SO DESIGNED AS TO FACILITATE THE SAME USE PATTERN
 5. TURNSTILES SHALL NOT BE USED IN OCCUPANCIES WHICH SERVE FEWER THAN 100 PERSONS, BUT TURNSTILES MAY BE USED IN OCCUPANCIES WHICH SERVE AT LEAST 100 PERSONS IF THERE IS AN UNLOCKED ALTERNATE PASSAGEWAY OR AN ACCESSIBLE ROUTE FORFORDING NOT LESS THAN 32 INCHES OF CLEARANCE, EQUIPPED WITH LATCHING DEVICES IN ACCORDANCE WITH THIS CODE
 6. DOORWAYS SHALL HAVE A MINIMUM CLEAR OPENING OF 32 INCHES WITH THE DOOR OPEN 90 DEGREES, MEASURED BETWEEN THE FACE OF THE DOOR AND THE OPPOSITE STOP
 EXCEPTION: DOORS NOT REQUIRING FULL USE PASSAGE, SUCH AS SHALLOW CLOSETS, MAY HAVE THE CLEAR OPENING REDUCED TO 20 INCHES MINIMUM
 7. THE MINIMUM SPACE BETWEEN TWO HINGED OR PROVED DOORS IN SERIES SHALL BE 48 INCHES PLUS THE WIDTH OF ANY DOOR SWINGING INTO THE SPACE. DOORS IN SERIES SHALL SWING IN THE SAME DIRECTION OR AWAY FROM THE SPACE BETWEEN THE DOORS
 8. THRESHOLDS AT DOORWAYS SHALL NOT EXCEED 3/4 INCH IN HEIGHT FOR EXTERIOR SLIDING DOORS OR 1/2 INCH FOR OTHER TYPES OF DOORS. RAISED THRESHOLDS AND FLOOR LEVEL CHANGES AT ACCESSIBLE DOORWAYS SHALL BE BEVELLED WITH A SLOPE GREATER THAN 1 TO 2
 9. HANDLES, PULLS, LATCHES, LOCKS, AND OTHER OPERATING DEVICES ON ACCESSIBLE DOORS SHALL HAVE A SHAPE THAT IS EASY TO GRASP WITH ONE HAND AND DOES NOT REQUIRE TIGHT GRASPING, TIGHT PINCHING, OR TWISTING OF THE WRIST TO OPERATE. LEVER-OPERATED MECHANISMS, PUSH-TYPE MECHANISMS, AND D-SHAPED HANDLES ARE ACCEPTABLE DESIGNS. WHEN SLIDING DOORS ARE FULLY OPEN, OPERATING HARDWARE SHALL BE EXPOSED AND USABLE FROM BOTH SIDES. HARDWARE REQUIRED FOR ACCESSIBLE DOOR PASSAGE SHALL BE MOUNTED NO HIGHER THAN 48 INCHES ABOVE FINISH FLOOR
 10. IF A DOOR HAS A CLOSER, THEN THE SWEEP PERIOD OF THE CLOSER SHALL BE ADJUSTED SO THAT FROM AN OPEN POSITION IT WILL HOLD THE DOOR WILL TAKE AT LEAST 3 SECONDS TO MOVE TO A POINT 2 INCHES FROM THE LATCH, MEASURED TO THE LEADING EDGE OF THE DOOR
 11. THE MAXIMUM FORCE FOR PUSHING OR PULLING OPEN A DOOR SHALL BE AS FOLLOWS:
 (A) FIRE DOORS SHALL HAVE THE MINIMUM OPENING FORCE ALLOWED BY THE APPROPRIATE ADMINISTRATIVE AUTHORITY
 (B) EXTERIOR HINGED DOORS SHALL BE SO DESIGNED THAT SUCH DOORS CAN BE PUSHED OR PULLED OPEN WITH A FORCE NOT EXCEEDING 8.5 LBS (37.8 N)
 (C) INTERIOR HINGED DOORS: 5 LBS (22.2 N)
 (D) SLIDING OR FLOOR DOORS: 5 LBS (22.2 N)
 THESE FORCES DO NOT APPLY TO THE FORCE REQUIRED TO RETRACT LATCH BOLTS OR DISASSEMBLE OTHER DEVICES THAT MAY HOLD THE DOOR IN A CLOSED POSITION
 12. IF AN AUTOMATIC DOOR IS USED, THEN IT SHALL COMPLY WITH ASHRAE 154-1986. SLIDING OR FLOOR DOORS MAY HOLD THE DOOR IN A CLOSED POSITION. SUCH DOORS SHALL HAVE THE MINIMUM OPENING FORCE ALLOWED BY THE APPROPRIATE ADMINISTRATIVE AUTHORITY. AUTOMATIC DOORS SHALL COMPLY WITH ANSI A118.19-1986. SUCH DOORS SHALL NOT OPEN TO BACK CHECK FASTER THAN 2 SECONDS AND SHALL REQUIRE NO MORE THAN 15 LBS (6.8 N) TO STOP DOOR MOVEMENT. A POWER-ASSISTED DEVICE IS USED, ITS CLOSING SHALL CONFORM TO THE REQUIREMENTS IN ANSI A118.19-1986

FLOORS AND LEVELS
 1. GROUND AND FLOOR SURFACES ALONG ACCESSIBLE ROUTES AND IN ACCESSIBLE ROOMS AND SPACES INCLUDING FLOORS, WALKS, RAMPS, STAIRS, AND CURB RAMPS, SHALL BE STABLE, FIRM, AND RESISTANT
 2. CHANGES IN LEVEL UP TO 1/4 INCH AND WITHOUT EDGE TREATMENT CHANGES IN LEVEL BETWEEN 1/4 INCH AND 1/2 INCH SHALL BE REVEALED WITH A SLOPE NO GREATER THAN 1 TO 2. CHANGES IN LEVEL GREATER THAN 1/2 INCH SHALL BE ACCOMPLISHED BY MEANS OF A RAMP
 3. IF CARPET OR CARPET TILE IS USED ON A GROUND OR FLOOR SURFACE, THEN IT SHALL BE SECURELY ATTACHED, HAVE A FIRM CUSHION, PAD, OR BACKING, OR ON GROUND OR PAD, AND HAVE A LEVEL, LOOP, LEVEL CUT, OR LEVEL CUT/NOVELTY PILE TEXTURE. THE MAXIMUM PILE THICKNESS SHALL BE 1/2 INCH. EXPOSED EDGES OF CARPET SHALL BE FASTENED TO FLOOR SURFACES AND HAVE TRIM ALONG THE LENGTH OF THE EXPOSED EDGE
 4. THE DIAMETER OR WIDTH OF THE GRIPPING SURFACE OF A HANDRAIL OR GRAB BAR SHALL BE 1-1/4 INCHES TO 1-1/2 INCHES, OR THE SHAPE SHALL PROVIDE AN EQUIVALENT GRIPPING SURFACE. IF HANDRAILS OR GRAB BARS ARE MOUNTED ADJACENT TO A WALL, THE SPACE BETWEEN THE WALL AND THE GRAB BAR SHALL BE 1-1/2 INCHES. HANDRAILS MAY BE LOCATED IN A RECESS IF THE RECESS IS A MAXIMUM OF 3 INCHES DEEP AND EXTENDS AT LEAST 18 INCHES ABOVE THE TOP OF THE WALL
 5. THE STRUCTURAL STRENGTH OF GRAB BARS, TUB AND SHOWER SEATS, FASTENERS AND MOUNTING DEVICES SHALL MEET THE FOLLOWING SPECIFICATION:
 (A) TENSILE FORCE INDUCED IN A FASTENER BY A DIRECT TENSION FORCE OF 250 LBS (112 N) PLUS THE MAXIMUM MOMENT FROM THE APPLICATION OF 250 LBS (112 N) SHALL BE LESS THAN THE ALLOWABLE WITHSTAND LOAD BETWEEN THE FASTENER AND THE SUPPORTING STRUCTURE
 (B) SHEAR STRESS INDUCED IN A GRAB BAR OR SEAT BY THE APPLICATION OF 250 LBS (112 N) SHALL BE LESS THAN THE ALLOWABLE SHEAR STRESS FOR THE MATERIAL OF THE GRAB BAR OR SEAT. IF THE CONNECTION BETWEEN THE GRAB BAR OR SEAT AND ITS MOUNTING BRACKET OR OTHER SUPPORT IS CONSIDERED TO BE FULLY RESTRAINED, THEN DIRECT AND TORSIONAL SHEAR STRESS SHALL BE TOTALLED FOR THE COMBINED SHEAR STRESS, WHICH SHALL NOT EXCEED THE ALLOWABLE SHEAR STRESS
 (C) SHEAR FORCE INDUCED IN A FASTENER ON MOUNTING DEVICES FROM THE APPLICATION OF 250 LBS (112 N) SHALL BE LESS THAN THE ALLOWABLE LATERAL LOAD OF EITHER THE FASTENER OR MOUNTING DEVICE OR THE SUPPORTING STRUCTURE, WHICHEVER IS THE SMALLER ALLOWABLE LOAD
 (D) TENSILE FORCE INDUCED IN A FASTENER BY A DIRECT TENSION FORCE OF 250 LBS (112 N) PLUS THE MAXIMUM MOMENT FROM THE APPLICATION OF 250 LBS (112 N) SHALL BE LESS THAN THE ALLOWABLE WITHSTAND LOAD BETWEEN THE FASTENER AND THE SUPPORTING STRUCTURE
 (E) GRAB BARS SHALL NOT ROTATE WITHIN THEIR FITTINGS
 6. A HANDRAIL OR GRAB BAR AND ANY WALL OR OTHER SURFACE ADJACENT TO IT SHALL BE FREE OF ANY SHARP OR ABRASIVE ELEMENTS. EDGES SHALL HAVE A MINIMUM RADIUS OF 1/8 INCH (3.2 MM)

SIGN & IDENTIFICATION
 1. ALL DOORS TO ACCESSIBLE TOILET ROOMS SHALL COMPLY WITH SECTION 11-4.13. DOORS SHALL NOT SWING INTO THE CLEAR FLOOR SPACE REQUIRED FOR ANY FUTURE
 2. THE ACCESSIBLE TOILET ROOMS AND CONTROLS REQUIRED IN SECTIONS 11-4.2.4, 11-4.2.5, 11-4.2.6 AND 11-4.2.7 SHALL BE ON AN ACCESSIBLE ROUTE. AN UNRESTRICTED TURNING SPACE COMPLYING WITH SECTION 11-4.2.3 SHALL BE PROVIDED WITHIN AN ACCESSIBLE TOILET ROOM. THE CLEAR FLOOR SPACE AT FUTURE AND CONTROLS, THE ACCESSIBLE ROUTE, AND THE TURNING SPACE MAY OVERLAP
 3. IF TOILET STALLS ARE PROVIDED, THEN AT LEAST ONE SHALL BE A STANDARD TOILET STALL COMPLYING WITH SECTION 11-4.17, WHERE SIX OR MORE STALLS ARE PROVIDED. IN ADDITION TO THE STALL COMPLYING WITH SECTION 11-4.17, AT LEAST ONE SHALL BE 36 INCHES WIDE WITH AN OUTRIM SWINGING, SELF-CLOSING DOOR AND PARALLEL GRAB BARS COMPLYING WITH SECTION 11-4.26 SHALL BE PROVIDED. WATER CLOSETS IN SUCH STALLS SHALL COMPLY WITH SECTION 11-4.16. IF WATER CLOSETS ARE NOT IN STALLS, THEN AT LEAST ONE SHALL COMPLY WITH SECTION 11-4.16
 4. IF URINALS ARE PROVIDED, THEN AT LEAST ONE SHALL COMPLY WITH SECTION 11-4.19
 5. IF LAVATORIES AND MIRRORS ARE PROVIDED, THEN AT LEAST ONE OF EACH SHALL COMPLY WITH SECTION 11-4.19
 6. IF CONTROLS, DISPENSERS, RECEPTACLES, OR OTHER EQUIPMENT ARE PROVIDED, THEN AT LEAST ONE OF EACH SHALL BE ON AN ACCESSIBLE ROUTE AND SHALL COMPLY WITH SECTION 11-4.27

CHARACTERS AND IDENTIFICATION
 1. THE CHARACTERS AND BACKGROUND OF SIGNS SHALL BE EGG-SHELL, MATTE, OR OTHER NONGLARE FINISH. CHARACTERS AND SYMBOLS SHALL CONTRAST WITH THEIR BACKGROUND—EITHER LIGHT CHARACTERS ON A DARK BACKGROUND OR DARK CHARACTERS ON A LIGHT BACKGROUND
 2. WHERE PERMANENT IDENTIFICATION IS PROVIDED FOR ROOMS AND SPACES, SIGNS SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH SIDE OF THE DOOR WHERE THERE IS NO WALL SPACE TO THE LATCH SIDE OF THE DOOR. INCLUDING THE LOCATION OF THE NEAREST TOILET TELEPHONE SHALL BE ADJACENT TO ALL BANKS OF TELEPHONES WHICH DO NOT CONTAIN A TEXT TELEPHONE. SUCH DIRECTIONAL SIGNAGE SHALL INCLUDE THE INTERNATIONAL TDD SYMBOL, IF A FACILITY HAS NO BANKS OF TELEPHONES, THE DIRECTIONAL SIGNAGE SHALL BE PROVIDED AT THE ENTRANCE (E.G., IN A BUILDING DIRECTORY)
 3. ASSISTIVE LISTENING SYSTEMS IN ASSEMBLY AREAS WHERE PERMANENTLY INSTALLED ASSISTIVE LISTENING SYSTEMS ARE REQUIRED BY SECTION 11-4.1.3 (1)(B) THE AVAILABILITY OF SUCH SYSTEMS SHALL BE IDENTIFIED WITH SIGNAGE THAT INCLUDES THE INTERNATIONAL SYMBOL OF ACCESS FOR HEARING LOSS

Order Plans

AMC

AMC MADISON YARDS 8
 AMC NEW BUILD
 906 MEMORIAL DR SE
 ATLANTA, GA 30316

KEY PLAN:

1	4	5
2	3	8

SHEET TITLE:
ACCESSIBILITY NOTES

SHEET NUMBER:
N120



SHEET LEGEND

0001 GENERAL INFORMATION & SCHEDULES OF WORK
 1000 GENERAL ARCHITECTURAL DETAILS
 1100 FLOOR PLANS & CEILING PLANS
 1200 EXTERIOR & INTERIOR ELEVATIONS
 1300 BUILDING SECTIONS
 1400 BUILDING SECTIONS
 1500 EXTERIOR & INTERIOR DETAILS
 1600 ROOF SCHEDULES, ROOF DETAILS
 1700 STAIR SCHEDULES, STAIR DETAILS
 1800 AUDITORIUM SEATING LINE SECTIONS
 1900 AUDITORIUM SEATING LINE SECTIONS

20 STRUCTURAL
 21 MECHANICAL
 22 ELECTRICAL
 23 PLUMBING
 24 HEATING, VENTILATION & AIR CONDITIONING
 25 SAFETY & SECURITY
 26 FURNITURE, FIXTURES & EQUIPMENT
 27 PLANTING