

SLEEVES AND FIRESTOPPING: USE PROSET "FIRESTOP PENETRATORS" OR APPROVED EQUIVALENT. U.L. CLASSIFIED IN THE BUILDING MATERIALS DIRECTORY, TESTED BY ASTM E-814. USE FOR ALL APPLICABLE PIPE PENETRATIONS THRU FIRE RATED FLOORS, WALLS OR FLOOR/CEILING ASSEMBLIES IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS.

A. SYSTEM "A": PENETRATORS FOR WATER LINES, HEATING AND COOLING LINES, FIRE STANDPIPE AND SPRINKLER LINES, TEMPERATURE CONTROL, ACID WASTE GLASS PIPE AND ELECTRIC AND COMMUNICATION CONDUIT PENETRATING FLOORS AND WALLS.

1. CAST-IN-PLACE PENETRATORS FOR POURED-IN-PLACE CONCRETE ON STEEL OR WOOD FORMS IN FLOORS AND WALLS.
2. CORE HOLE COUPLING PENETRATORS FOR CORED HOLES THRU PRECAST OR EXISTING CONCRETE IN FLOORS OR WALLS.
3. SPLIT WALL SLEEVE PENETRATORS FOR PIPES PASSING THRU GYPSUM WALLS OR FLOOR/CEILING ASSEMBLIES.

FIRESTOP PENETRATION DETAILS

NOT TO SCALE



NOTES:
1.) REFER TO SCHEDULES AND SPECIFICATIONS FOR SIZE OF ELECTRIC WATER HEATER AND CIRCULATION PUMP.
2.) ARRANGEMENT SHOWN IS SCHEMATIC. ADJUST TO SUIT FIELD CONDITIONS. REFER TO FLOOR PLAN FOR PIPE SIZES.
3.) SET WATER HEATER THERMOSTAT AT 140°F.
4.) PROVIDE SEISMIC STRAP OR BRACING AND FLEXIBLE CONNECTORS TO WATER CONNECTIONS IF/AS REQUIRED BY LOCAL AUTHORITIES.

ELECTRIC WATER HEATER AND EXPANSION TANK

NOT TO SCALE



NOTE:
ARRANGEMENT SHOWN IS SCHEMATIC. MODIFY AS REQUIRED TO SUIT CONDITIONS. INSTALL WITHIN CASEWORK BELOW COFFEE MAKER. VALVING SHALL BE SAME SIZE AS SERVICE PIPE REFER TO PLANS FOR SERVICE LINE SIZE. PROVIDE BACKFLOW PREVENTER (BFP) OF TYPE & MANUFACTURED APPROVED BY LOCAL AUTHORITIES AND DEPARTMENT OF NATURAL RESOURCES. INSTALL BACKFLOW PREVENTER IN HORIZONTAL UPRIGHT POSITION. PROVIDE ALL NECESSARY PLUMBING TO CONNECT FILTER SYSTEM ABOVE BFP. CLEAN STRAINER BEFORE TURNING BUILDING OVER TO OWNER. PROVIDE ANY REQUIRED CERTIFICATION OF TEST OF BACKFLOW PREVENTER TO LOCAL AUTHORITIES.

BACKFLOW PREVENTER INSTALLATION DETAIL - COFFEE MAKER

NOT TO SCALE



ROOF HYDRANT DETAIL

NOT TO SCALE



NOTE:
ROUTE PIPE INCONSPICUOUSLY AND UNOBTRUSIVELY. HANG PIPE AS REQUIRED. DO NOT INSULATE INDIRECT DRAIN PIPE WHEN INSTALLED EXPOSED IN FOOD SERVICE FACILITY. REFER TO LOCAL CODES FOR FURTHER INFORMATION.

INDIRECT DRAIN DETAIL

NOT TO SCALE



PDI SIZE	PIPE SIZE	FIXTURE UNIT LOAD
A	1/2"	1-11
B	3/4"	12-32
C	1"	33-60
D	1 1/4"	61-113
E	1 1/2"	114-154
F	2"	154-330

FIXTURE UNIT TABULATION		
FIXTURE	COLD	HOT
VALVE WATER CLOSET	10	--
TANK WATER CLOSET	5	--
URINAL	5	--
LAVATORY/SINK	1.5	1.5
JANITOR'S SINK	3	3
SHOWER/BATHTUB	2	2

NOTE:
PROVIDE WATER HAMMER ARRESTERS (WHA) BY SIOUX CHIEF, PRECISION PLUMBING PRODUCTS, WATTS OR APPROVED EQUIVALENT WITH PISTON AND O-RING CONSTRUCTION, HAVING PDI WHA-201, ASSE #1010 AND ANSI #A112.26.1M CERTIFICATION. INSTALL IN HORIZONTAL OR VERTICAL POSITION, BUT NEVER UPSIDE DOWN. INSTALL IN LINE WITH WATER FLOW DIRECTION IF POSSIBLE. SIZE THE UNITS AS SHOWN ON THE DRAWINGS AND/OR PER THE TABLES SHOWN ABOVE. INSTALL IN AN ACCESSIBLE LOCATION (ABOVE LAY-IN IS ACCEPTABLE) AND PER PDI STANDARDS AND MANUFACTURER'S INSTRUCTIONS.

WATER HAMMER ARRESTERS DETAIL

NOT TO SCALE



GLASS WASHER CONNECTION DETAIL

NOT TO SCALE



NOTE:
VERIFY REQUIREMENTS FOR METERING AND PIPING WITH GAS COMPANY. GAS COMPANY SHALL EXCAVATE, BACKFILL, AND REPAIR PAVING AND SOD FOR GAS SERVICE LINE INSTALLATION FROM MAIN TO BUILDING. PLUMBING CONTRACTOR TO PAY ALL GAS COMPANY FEES FOR THIS INSTALLATION. USE WELDED OR SCREWED PIPE AND FITTINGS PER SPECIFICATIONS. PAINT EXPOSED METAL GAS PIPE, FITTINGS AND ITEMS LIGHT GREEN.

GAS SERVICE DETAIL

NOT TO SCALE



NOTE:
REFER TO PLANS FOR PIPE SIZE(S) AND LOCATION(S). USE WELDED OR SCREWED FITTINGS AS SPECIFIED FOR PIPE SIZE. LOCATE PENETRATION MINIMUM 18" FROM ADJACENT WALLS. PRIMER COAT AND PAINT EXTERIOR GAS PIPE YELLOW COLOR.

PIPE ROOF PENETRATION DETAIL

NOT TO SCALE



NOTE:
PROVIDE FIBERGLASS INSULATION WITH ALL-SERVICE JACKET WITH VAPOR BARRIER ON ALL COLD/HOT WATER PIPING AND CONDENSATE DRAIN PIPE. REFER TO SPECIFICATIONS FOR FURTHER INFORMATION REGARDING INSULATION. INSTALL INSULATION AS ALL ITEMS PER SPECIFICATIONS AND MANUFACTURER'S INSTRUCTIONS. MAINTAIN VAPOR BARRIER ON COLD PIPING BY MEANS OF SEALANT AND TAPE. FLAME-SPREAD AND SMOKE-DEVELOPED INDEXES SHALL NOT EXCEED 25/50. SEAL EXPOSED ENDS OF FIBERGLASS INSULATION WITH ADHESIVE MASTIC.

PIPE INSULATION DETAIL

NOT TO SCALE



NOTE:
PROVIDE UPPER ATTACHMENT AS REQUIRED FOR CASES NOT SHOWN HERE. DO NOT INSTALL HANGER INSIDE INSULATION OR OTHERWISE PENETRATE VAPOR BARRIER. DO NOT HANG ONE PIPE FROM ANOTHER EXCEPT IN CHASES. TRAPEZE HANGERS MAY BE USED FOR MULTIPLE PARALLEL PIPES.
HANGER SPACING FOR PIPE SIZE:
COPPER: 4"=9'; 3"=11'; 2 1/2"=10'; 2"=9'; 1 1/2"=8'; 1 1/4"=7'; 1"=6' ;3/4"=6'; 1/2"=5'.
CAST IRON: 10' AND ONE NEAR ALL JOINTS.
STEEL: 4"=14'; 3"=12'; 2-1/2"=11'; 2"=10'; 1 1/2"=9'; 1"=7'; 3/4"=6'; 1/2"=5'.
LOCATE HANGERS AS CLOSE AS POSSIBLE TO TURNS AND TEES OF PIPE. PROVIDE SUPPLEMENTARY STEEL STRUTS BETWEEN JOISTS IF REQUIRED.
LOCATE HANGERS TO TAKE LOAD OFF OF EQUIPMENT CONNECTIONS. ANCHOR WATER PIPE AGAINST SWAYING DUE TO CHANGES IN WATER VELOCITY. PROVIDE SEISMIC BRACING IF/AS REQUIRED BY LOCAL AUTHORITIES. CHAINS OR PERFORATED STRAP IRON OR STEEL IS NOT ACCEPTABLE. REFER TO CODES AND SPECIFICATIONS FOR FURTHER INFORMATION.

PIPE HANGERS DETAIL

NOT TO SCALE



NOTE:
PIPING ARRANGEMENT SHOWN IS SCHEMATIC. ADJUST AS REQUIRED.

MAKEUP AIR UNIT CONNECTION DETAIL

NOT TO SCALE



NOTE:
ARRANGEMENT SHOWN IS SCHEMATIC. ADJUST AS REQUIRED.

ROOFTOP UNIT CONNECTION DETAIL

NOT TO SCALE



NOTE:
SUPPORT SPACING FOR PIPE SIZE: 1/2"=6'; 3/4"-1"=8'; 1 1/4"AND LARGER=10'; PLACE DECK PLATES ON ROOFING, SET PIPE STAND FREE ON DECK PLATES. STACK PIPE STAND WHERE REQUIRED TO ELEVATE PIPING. INSTALL GAS PIPE TO ALLOW FOR EXPANSION AND CONTRACTION. PRIMER COAT AND PAINT EXTERIOR GAS PIPE YELLOW COLOR.

ROOF BLOCKING PIPE SUPPORT DETAIL

NOT TO SCALE



NOTE:
ARRANGEMENT SHOWN IS SCHEMATIC. MODIFY AS REQUIRED TO SUIT CONDITIONS OF NUMBER OF AND TYPE OF BFP ARE REQUIRED. DO NOT INSTALL VALVE TRAIN ABOVE ELECTRICAL EQUIPMENT. VALVING SHALL BE SAME SIZE AS SERVICE PIPE REFER TO PLANS FOR SERVICE LINE SIZE. NUMBER AND TYPE OF BACKFLOW PREVENTER WILL VARY FROM PLACE TO PLACE, REFER TO PLAN FOR SIZE. PROVIDE BACKFLOW PREVENTER (BFP) OF TYPE AND MANUFACTURED APPROVED BY LOCAL AUTHORITIES AND DEPARTMENT OF NATURAL RESOURCES. INSTALL BACKFLOW PREVENTER IN HORIZONTAL UPRIGHT POSITION. PROVIDE ALL NECESSARY PLUMBING TO CONNECT FILTER SYSTEM ABOVE BFP. CLEAN STRAINER BEFORE TURNING BUILDING OVER TO OWNER. PROVIDE ANY REQUIRED CERTIFICATION OF TEST OF BACKFLOW PREVENTER TO LOCAL AUTHORITIES.

BACKFLOW PREVENTER INSTALLATION DETAIL - ICE UNITS

NOT TO SCALE



NOTE:
ARRANGEMENT SHOWN IS SCHEMATIC. MODIFY AS REQUIRED TO SUIT CONDITIONS OF NUMBER OF AND TYPE OF BFP ARE REQUIRED. DO NOT INSTALL VALVE TRAIN ABOVE ELECTRICAL EQUIPMENT. VALVING SHALL BE SAME SIZE AS SERVICE PIPE REFER TO PLANS FOR SERVICE LINE SIZE. NUMBER AND TYPE OF BACKFLOW PREVENTER WILL VARY FROM PLACE TO PLACE, REFER TO PLAN FOR SIZE. PROVIDE BACKFLOW PREVENTER (BFP) OF TYPE AND MANUFACTURED APPROVED BY LOCAL AUTHORITIES AND DEPARTMENT OF NATURAL RESOURCES. INSTALL BACKFLOW PREVENTER IN HORIZONTAL UPRIGHT POSITION. PROVIDE ALL NECESSARY PLUMBING TO CONNECT FILTER SYSTEM ABOVE BFP. CLEAN STRAINER BEFORE TURNING BUILDING OVER TO OWNER. PROVIDE ANY REQUIRED CERTIFICATION OF TEST OF BACKFLOW PREVENTER TO LOCAL AUTHORITIES.

BACKFLOW PREVENTER INSTALLATION DETAIL - CARBONATED BEVERAGE UNITS

NOT TO SCALE

THIS DRAWING IS A PRODUCT OF MY INTELLECTUAL EFFORT AND IS PROTECTED BY COPYRIGHT. ANY UNAUTHORIZED USE, REPRODUCTION OR DISTRIBUTION IS PROHIBITED BY LAW. IT IS NOT TO BE ALTERED OR USED ON ANY OTHER PROJECT WITHOUT THE EXPRESS WRITTEN CONSENT OF GDS ENGINEERING, LLC. ANY UNAUTHORIZED USE OF THIS DRAWING WILL RESULT IN LEGAL ACTION AGAINST THE PARTY RESPONSIBLE FOR SUCH USE. THE ARCHITECT/ENGINEER SHALL NOT BE RESPONSIBLE FOR ALL AS-BUILT DRAWINGS. ALL AS-BUILT DRAWINGS ARE THE SOLE RESPONSIBILITY OF THE CONTRACTOR WHO IS RESPONSIBLE FOR THE INFORMATION SHOWN ON THEM. THE CONTRACTOR SHALL NOTIFY THE ARCHITECT/ENGINEER OF ANY DISCREPANCIES BETWEEN THE AS-BUILT DRAWINGS AND THE ACTUAL CONDITIONS AS CONSTRUCTED. THE CONTRACTOR SHALL ALSO BE RESPONSIBLE FOR THE ACCURACY OF THE AS-BUILT DRAWINGS. THE ARCHITECT/ENGINEER SHALL NOT BE RESPONSIBLE FOR ANY DEVIATIONS FROM THE CONSTRUCTION DOCUMENTS THAT ARE NOT REFLECTED ON THE AS-BUILT DRAWINGS. ANY CHANGES IN THE CONSTRUCTION DOCUMENTS MADE ON THE JOB SITE SHALL BE CLEARLY NOTED ON THE AS-BUILT DRAWINGS BY THE CONTRACTOR.

Order Plans @ WWW.DILine.com

GEORGIA REGISTERED No. PE023466 PROFESSIONAL ENGINEER TIM L. SCOTT

SIGNATURE: DATE: 2-21-12

GDS ENGINEERING

Gibbens, Drake, Scott, Inc.
9201 E. 63rd Street, Suite 100
Raytown, Missouri 64133
Phone: (816) 358-1760
Fax: (816) 358-2367
www.gdsengr.com
GEORGIA COA #PEENG063

SHEET LEGEND

G000	GENERAL INFORMATION & SCOPE OF WORK
A100	EGRESS / ADA PLANS & DETAILS
A101	FLOOR PLANS & CEILING PLANS
A200	EXTERIOR & INTERIOR ELEVATIONS
A300	BUILDING SECTIONS
A400	ENLARGED PLANS
A500	DOOR & WINDOW DETAILS
A600	DOOR SCHEDULE, DOOR DETAILS, FINISH SCHEDULE, FINISH PLANS
G000	AUDITORIUM SIGHT LINE SECTIONS
G120	AUDITORIUM SEATING PLAN
S1	STRUCTURAL
M1	MECHANICAL
P1	PLUMBING
E1	ELECTRICAL
FP1	FIRE PROTECTION
WF1	WAYFINDING DETAILS
FS1	FOODSERVICE EQUIPMENT

MADISON YARDS 8

AMC NEW BUILD
905 MEMORIAL DRIVE SE
ATLANTA, GA 30316

amc

American Multi-Cinema, Inc.
One AMC Way
11500 Ash Street
Leawood, KS 66211

No.	Date	Description

Project Issue Date:

KEY PLAN

SHEET TITLE:
PLUMBING DETAILS

SHEET NUMBER:
P001