



FIRE ALARM GENERAL NOTES

- A. ALL CONDUIT INSTALLED INDOORS SHALL BE ELECTRICAL METALLIC TUBING (EMT), MINIMUM 1/2".
- B. THE CONTRACTOR SHALL FURNISH ALL LABOR, MATERIALS, TOOLS, EQUIPMENT AND PERFORM ALL WORK AND SERVICES NECESSARY FOR OR INCIDENTAL TO THE FURNISHING AND INSTALLATION, COMPLETE, OF ALL WIRING MATERIALS AND METHODS AS SHOWN ON THE DRAWINGS AND AS SPECIFIED, IN ACCORDANCE WITH PROVISIONS OF THE CONTRACT DOCUMENTS AND COMPLETELY COORDINATED WITH WORK OF ALL OTHER TRADES.
- C. ALL EMPTY CONDUITS SHALL BE PROVIDED WITH PULL STRING INSTALLED AND PLASTIC GROMMET.
- D. THE CONTRACTOR TO VERIFY EXACT PLACEMENT OF ALL DEVICES SHOWN ON THE ELECTRICAL CONSTRUCTION DOCUMENTS WITH MECHANICAL DRAWINGS PRIOR TO FINAL PLACEMENT.
- E. ALL OPENINGS SLEEVED THROUGH FLOOR CONSTRUCTION, FIRE WALLS OR PARTITIONS, SHALL BE SEALED WITH AN APPROVED SEALANT HAVING FIRE RATING EQUAL TO THAT OF STRUCTURAL MEMBER PENETRATED.
- F. PROVIDE TRANSIENT PROTECTION TO REDUCE THE POSSIBILITY OF REDUCED TRANSMITS, CIRCUITS AND EQUIPMENT SHALL BE PERMITTED IN ACCORDANCE WITH THE REQUIREMENTS OF ARTICLE 905 OF THE NATIONAL ELECTRICAL CODE.
- G. THE CIRCUIT BREAKERS FOR THE FIRE ALARM SYSTEM SHALL BE A RED MARKING AND SHALL BE IDENTIFIED AS "FIRE ALARM CIRCUIT".
- H. THE LOCATION OF THE CIRCUIT BREAKER SHALL BE PERMANENTLY MARKED ON THE FIRE ALARM CONTROL UNIT.
- I. ANY DEVICE OR SYSTEM THAT AUTOMATICALLY LOCKS OR UNLOCKS OF EXITS SHALL BE CONNECTED TO THE FIRE ALARM SYSTEM BY THE CONTRACTOR UNLOCK UPON RECEIPT OF A FIRE ALARM SIGNAL BY MEANS OF A RELAY.
- J. ALL FIRE ALARM DEVICES SHALL BE WITHIN 5'0" OF THE DOORWAY OR IN A COMMON AREA.
- K. ALL FIRE ALARM HORNS OR BELLS LOCATED IN THE SAME ROOM OR OPEN OFFICE SHALL BE SOUNDING TO FLASH AT THE SAME RATE PER LATEST FIRE ALARM CODE.

FIRE ALARM PLAN NOTES

- 1. INSTALL A FIRE ALARM OUTPUT DEVICE THAT WILL CLOSE DRY CONTACTS WHEN THE FIRE ALARM SYSTEM GOES INTO ALARM. THE CONTACTS WILL OPEN WHEN THE FIRE ALARM SYSTEM IS CLEARED AND THE SYSTEM IS RESET. THE DEVICE SHALL CONTAIN TWO SEPARATE CONTACTS. WIRE ONE SET INTO THE PROJECTION AUTOMATION PANEL AND THE OTHER SET INTO THE AUDITORIUM DAMING PANEL.

DATE: _____
 SIGNATURE: _____

ENGINEERING
 Gilbert, Drake, Scott, Inc.
 4209 E. 67th Street, Suite 100
 Raytown, Missouri 64133
 Phone: (816) 334-1759
 Fax: (816) 334-2007
 www.gds-engine.com
 GDS ENGINEERS & ARCHITECTS

SHEET LEGEND	
0000	GENERAL INFORMATION & SCHEDULES
1000	FLOOR PLANS & DETAILS
2000	EXTERIOR & INTERIOR ELEVATIONS
3000	BUILDING SECTIONS
4000	INTERIOR & EXTERIOR DETAILS
5000	MECHANICAL
6000	ELECTRICAL
7000	PLUMBING
8000	MECHANICAL
9000	HAZARDOUS WASTE
9900	DATE

MADISON YARDS 8
 AMC NEW BUILD
 905 MEMORIAL DRIVE SE
 ATLANTA, GA 30316



No.	Date	Description

Project Issue Date: _____

KEY PLAN:

SHEET TITLE:
PROJECTION LEVEL AREA-A FIRE ALARM PLAN

SHEET NUMBER:
F103

PROJECTION LEVEL AREA A FIRE ALARM PLAN
 1/8" = 1'-0"

THIS DRAWING IS A PORTION OF A CONTRACT DOCUMENTS AND IS TO BE USED ONLY IN CONNECTION WITH THE CONTRACT DOCUMENTS. THIS DRAWING AND THE CONTRACT DOCUMENTS SHALL BE KEPT AT THE PROJECT SITE UNTIL THE PROJECT IS COMPLETED. ANY CHANGES TO THIS DRAWING SHALL BE MADE IN ACCORDANCE WITH THE PROVISIONS OF THE CONTRACT DOCUMENTS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR OBTAINING ACCESS TO ALL AREAS WHERE WORK IS TO BE PERFORMED. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ACCESS TO ALL AREAS WHERE WORK IS TO BE PERFORMED. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ACCESS TO ALL AREAS WHERE WORK IS TO BE PERFORMED.

Order Plans @

WWW.DIline.com