



PROJECTION LEVEL AREA B FIRE ALARM PLAN
1/8" = 1'-0"

FIRE ALARM GENERAL NOTES

- A. ALL CONDUIT INSTALLED IN DOORS SHALL BE ELECTRICAL METALLIC TUBING (EMT), MINIMUM 1/2".
- B. THE CONTRACTOR SHALL FURNISH ALL LABOR, MATERIALS, TOOLS, EQUIPMENT AND PERFORM ALL WORK AND SERVICES NECESSARY FOR OR INCIDENTAL TO THE FURNISHING AND INSTALLATION, COMPLETE OF ALL WORKING MATERIALS AND METHODS AS SHOWN ON THE DRAWINGS AND AS SPECIFIED, IN ACCORDANCE WITH PROVISIONS OF THE CONTRACT DOCUMENTS AND COMPLETELY COORDINATED WITH WORK OF ALL OTHER TRADES.
- C. ALL EMPTY CONDUITS SHALL BE PROVIDED WITH PULL STRING INSTALLED AND PLASTIC GROMMET.
- D. THE CONTRACTOR TO VERIFY EXACT PLACEMENT OF ALL DEVICES SHOWN ON THE ELECTRICAL CONSTRUCTION DOCUMENTS WITH MECHANICAL DRAWINGS PRIOR TO FINAL PLACEMENT.
- E. ALL OPENINGS SLEEVED THROUGH FLOOR CONSTRUCTION, FIRE WALLS OR SMOKING PARTITIONS, SHALL BE SEALED WITH AN APPROVED SEALANT HAVING FIRE RATING EQUAL TO THAT OF STRUCTURAL MEMBER PENETRATED.
- F. PROVIDE TRANSPARENT PROTECTION TO REDUCE THE POSSIBILITY OF INDUCED TRANSIENTS, CIRCUITS AND EQUIPMENT SHALL BE INSTALLED IN ACCORDANCE WITH THE REQUIREMENTS OF ARTICLE 68 OF THE NATIONAL ELECTRICAL CODE.
- G. THE CIRCUIT BREAKERS FOR THE FIRE ALARM SYSTEM SHALL BE Labeled WITH A RED MARKING AND SHALL BE IDENTIFIED AS "FIRE ALARM CIRCUIT".
- H. THE LOCATION OF THE CIRCUIT BREAKER SHALL BE PERMANENTLY MARKED ON THE FIRE ALARM CONTROL UNIT.
- I. ANY DEVICE OR SYSTEM WHICH OPERATES TO LOCK OR UNLOCKING OF ENTRY SHALL BE CONNECTED TO THE FIRE ALARM SYSTEM BY WIRING CONNECTED TO THE FIRE ALARM SYSTEM BUS OR TO A COMMON BUS BY FIRE ALARM SIGNAL BY WIRING TO THE FIRE ALARM SYSTEM.
- J. ALL FIRE ALARM DEVICES SHALL BE WITHIN 8'-0" OF THE DOORWAY OR THE POINT OF ENTRY TO THE ROOM AND ACCESSIBLE AT EACH EXIT ON EACH FLOOR.
- K. ALL FIRE ALARM DEVICES LOCATED IN THE SAME ROOM OR OPEN OFFICE AREA SHALL BE FLASHED AT THE SAME RATE PER LATEST FIRE ALARM CODE.
- L. THE CONTRACTOR SHALL BE RESPONSIBLE FOR INCLUDING THE COST OF ALL REQUIRED 120 VOLT CIRCUITS REQUIRED FOR THE FIRE ALARM CONTROL PANEL, SUPPLEMENTAL POWER SUPPLY PANELS, XTRAL/SVEDIA PANELS AND ALL OTHER FIRE ALARM SYSTEM REQUIRED TO 120 VOLT CIRCUITS.

FIRE ALARM PLAN NOTES

- 1. INSTALL A FIRE ALARM OUTPUT DEVICE THAT WILL CLOSE DRY CONTACTS WHEN THE FIRE ALARM SYSTEM GOES INTO ALARM. THE CONTACTS WILL OPEN WHEN THE FIRE ALARM SYSTEM IS CLEARED AND THE SYSTEM IS RESET. THE DEVICE SHALL CONTAIN TWO SEPARATE CONTACTS. WIRE ONE SET INTO THE DETECTOR AUTOMATION PANEL AND THE OTHER SET INTO THE AUDITORIUM DIMMING PANEL.

GEORGIA REGISTERED PROFESSIONAL ENGINEER
W. L. SCOTT, III
SIGNATURE: _____
DATE: _____
ENGINEERING
Clibbens, Drake, Scott, Inc.
9250 E. 4th Street, Suite 150
Kennesaw, Missouri 64133
Phone: 404.335.1790
Fax: 404.335.1347
www.cdengineering.com
GEORGIA LICENSE # 17570-1

SHEET LEGEND
0000 GENERAL INFORMATION & SCOPE OF WORK
1000 FLOOR PLANS & CEILING PLANS
2000 ELECTRICAL & MECHANICAL EQUIPMENT
3000 BUILDING SECTIONS
4000 DOOR SCHEDULES & DETAILS
5000 WINDOW & SILLING DETAILS
6000 DOOR SCHEDULES, DOOR DETAILS
6070 ACCESSIBLE DOOR SCHEDULES
6075 ACCESSIBLE DOOR SCHEDULES
7000 MECHANICAL
8000 PLUMBING
9000 ELECTRICAL
9075 WARMWATER SCHEDULES
9076 WARMWATER EQUIPMENT

MADISON YARDS 8
AMC NEW BUILD
905 MEMORIAL DRIVE SE
ATLANTA, GA 30316

amc
American Multi-Cinema, Inc.
One AMC Way
11500 Ash Street
Leawood, KS 66211

No.	Date	Description

Project Issue Date: _____

KEY PLAN:

**PROJECTION LEVEL AREA-B
FIRE ALARM
PLAN**

SHEET NUMBER:
F104

Order Plans @