






- LEGEND:
- ⊕ = PART NUMBER; SEE SHEET F-1
 - # = KEYNOTE; SEE SHEET F-1
 - ⊞ = CONDUIT; SEE SHEET FE-1
 - ⊞-# = DETAIL CALLOUT
 - ⊞-# = ELEVATION CALLOUT
 - ⊞-# = SECTION CALLOUT




CONDUIT TABLE

E1	3/4" CONDUIT FOR EMERGENCY STOP
E2	3/4" CONDUIT FOR EMERGENCY STOP
1	3/4" CONDUIT FOR ICE MACHINE
2	3/4" CONDUIT FOR AIR/VAC MACHINE
3	3/4" CONDUIT FOR SIGN CONTROLLER ON FACE OF COLUMN (POWER)
4	3/4" CONDUIT FOR SIGN CONTROLLER ON FACE OF COLUMN (CONTROL)
5	1" CONDUIT FOR DISPENSER POWER/COMMUNICATION (TYP. EA. DISPENSER)
6	3/4" CONDUIT FOR SUBMERSIBLE TURBINE PUMP POWER (TYP. EACH SUMP)
7	1" CONDUIT FOR CANOPY CIRCUITS (INSIDE COLUMN)
8	1" CONDUIT FOR SECURITY (INSIDE COLUMN)
9	3/4" CONDUIT FOR ETHERNET (TYP. EACH DISPENSER)
10	3/4" CONDUIT FOR SUMP SENSOR (TYP. EACH DISPENSER)
11	3/4" CONDUIT FOR INTERCOM (TYP. EACH DISPENSER)
12	3/4" CONDUIT FOR SUMP SENSOR/GALGE (TYP. EACH SUMP)
13	3/4" CONDUIT FOR INTERSTITIAL MONITOR (LOOPED BETWEEN INTERSTITIAL)
14	3/4" CONDUIT FOR ATG (TYP. EACH SUMP)
15	1" CONDUIT FOR ENTERTAINMENT SYSTEM/SATELLITE SYSTEM (INSIDE COLUMN)
16	3/4" CONDUIT FOR ATM (IF APPLICABLE - SEE BUILDING PLANS)
17	2" CONDUIT FOR P.O.S. (CASHIER AREA)
18	1" CONDUIT FOR MONUMENT/PYLON SIGN (POWER FOR 2-120V CIRCUITS)
19	1" CONDUIT FOR MONUMENT/PYLON SIGN (CONTROL)
20	TELEPHONE MAIN
21	INTERNET SERVICES
22	ELECTRICAL MAIN
23	3/4" CONDUIT FOR SITE POLE LIGHTS
24	1" CONDUIT FOR IRRIGATION SYSTEM (CONTROL)

THE POWER INTEGRITY CORPORATION "LOW VOLTAGE DISCONNECT SYSTEM" SHALL BE POWERED FROM A DUPLEX RECEPTACLE FED FROM THE FUEL PANEL TO ENSURE RECEPTACLE POWER LOSS IF ANY EMERGENCY STOP SWITCH IS ACTIVATED PER NEC 514. FIELD VERIFY QUANTITY OF DUPLEX RECEPTACLES REQUIRED.

ALL EXTERIOR LIGHTS, EXTERIOR SIGNS, AND DISPENSERS TO BE CIRCUITED THROUGH THE MMB BOX. ALL PRICE SIGNS TO HAVE ADDITIONAL CONDUITS FOR CONTROLLER.



CONDUIT PLAN

DATE: MARCH, 2018	SCALE: AS NOTED	FILE NAME: 15-Mcc800616_FE-1
No. 1	REVISION	DATE: 5/30/2018
1	OTB SET: UPDATED PER REVISED SITE	

GREENWOOD SOUTH CAROLINA
508 SC - 72

Galloway
Planning, Architecture, Engineering
6162 S. Willow Drive, Suite 300
Greenwood Village, CO 80111
303.770.3800
www.gallowayus.com



MURPHY USA
MURPHY OIL U.S.A. INC.
200 EAST PEACH STREET
EL DORADO, ARKANSAS 71730

Order Plans @ WWW.LDLine.com