

NOTES:
1. USE THREADED ROD FOR ALL DUCTS LARGER THAN 60"Ø WIDE.
2. SHEET METAL SCREWS MAY BE OMITTED IF HANGER STRAP IS CONTINUOUS AND LOOPS UNDER ENTIRE DUCT.
3. CONNECTIONS TO SLAB OR DECKING ABOVE ARE NOT PERMITTED.

4 RECTANGULAR DUCT SUPPORT DETAIL
NTS



NOTES:
1. EXTEND RIGID METAL DUCT SO THAT MAXIMUM FLEXIBLE DUCT LENGTH DOES NOT EXCEED 5'-0". PROVIDE RIGID 90° ELBOW WHERE REQUIRED TO KEEP FLEXIBLE DUCT WITHIN 5'-0" LENGTH LIMITATION.

3 LAY-IN CEILING DIFFUSER DETAIL
NTS



2 DOWNBLAST EXHAUST FAN DETAIL
NTS



NOTES:
1. CUT OPENING IN SHEETMETAL DUCT ACCURATELY. INSTALL 45° LATERAL TO AVOID VISIBLE OPENINGS AND SECURE FITTING SUITABLY FOR PRESSURE CLASS.
2. INSTALL FLEXIBLE DUCT IN AS STRAIGHT A RUN AS POSSIBLE. USE LONG RADIUS BENDS WHERE POSSIBLE. PULL DUCT TIGHT AT BOTH ENDS AND SECURE BOTH INNER LINER & OUTER INSULATION SKIN WITH TAPE & METAL CLAMPS.
3. EXTEND DAMPER ROD TO ACCOMMODATE INSULATION IF APPLICABLE. PROVIDE END TO EDGE OF DUCTWORK AS REQUIRED AND SEAL TO MAINTAIN VAPOR BARRIER.
4. INSTALL LOCKING QUADRANT TO HANDLE ON BOTTOM OF DUCT FOR EASY SERVICE.

45° LATERAL FLEXIBLE DUCT TAKE OFF DETAIL
1 NTS



NOTES:
1. INSTALL REFRIGERANT PIPING AND COMPONENTS IN STRICT CONFORMANCE WITH ALL MANUFACTURERS RECOMMENDATIONS AND REQUIREMENTS, WHICH SHALL TAKE PRECEDENT OVER INFORMATION PRESENTED IN THIS DETAIL.
2. ALL COMPONENTS INSTALLED SHALL BE THE EXACT MODEL RECOMMENDED BY THE MANUFACTURER WITHOUT EXCEPTION.
3. CONSULT THE MANUFACTURER REGARDING THE NEED TO INSTALL A SOLENOID VALVE IN THE LIQUID LINE BETWEEN THE FILTER-DRIER AND SITE GLASS.
4. INSTALL REFRIGERATION PIPE SIZES RECOMMENDED BY THE MANUFACTURER AND CONSULT THE MANUFACTURER REGARDING THE NEED FOR INTERMEDIATE TRAPS BASED ON THE RECOMMENDED PIPE SIZES AND PIPING CONFIGURATION.
5. INSTALL THERMAL EXPANSION VALVE WITH BALANCED PORT CONSTRUCTION AND EXTERNAL EQUALIZER LINES FOR ALL EVAPORATOR COILS EQUIPPED WITH A REFRIGERANT DISTRIBUTOR.

REFRIGERANT PIPING DETAIL (SINGLE CIRCUIT WITH COIL ABOVE OR BELOW CU)
5 NTS



ROOF EQUIPMENT SUPPORT RAIL DETAIL
7 12" = 1'-0"



NOTES:
1. FOR DUCTS LARGER THAN 36"Ø, USE TWO HANGER RODS, WIRES OR STRAPS TO SUPPORT DUCT FROM EACH SIDE.
2. CONNECTIONS TO SLAB OR DECKING ABOVE ARE NOT PERMITTED.

6 ROUND DUCT SUPPORT DETAIL
NTS



NOTES:
1. CUT METAL DECKING TO ALLOW CURB INSTALLATION ON STEEL FRAMING. AFTER CURB IS SET IN PLACE, TRIM REMAINING METAL DECKING AND INSTALL WITHIN CURB. TACK WELD DECKING TO SUPPORT STEEL. DO NOT WELD INTERIOR DECKING TO ROOF CURB. PROVIDE ADDITIONAL CROSS FRAMING TO SUPPORT INTERIOR DECKING AND FILL MATERIAL AS REQUIRED.

5 ROOF CURB DETAIL
NTS



NOTES:
1. SUBMIT SHOP DRAWINGS OF ALL HOOD SYSTEM COMPONENTS FOR APPROVAL PRIOR TO INSTALLATION.
2. TOTAL HOOD SYSTEM TO BE IN COMPLIANCE WITH LATEST EDITION OF NFPA, AS WELL LOCAL CODES AND REGULATIONS.
3. COORDINATE ALL ANSUL FIRE PROTECTION SYSTEMS WITH LOCAL AUTHORITIES AND CONTRACTOR WHO SHALL ALSO BE RESPONSIBLE FOR PERMITS AND TESTING REQUIRED.
4. PROVIDE WRAP AROUND CURB AS APPROVED BY LOCAL CODES AT EXPOSED ENCLOSURE
5. PROVIDE ACCESS PANELS AS REQUIRED BY LOCAL CODES.
6. HOODS SHALL EXTEND MINIMUM 6" BEYOND ALL SIDES AND FRONT EDGE OF FOOD COOKING EQUIPMENT BELOW.
7. HOOD SIZES & ROOF OPENING DIMENSIONS SHALL BE DETERMINED BY FAN MANUFACTURER. COORDINATE WITH STRUCTURAL DRAWINGS FOR EQUIPMENT
8. FAN MANUFACTURER SHALL FABRICATE ROOF CURB ACCORDINGLY SUCH THAT TOP OF THE CURB IS LEVEL.

13 KITCHEN HOOD DETAIL
NTS



W = DUCT WIDTH
R = 1.5W (MAX) [Ro = 2W, Ri = 1.0W]

NOTE: 90° ELBOW SHOWN. IF OTHER ANGLE LESS THAN 90° IS PROVIDED USE RADIUS DIMENSIONS SHOWN ABOVE.

12 TYPICAL GREASE EXHAUST ELBOW
NTS



NOTES:
1. THIS CONNECTION SHALL BE TYPICAL FOR ALL RECTANGULAR BRANCH DUCT CONNECTIONS TO RECTANGULAR TRUNK DUCTS, INCLUDING SUPPLY, RETURN, OUTSIDE AIR AND EXHAUST DUCTS.

17 RECTANGULAR BRANCH TAP DETAIL
NTS



NOTES:
1. ARRANGEMENT SHOWN IS SCHEMATIC, ADJUST TO SUIT FIELD CONDITIONS OR MEET LOCAL CODE REQUIREMENTS.
2. PROVIDE MINIMUM 3.5" OF CLEARANCE AT THE TOP OF THE UNIT.
3. ATTACH FAN COIL UNIT TO MANUFACTURER'S PROVIDED INSTALLATION PLATE. MOUNT INSTALLATION PLATE TO WALL PER MANUFACTURER'S RECOMMENDATIONS.

19 VRF - FAN COIL UNIT - WALL MOUNTED
NTS

8 ADJUSTABLE BAND PIPE HANGER
NTS



NOTES:
1. TYPICAL WHERE DAMPER IS LOCATED AT END OF RIGID ROUND DUCT AT CONNECTION TO FLEXIBLE DUCT.

DAMPER AT FLEX DUCT CONNECTION DETAIL
16 NTS



15 UPBLAST GREASE EXHAUST FAN DETAIL
NTS



GREASE DUCT FIRE WRAP INSULATION INSTALLATION DETAIL
18 NTS

NOTE:
EXISTING CONDITIONS WERE TAKEN FROM ORIGINAL DRAWINGS & SITE VISITS AND MAY NOT REFLECT EXACT "AS-BUILT" CONDITIONS. FIELD VERIFY ALL EXISTING CONDITIONS PRIOR TO SUBMITTING FINAL BIDS. CAREFULLY COORDINATE NEW WORK AND DEMOLITION WITH ALL OTHER DISCIPLINES AND EXISTING CONDITIONS.

Order Plans @ WWW.DILine.com

CALLISONRTKL
A DESIGN CONSULTANCY OF ARCADIS

CallisonRTKL, Inc
1420 Fifth Ave., Suite 2400
Seattle, WA 98101
Tel: 206 623 4646

CallisonRTKL Project No: 003-180034.00

Consultant
HENDERSON ENGINEERS
Henderson Engineers, Inc.
Lenexa, KS 66219
913 742 5300

Consultant
EVS
229 West 27th Street, 5th Floor
New York, NY 10001
Tel: 212 254 0030

BOWLERO - AUGUSTA

ISSUE FOR PERMIT / BID

Client/Owner/Project Address

Bowlmor / AMF
Client Address
222 W 44th Street
New York, NY 10036

Project Address
3261 Washington Rd
Augusta, GA 30907

Issue Drawing Log

2018.05.29	ISSUE FOR PERMIT
2018.05.29	ISSUE FOR BID

Seal

THIS DOCUMENT IS RELEASED FOR THE PURPOSE OF PRELIMINARY SUBMITTAL
LICENSE # PE-034824

IT IS NOT TO BE USED FOR CONSTRUCTION PURPOSES

Sheet Identification

MECHANICAL DETAILS

M-200

ANDREW S. KNIGHT