

Order Plans @

**Typical Hood R-141 200906 040307**

REV	DATE	BY	CHK	DESCRIPTION
1	06/04/09	JLD	JLD	ISSUE FOR PERMIT
2	06/04/09	JLD	JLD	REVISED TO SHOW R-141 HOOD

**System Design Verification (SDV)**

If ordered, Call Service will perform a System Design Verification (SDV) once all equipment has been installed and the hood is operational. The SDV will be performed at the site of the hood and will include:

- Verify hood dimensions and clearances meet the SDV.
- Verify hood is properly installed and supported.
- Verify hood is properly connected to the ductwork.
- Verify hood is properly vented to the exterior.
- Verify hood is properly grounded.
- Verify hood is properly labeled.
- Verify hood is properly maintained.

**CAPTIVE LIFE**

BOWLERO AUGUSTA GA  
AUGUSTA GA 30907

DATE: 06/04/09  
DRAWN: JLD  
CHECKED: JLD  
SCALE: AS SHOWN  
SHEET NO. 7

**Typical Hood R-141 200906 040307**

REV	DATE	BY	CHK	DESCRIPTION
1	06/04/09	JLD	JLD	ISSUE FOR PERMIT
2	06/04/09	JLD	JLD	REVISED TO SHOW R-141 HOOD

**CAPTIVE LIFE**

BOWLERO AUGUSTA GA  
AUGUSTA GA 30907

DATE: 06/04/09  
DRAWN: JLD  
CHECKED: JLD  
SCALE: AS SHOWN  
SHEET NO. 8

**Typical Hood R-141 200906 040307**

REV	DATE	BY	CHK	DESCRIPTION
1	06/04/09	JLD	JLD	ISSUE FOR PERMIT
2	06/04/09	JLD	JLD	REVISED TO SHOW R-141 HOOD

**CAPTIVE LIFE**

BOWLERO AUGUSTA GA  
AUGUSTA GA 30907

DATE: 06/04/09  
DRAWN: JLD  
CHECKED: JLD  
SCALE: AS SHOWN  
SHEET NO. 9