1 EQUIPMENT CONNECTION ROOF PLAN
1/8" = 1'-0"

POWER PLAN GENERAL NOTES

1. REFER TO SHEET E-000 FOR ADDITIONAL GENERAL NOTES
2. REFER TO ARCHITECTURAL DRAWINGS FOR EXACT COLOR, LOCATION AND MOUNTING HEIGHTS OF ELECTRICAL DEVICES
3. REFER TO FOOD SERVICE EQUIPMENT DRAWINGS AND SPECIFICATIONS FOR ADDITIONAL ROUGH-IN REQUIREMENTS NOT INDICATED ON DRAWINGS. ELECTRICAL CONTRACTOR SHALL COORDINATE ALL FOOD SERVICE ROUGH-IN REQUIREMENTS WITH EQUIPMENT INSTALLER PRIOR TO ROUGH-IN.
4. "ISI" REFERS TO INTERIOR INTERNALLY ILLUMINATED SIGNS
5. "ISX" REFERS TO EXTERIOR INTERNALLY ILLUMINATED SIGN
6. "ISLS" REFERS TO EXTERNALLY ILLUMINATED BLACK LIGHT SIGNS

ELECTRICAL FIXTURE TAGGING LEGEND

PNL#-## / RP#-## = PANEL AND CIRCUIT NUMBER / RELAY PANEL AND RELAY NUMBER (AS REQUIRED)

ELECTRICAL PLAN NOTES

1. MOUNT DISCONNECT SWITCH ON CONDENSING UNIT. COORDINATE LOCATION WITH MANUFACTURER TO ENSURE ALL REQUIREMENTS ARE MET.
2. PROVIDE MOTOR RATED TOGGLE DISCONNECT SWITCH AND POWER CONNECTION FOR CONDENSING UNIT.
3. INSTALL DISCONNECT SWITCH FURNISHED BY DIVISION 23 EQUIPMENT. COORDINATE FINAL LOCATION, REQUIREMENTS AND POWER CONNECTION WITH DIVISION 23 CONTRACTOR PRIOR TO ROUGH-IN.
4. PROVIDE STARTER FOR MECHANICAL EQUIPMENT AND CONNECT TO OWNER PROVIDED DISCONNECT SWITCH. COORDINATE REQUIREMENTS WITH MANUFACTURER AND DIVISION 23 CONTRACTOR PRIOR TO ROUGH-IN.

CONTRACTOR SHALL ROUTE ALL CONDUITS FOR ROOF CIRCUITS BELOW ROOF WITHIN THE BUILDING. IF CONDUITS MUST BE ROUTED ON ROOF, CONTRACTOR SHALL INCREASE CONDUCTOR SIZE PER NEC REQUIREMENTS FOR ALL ROOF MOUNTED CONDUITS

NOTE:
EXISTING CONDITIONS WERE TAKEN FROM ORIGINAL DRAWINGS & SITE VISITS AND MAY NOT REFLECT EXACT "AS-BUILT" CONDITIONS. FIELD VERIFY ALL EXISTING CONDITIONS PRIOR TO SUBMITTING FINAL BIDS. CAREFULLY COORDINATE NEW WORK AND DEMOLITION WITH ALL OTHER DISCIPLINES AND EXISTING CONDITIONS.

CALLISONRTKL
A DESIGN CONSULTANCY OF ARCADIS

CallisonRTKL, Inc
1420 Fifth Ave., Suite 2400
Seattle, WA 98101
Tel: 206 623-4646

CallisonRTKL Project No: 003-180034.00

Consultant
HENDERSON ENGINEERS
Henderson Engineers, Inc.
[illegible], KS 66219
913 742 5317

Consultant
GMS
GMS Inc.
29 West 27th Street, 5th Floor
New York, NY 10001
Tel: 212 254-0030

BOWLERO - AUGUSTA

ISSUE FOR PERMIT / BID

Client/Owner/Project Address

Bowlmor | AMF
Client Address
222 W44th Street
New York, NY 10036

Project Address
3087 Washington Rd
Augusta, GA 30907

Issue Drawing Log

	2018.05.29	ISSUE FOR PERMIT
	2018.05.29	ISSUE FOR BID

Seal

THIS DOCUMENT IS RELEASED FOR THE PURPOSE OF PRELIMINARY SUBMITTAL
LICENSE # PE029027

IT IS NOT TO BE USED FOR CONSTRUCTION PURPOSES

Sheet Identification

EQUIPMENT CONNECTON ROOF PLAN

E-121

CRAIG R. LANHAM

Order Plans @ WWW.LDILine.com