

NO.	TYPE	CFM RANGE	NECK/FACE SIZE	INLET DUCT DIA.	MAT'L	VOL. DMPR	FINISH	FRAME	THROW	MODEL	REMARKS
5-6	LOUVER	0-75	24 X 24	6"	ALUM.	(3)	(1)	LAY-IN (2)	4-WAY	TMS-AA	"TITUS"
5-8	LOUVER	76-275	24 X 24	8"	ALUM.	(3)	(1)	LAY-IN (2)	4-WAY	TMS-AA	"TITUS"
5-10	LOUVER	276-375	24 X 24	10"	ALUM.	(3)	(1)	LAY-IN (2)	4-WAY	TMS-AA	"TITUS"
5-12	LOUVER	375-550	24 X 24	12"	ALUM.	(3)	(1)	LAY-IN (2)	4-WAY	TMS-AA	"TITUS"
5-14	LOUVER	551-750	24 X 24	14"	ALUM.	(3)	(1)	LAY-IN (2)	4-WAY	TMS-AA	"TITUS"

- ACCEPTABLE MANUFACTURERS: TITUS, KRUEGER, CARNES, SHOEMAKER.
- NOT ALL SUPPLY GRILLES SCHEDULED ARE USED ON THE PROJECT.
- PROVIDE R-6 MOLDED BACKED INSULATION BLANKET.
- BRANCH DUCT SIZE TO GRILLE SHALL BE SAME SIZE AS NECK UNLESS OTHERWISE NOTED.
- (1) WHITE. PROVIDE MANUFACTURER'S COLOR CHART WITH SHOP DRAWING SUBMITTAL. VERIFY COLOR SELECTIONS WITH OWNER / ARCHITECT PRIOR TO PURCHASE.
- (2) COORDINATE MOUNTING WITH ARCH PLANS. PROVIDE PLASTER RINGS WHERE REQUIRED FOR INSTALLATION.
- (3) VOLUME DAMPER AT THE GRILLE INDICATED BY A "D" AFTER THE GRILLE DESIGNATION. EXAMPLE: SG15D-6 IS SG15-6 WITH A DAMPER.

NO.	TYPE	MAX. CFM	NECK/FACE SIZE	FLEX. DUCT DIA.	MAT'L	VOL. DMPR	FINISH	FRAME	MODEL	REMARKS
2-6	EGG CRATE	75	24 X 24	6"	ALUM.	(4)	(1)	LAY-IN (2)	50F (3)	"TITUS"
2-8	EGG CRATE	250	24 X 24	8"	ALUM.	(4)	(1)	LAY-IN (2)	50F (3)	"TITUS"
2-10	EGG CRATE	450	24 X 24	10"	ALUM.	(4)	(1)	LAY-IN (2)	50F (3)	"TITUS"
2-12	EGG CRATE	750	24 X 24	12"	ALUM.	(4)	(1)	LAY-IN (2)	50F (3)	"TITUS"
2-14	EGG CRATE	1,100	24 X 24	14"	ALUM.	(4)	(1)	LAY-IN (2)	50F (3)	"TITUS"
2-16	EGG CRATE	1,600	24 X 24	16"	ALUM.	(4)	(1)	LAY-IN (2)	50F (3)	"TITUS"
2-18	EGG CRATE	2,200	24 X 24	18"	ALUM.	(4)	(1)	LAY-IN (2)	50F (3)	"TITUS"

- ACCEPTABLE MANUFACTURERS: TITUS, KRUEGER, CARNES, SHOEMAKER.
- NOT ALL SUPPLY GRILLES SCHEDULED ARE USED ON THE PROJECT.
- PROVIDE MIN. 6" DEEP PLENUM BOX AT ALL RETURN GRILLES (TYP.)
- BRANCH DUCT SIZE TO GRILLE SHALL BE SAME SIZE AS NECK UNLESS OTHERWISE NOTED.
- (1) WHITE. PROVIDE MANUFACTURER'S COLOR CHART WITH SHOP DRAWING SUBMITTAL. VERIFY COLOR SELECTIONS WITH OWNER / ARCHITECT PRIOR TO PURCHASE.
- (2) COORDINATE MOUNTING WITH ARCH PLANS. PROVIDE PLASTER RINGS WHERE REQUIRED FOR INSTALLATION.
- (3) 1/2 X 1/2 X 1/2 CORE
- (4) VOLUME DAMPER AT THE GRILLE INDICATED BY A "D" AFTER THE GRILLE DESIGNATION. EXAMPLE: RG15D-6 IS RG15-6 WITH A DAMPER.

NO.	NOM. TONS	SUPPLY FAN				RELIEF		COOLING				HEATING				OUTSIDE AIR	SMOKE DETECTOR	CURB HEIGHT BY MFR	TYPE	MCA	MOP	DLT/PHASE	EMERGENCY	UNRATING	TEST PROC	WEIGHT (LBS.)	MODEL	REMARKS		
		CFM	OA CFM	EXT. SP	DRIVE TYPE	MOTOR BHP	MOD. TYPE	BAR.	FAN	EAT DB / WB	MBH CAP.	AMB. TEMP F	NO. COMPR.	NO. STAGES	KW														MBH IN	MBH OUT
1	3	1,200	175	1	BELT	0.69	-	X	-	80/67	30.3	110	1	1	-	72	59	1	EC0N	NO (1)	14"	STANDARD	20.0	20.0	13.0 SEER	14.0 SEER	ARI 210/240	850	48KC	CARRIER
2	4	1,450	250	1	BELT	0.94	-	X	-	80/67	42.5	110	1	1	-	72	59	1	EC0N	NO (1)	14"	STANDARD	24.0	20.0	13.0 SEER	14.0 SEER	ARI 210/240	850	48KC	CARRIER
3	3	1,075	175	1	BELT	0.58	-	X	-	80/67	28.9	110	1	1	-	72	59	1	EC0N	NO (1)	14"	STANDARD	20.0	20.0	13.0 SEER	14.0 SEER	ARI 210/240	850	48KC	CARRIER

- ADMIN TO SUPPLY RTAC UNITS. H.C. / G.C. TO INSTALL.
- SEE MOTOR SPECIFICATIONS FOR MOTOR REQUIREMENTS.
- PROVIDE WITH 2" ASHRAE STD 52.2 MERV 8 T.A. FILTERS.
- RTAC DESIGNED TO PREVENT RAIN INTRUSION INTO THE AIRSTREAM WHEN TESTED AT DESIGN AND NO AIRFLOW PER SECTION 58 OF UL 1995.
- PROVIDE UNIT WITH INTEGRAL MANUFACTURER INSTALLED WATER-LEVEL MONITORING DEVICE IN THE PRIMARY DRAIN PAN TO SHUT OFF THE EQUIPMENT PER IMC 307.2.3.1.
- PROVIDE UNIT MOUNTED WEATHERPROOF DISCONNECT.
- PROVIDE WITH ULTRA LOW LEAK CODE COMPLIANT ECONOMIZER WITH BAROMETRIC RELIEF AND COMPARATIVE ENTHALPY CONTROL.
- PROVIDE WITH HINGED ACCESS PANELS AND HINGED DOOR FOR ECONOMIZER.
- PROVIDE WITH STAINLESS STEEL HEAT EXCHANGER.
- PROVIDE WITH HAIL GUARD FOR CONDENSING COILS.
- (1) DUCT SMOKE DETECTOR IS NOT REQUIRED PER IMC 606.2.1 AS RETURN AIR FLOW DOES NOT EXCEED 2,000 CFM IN ANY LOCATION AND SYSTEMS DO NOT SHARE COMMON SUPPLY OR RETURN AIR DUCTS.

HVAC SPECIFICATIONS

- BASIC HVAC REQUIREMENTS
 - SEE SHEET T2.0
 - SUBSTITUTIONS: WHERE SUBSTITUTE EQUIPMENT REQUIRES REDESIGN OF ANY PART OF THE PROJECT, THE COST OF REDESIGN AND ADDITIONAL COSTS OF THE WORK SHALL BE PAID BY THE CONTRACTOR. REDESIGN SHALL BE SUBJECT TO THE APPROVAL OF ALL AUTHORITIES HAVING JURISDICTION OVER THE WORK INCLUDING THE ARCHITECT/ENGINEER.
 - DETAILS AND SCHEDULES ARE SHOWN TO AID THE CONTRACTOR AND ARE NOT MEANT TO BE INCLUSIVE OF ALL DEVICES. PROVIDE REQUIRED EQUIPMENT AND ACCESSORIES FOR A COMPLETE INSTALLATION.
 - INSTALL ALL EQUIPMENT PER MANUFACTURER'S INSTALLATION INSTRUCTIONS AND REQUIREMENTS. PROVIDE ADDITIONAL WORK AND MATERIALS AS REQUIRED.
 - COORDINATE INSTALLATION OF HVAC WORK WITH THE OTHER CONTRACTORS AND THE EXISTING BUILDING TO AVOID CONFLICTS WITH OTHER WORK.
 - PROVIDE ALL CUTTING AND PATCHING NECESSARY FOR HVAC WORK INSTALLATION UNLESS THIS WORK IS IDENTIFIED TO BE THE WORK OF OTHER CONTRACTORS. PATCHING SHALL MATCH ADJACENT SURFACES.
 - INSTALL CLEAN SET OF FILTERS IN ALL UNITS AT TIME OF TESTING AND BALANCING.
 - CLEAN GRILLES AND EQUIPMENT AND LEAVE IN PROPER WORKING CONDITION AT THE TIME OF FINAL CLEAN-UP.
- FINISH AND PAINTING
 - COORDINATE WORK WITH THE PAINTERS SO THAT ALL EQUIPMENT IS INSTALLED PRIOR TO PAINTING. H.C. SHALL PAINT ITEMS IF NOT IN PLACE PRIOR TO NOT BEING ROUTED TO PAINTING.
 - IF FINISH BECOMES RUSTED, CORRODED, SCRATCHED OR FLAKED DURING STORAGE/INSTALLATION, REFINISH THE EQUIPMENT TO THE SATISFACTION OF THE OWNER.
 - WHERE THE HEATING CONTRACTOR IS REQUIRED TO PAINT, THE PAINTING SHALL BE DONE IN ACCORDANCE WITH THE PAINTING PORTION OF THE ARCHITECTURAL SPECIFICATION.
- INSULATION
 - INSULATION SYSTEM SHALL MEET ALL REQUIREMENTS OF THE FIRE HAZARD CLASSIFICATIONS OF 26. MAX. FLEX. SPREAD OF 50 WHEN INSTALLED IN RETURN AIR PLENUM.
 - INSTALL MATERIALS IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS AND MICA PUBLICATION "COMMERCIAL STANDARDS", 1999 FIFTH EDITION.
 - CONTINUE INSULATION WITHOUT INTERRUPTIONS THROUGH WALLS, SLEEVES, AND HANGERS.
 - FIBERGLASS (G) INSULATION
 - MANUFACTURERS: OWENS CORNING (O.C.) FIBERGLASS CORPORATION, CERTAINTED, KNAUF.
 - FLEX. F.G. 0.5 MIL THICK GLASS FIBER INSULATION FACTORY LAMINATED TO FRK VAPOR RETARDER. LISTED THICKNESS IS NOMINAL, R-3.3 / NOMINAL INCH.
 - INSULATE FITTINGS, JOINTS, FLANGES, DAMPERS, AND IN-LINE ACCESSORIES WITHOUT INTERNAL LININGS/INSULATION WITH SAME MATERIAL AND THICKNESS AS SPECIFIED FOR THE DUCT SYSTEM. STOP AND POINT INSULATION AROUND ACCESS DOORS AND DAMPER OPERATORS TO ALLOW OPERATION WITHOUT DISTURBING WRAPPING.

IV. DUCTWORK

- PERFORM WORK IN ACCORDANCE WITH THE LATEST EDITIONS OF SMACNA HVAC DUCT CONSTRUCTION STANDARDS.
- PAINT THE INSIDE OF ALL DUCTS VISIBLE THROUGH GRILLES OR OTHER OUTLETS WITH DULL BLACK PAINT.
- CERTAIN VERTICAL AND HORIZONTAL OFFSETS ARE INDICATED TO INDICATE THE GENERAL POSITION RELATIONSHIP OF THE DUCTWORK SYSTEMS. PROVIDE ADDITIONAL OFFSETS AS REQUIRED TO COORDINATE WITH THE INSTALLATION OF OTHER SYSTEMS, CEILING AND STRUCTURE. THE OFFSETS ARE APPROXIMATE AND SHALL NOT BE SOLELY TO DETERMINE EXACT LOCATION OF DUCTWORK.
- PROVIDE TEMPORARY CLOSURES AT ALL OPEN ENDS OF DUCTWORK TO PREVENT CONTAMINATION OF THE DUCTWORK SYSTEM.
- LOCATE DUCTS TO AVOID SPILLAGE OF OILS AND GREASE.
- TEMPERATURES SHALL BE MAINTAINED AT 15 DEGREES WHENEVER POSSIBLE.
 - 0 DEGREE MAXIMUM BERGENS. 15 DEGREE MAXIMUM.
 - CONVERGENCE DOWNSTREAM.
 - MINIMUM DUCTS MAY BE SUBSTITUTED FOR RECTANGULAR IF SIZED IN ACCORDANCE WITH TABLES OF EQUIPMENT RECTANGULAR AND ROUND DUCTS.
- ROUND DUCTWORK, CONCEALED BRANCH DUCTWORK TO GRILLES AND DIFFUSERS MAY BE SUBSTITUTED FOR SPIRAL. ALL OTHER ROUND DUCTWORK SHALL BE SPIRAL. LOCATIONS WITH FITTINGS AND COUPLINGS MINIMUM 2 GAUGES HEAVIER THAN DUCT.
- FLEXIBLE DUCTWORK
 - UL LISTED CLASS 1 FLEXIBLE AIR DUCT, COMPLY WITH NFPA 90A, FLAME SPREAD OF 25 OR LESS, SMOKE DEVELOPED RATING OF 50 OR LESS.
 - MANUFACTURERS: THERMAFLEX, FLEXMASTER.
 - INSULATED FOR SUPPLY AND RETURN DUCTWORK. UNINSULATED FOR EXHAUST DUCTWORK.
 - CONNECT TO SUPPLY DUCTWORK BY SLIDING CORE OVER COLLAR. TAPE JOINT WITH MINIMUM 3 WRAPS OF TAPE, AND APPLY METAL BAND CLAMP OR PANDUIT. FOR INSULATED DUCTWORK, PULL INSULATION AND OUTER JACKET BACK INTO POSITION, AND TAPE WITH MINIMUM 3 WRAPS OF TAPE BETWEEN FLEX DUCT AND DUCT INSULATION.
 - CONNECT TO GRILLES AND RETURN AND TRANSFER DUCTWORK WITH METAL BAND CLAMP OR PANDUIT.
 - MAXIMUM LENGTH THROUGH WALLS OR PARTITIONS.
 - DO NOT RUN THROUGH WALLS OR PARTITIONS.
- DUCTWORK SEALANTS
 - MANUFACTURERS: HARDCAST #601, UNITED MCGILL WATER BASED DUCT SEAL. MAXIMUM FLAME SPREAD OF 25, FUEL CONTRIBUTED OF 50, AND SMOKE DEVELOPED OF 50.
 - HARDCAST ALUMA-GRIP 701 OR EQUIVALENT PRESSURE SENSITIVE DUCT JOINT ROLLED SEALANT MAY BE USED IN PLACE OF MASTIC. SEALANT SHALL COMPLY WITH THE FOLLOWING:
 - MILL FINISH ALUMINUM SUBSTRATE WITH GRAY ADHESIVE.
 - MINIMUM 30 MIL THICK.
 - MIN. 17 LB PER LINEAR INCH PEEL STRENGTH.
 - MAX FLAME SPREAD OF 25, MAX SMOKE DEVELOPED OF 50 WHEN TESTED IN ACCORDANCE WITH ASTM G-53.
 - VOC: 0 G/L. COMPLIANT WITH LEED SCQMD RULE 1168.
 - PRESSURE CLASSES UP TO 10" W.C.

DUST CLEANING

- PROTECT DUCTWORK AGAINST ENTRY OF DUSTY MATTER DURING CONSTRUCTION. PROVIDE TEMPORARY END CAPS AND SEALS. PROVIDE TEMPORARY FILTERS OVER RETURN AND EXHAUST AIR INLETS IF DUCTWORK IS USED DURING CONSTRUCTION.
- REMOVE ALL DIRT AND FOREIGN MATTER AND CLEAN DIFFUSERS, REGISTERS, AND GRILLES BEFORE OPERATING FANS.
- SEALING DUCT PENETRATIONS
 - THRU NON-RATED WALLS WHERE DRYWALL, CONCRETE, OR MASONRY EXTENDS TO STRUCTURE, FILL VOID BETWEEN DUCT AND WALL WITH MINERAL WOOL AND CAULK BOTH SIDES WITH NON-HARDENING DUCT.
- DUCTWORK ACCESSORIES
 - TURNING VANES
 - MANUFACTURERS: AERO/DYNE CO. H.E.P., HART & COOLEY, UNITED MCGILL, SEMCO.
 - RECTANGULAR DUCTWORK: AIRFLOW TURNING VANES IN ACCORDANCE WITH SMACNA FIG. 2-3 AND 2-4. VANE RADIUS AS PROVIDED BY AERO/DYNE H.E.P. OR 4-1/2 INCHES WITH A 3-1/2 INCH SPACING.
 - MANUAL VOLUME DAMPERS
 - MANUFACTURERS: RUSKIN, VENT PRODUCTS, UNITED MCGILL.
 - DAMPERS WITH EXTENDED SHAFTS AND QUADRANTS, OPERATOR WITH LOCKING DEVICE, POSITION INDICATOR, AND ELEVATED PLATFORM FOR EXTERNALLY INSULATED DUCTWORK.
 - BUTTERFLY DAMPER, MINIMUM 22 GAUGE. SHAFT ALONG ENTIRE LENGTH OF DAMPER FOR DAMPERS EXCEEDING 18" IN WIDTH.
 - ROUND DAMPERS: MINIMUM 20 GAUGE BUTTERFLY DAMPER.
 - TAKE-OFF FITTINGS
 - MANUFACTURERS: FLEXMASTER, UNITED MCGILL.
 - TO GRILLES: ONE PIECE SPIN-IN WITH INTEGRAL FACTORY INSTALLED LOCKING TYPE BALANCING DAMPERS.
 - DUCT ACCESS DOORS
 - MANUFACTURERS: CESCO, FLEXMASTER, VENT PRODUCTS, KEES, UNITED MCGILL, SEMCO.
 - HINGE, LATCHES, HANDLES, AND RUBBER GASKET IN FRAME. 1" INSULATED DOUBLE WALL CONSTRUCTION FOR DOORS IN LINED OR EXTERNALLY INSULATED DUCTWORK. ATTACHMENT CABLES FOR SPIN-IN UNITS. DOOR SUITABLE FOR DUCT STATIC PRESSURE CLASS.
 - DOOR SIZE 2" LESS THAN THE WIDTH OF THE DUCT (MAX. DOOR SIZE 24" X 24" DIA.).
 - ROUND DUCTWORK: 16 GAUGE ROLLED SHEET METAL HINGED ACCESS DOOR WITH BUCKLE LOCKS.
 - PROVIDE AT TURNING VANES IN RETURN AND EXHAUST DUCTWORK; AT ANY DEVICE IN THE DUCT WHICH REQUIRES MAINTENANCE, SERVICE OR CLEANING.
 - USE HINGED ACCESS DOORS WHERE POSSIBLE. USE CAM OPERATED REMOVABLE DOORS WHERE SPACE PREVENTS THE OPENING OF A HINGED MODEL.
 - BACKDRAFT DAMPERS
 - MANUFACTURERS: RUSKIN, VENT PRODUCTS.
 - ALUMINUM FRAME AND BLADE CONSTRUCTION WITH BLADE AND EDGE SEALS. LEAKAGE LESS THAN 12 CFM PER SQ. FT. AT 1/2" W.G., COUNTERBALANCE TO OPEN AT APPROXIMATELY 0.05" STATIC PRESSURE.

F. FLEXIBLE CONNECTIONS

- MANUFACTURERS: VENTFABRICS, DURO-DYNE.
 - MATERIAL BOLTED SECURELY TO THE EQUIPMENT AND CONNECTING DUCTWORK WITH #16 GAUGE GALVANIZED IRON BAND (LOOP) CLAMPS BOLTED TIGHT TO MAKE AN AIRTIGHT CONNECTION. MINIMUM 6" WIDE.
 - PROVIDE AT INLET AND OUTLET OF ALL AIR HANDLING UNITS AND FANS IN ACCORDANCE WITH SMACNA FIGURE 2-19.
 - CONVENTIONAL INTERIOR: VENTGLAS, -20 TO 200 DEG F., 30 OZ. PER SQUARE YARD GLASS FABRIC DOUBLE COATED WITH NEOPRENE. UL 214 APPROVED.
- VI. ROOFTOP AIR CONDITIONING UNIT - SEQUENCE OF OPERATION
- PROVIDE A CARRIER 33C2PP25-03 EDGE PRO COMMERCIAL SERIES PROGRAMMABLE HEATING/COOLING THERMOSTAT CAPABLE OF 2 STAGES OF HEATING AND 2 STAGES OF COOLING.
 - SET FAN SETTING TO "ON" FOR FAN TO RUN CONTINUOUSLY IN OCCUPIED PERIODS, AND TO RUN WITH EQUIPMENT OPERATION DURING UNOCCUPIED PERIODS.
 - DRY CONTACT OUTPUT SHALL BE USED TO ENERGIZE ECONOMIZER TO OPEN OUTDOOR AIR DAMPER TO MINIMUM POSITION DURING OCCUPIED OPERATION.
 - THERMOSTAT INSTALLER SETUP SHALL OTHERWISE UTILIZE FACTORY DEFAULTS.
 - MOUNT AND WIRE ALL CONTROL WIRING ASSOCIATED WITH THE ROOFTOP AND PROVIDE ANY ADDITIONAL DEVICES NECESSARY FOR A COMPLETE OPERATIONAL SYSTEM.
- VII. TESTING, ADJUSTING, AND BALANCING
- QUALITY ASSURANCE - PERFORM TOTAL SYSTEM BALANCE IN ACCORDANCE WITH AABC NATIONAL STANDARDS FOR FIELD MEASUREMENT AND INSTRUMENTATION, TOTAL SYSTEM BALANCE OR NEBB PROCEDURAL STANDARDS FOR TESTING, BALANCING AND ADJUSTING OF ENVIRONMENTAL SYSTEMS.
 - SUBMITTALS
 - CONTRACTOR SHALL SUBMIT THE FINAL TESTING AND BALANCING REPORT PRIOR TO PROJECT COMPLETION AND IN ADVANCE OF OCCUPANCY. SUBMIT REPORTS ON AABC NATIONAL STANDARDS FOR TOTAL SYSTEM BALANCE OR NEBB FORMS.
 - SUBMIT THE DESIGN AND ACTUAL DATA FOR EACH SCHEDULED PIECE OF EQUIPMENT: MODEL, SUPPLY, RETURN, AND OUTSIDE AIR FLOWS; FAN RPM, BHP, AMPERAGE; FAN AND MOTOR SHEAVE, DIAMETER, BORE AND MAKE; BELT SIZE AND QUANTITY; MOTOR SHEAVE CENTER LINE AND OPERATOR DISTANCE, ROOM AIR FLOW.
 - INSTALLATION TOLERANCES
 - AIR HANDLING SYSTEMS: ADJUST SUPPLY SYSTEMS TO WITHIN PLUS OR MINUS 5 PERCENT OF DESIGN AND RETURN AND EXHAUST SYSTEMS TO PLUS OR MINUS 10 PERCENT OF DESIGN.
 - AIR OUTLETS AND INLETS: ADJUST TOTAL AIR FLOW TO SPACE TO WITHIN PLUS 10 PERCENT AND MINUS 5 PERCENT OF DESIGN.
 - ADJUST OUTLETS AND INLETS IN SPACE TO WITHIN PLUS OR MINUS 10 PERCENT OF DESIGN.
 - AIR SYSTEM BALANCE
 - VARY TOTAL SYSTEM AIR QUANTITIES BY ADJUSTING FAN SPEEDS. VARY BRANCH AIR QUANTITIES BY DAMPER REGULATION.
 - ADJUST OUTSIDE AIR AND RETURN AIR AUTOMATIC DAMPERS FOR DESIGN CONDITIONS.
 - ROOM AIRFLOW TESTING AND BALANCING TO OCCUR WITH ROOM DOORS CLOSED.

PROJECT DESIGN CRITERIA		
MECHANICAL CODE	2012 IMC	
ENERGY CODE	2012 IECC	
SEISMIC DESIGN CATEGORY	B	
NEAREST ASHRAE CITY	LYNCHBURG/MUN., VA	
ELEVATION	938	
	OUTSIDE	
	DB	WB
WINTER:	15.3	N/A
SUMMER:	92.2	76.2

EXCEL
ENGINEERS • SURVEYORS

1630 HAMELOT DRIVE
FOUNTAIN LAKE, WI 54935
PHONE: (920) 926-9800
WWW.EXCELENGINEER.COM

PROJECT INFORMATION

PROJECT NUMBER: 1823380

TENANT BUILD-OUT FOR:
ASPEN DENTAL
4011 WARDS ROAD • LYNCHBURG, VA 24502

PROFESSIONAL SEAL

SHEET DATES	
ISSUE DATE	MAY 31, 2018
REVISIONS	

SHEET INFORMATION

SPECIFICATIONS & SCHEDULES

SHEET NUMBER

H0.1