

LIGHTING FIXTURE SCHEDULE 'L'

DESIGN ID	QUANTITY	DESCRIPTION	RESP.	MODEL	LAMP	MAX WATTS
11419	2	EMERGENCY LIGHT DOUBLE - BLACK	SB	JUNO #N1BLHO	INCLUDED W/ FIXTURE	10
11517	5	EMERGENCY EXIT LIGHT - BLACK	SB	JUNO #NXP3RBL	INCLUDED W/FIXTURE	5
13401	8	5" BAFFLE TRIM - BLACK	SB	JUNO #SP29443B-BL	N/A	
13827	8	CAN - RECESSED INTEGRATED LED HOUSING - 5IN 125MM - 900LM NEW CEILING	SB	JUNO #SP29403G3-27K-N-1	INTEGRAL LED	15
15057	8	TROFFER - LED RECESSED - 24X48IN - 600X1200MM - WHITE - 3900LM	SB	INDY #S2X4BL-3935U-WH3	INTEGRATED LED	40
16593	2	SCONCE - LED RESTROOM VANITY TUBULAR - OPAL GLASS AND BRUSHED NICKEL	SB	DOLAN HOSPITALITY #400290	(1) LED 20LM 2700K (INCLUDED)	10

TRACK SCHEDULE

DESIGN ID	QUANTITY	DESCRIPTION	RESP.	MODEL	LAMP	MAX WATTS
12947	7	TRACK - WITH CONNECTORS - 8FT - BLACK	SB	TRACK: (2) JUNO R4BL END FEED CONN: (1) JUNO R38BL MINI CONNECTOR: (1) JUNO R23BL		0
12948	7	TRACK - WITH CONNECTORS - 16FT - BLACK	SB	TRACK: (4) JUNO R4BL END FEED CONN: (1) JUNO R38BL MINI CONNECTOR: (3) JUNO R23BL ADJUSTABLE CONN: (1) JUNO R20BL		0
12949	2	TRACK - WITH CONNECTORS - 12FT - BLACK	SB	TRACK: (3) JUNO R4BL END FEED CONN: (1) JUNO R38BL MINI CONNECTOR: (2) JUNO R23BL ADJUSTABLE CONN: (1) JUNO R20BL		0
12955	60	TRACK FIXTURE OPEM FLARE - 3.5IN - BLACK	SB	JUNO #R551BL	(1) 7W 14516 PAR20	7
12958	12	TRACK FIXTURE OPEM FLARE - 5IN - BLACK	SB	JUNO #RxxBL	(1) 7W 14673 PAR30	7
15058	1	TRACK - WITH CONNECTORS - 6FT - BLACK	SB	TRACK: (2) JUNO R6BL END FEED CONN: (1) JUNO R38BL MINI CONNECTOR: (1) JUNO R23BL		0
17472	3	TRACK - WITH CONNECTORS - VARIABLE LENGTH - BLACK	SB	END FEED CONN: (1) JUNO R38BL		0

LIGHTING DESIGN PLAN NOTES

- A. ALL FIXTURES IN WORK ROOM, BACK AND FRONT LINE, ABOVE CONDIMENT CART, AND ANY OTHER AREAS WHERE EXPOSED FOOD, CLEAN EQUIPMENT OR UTENSILS, OR UNWRAPPED SINGLE SERVICE ITEMS WILL BE EXPOSED, SHALL HAVE SHATTERPROOF LAMPS IF THE FIXTURE IS NOT LENSED. ARCHITECT OF RECORD TO INCLUDE APPROPRIATE LAMPS / FIXTURES ON DRAWINGS AND SCHEDULES, AND COMPLY WITH ANY ADDITIONAL JURISDICTIONAL LIGHTING REQUIREMENT.
- B. PROVIDE GROMMET AT ALL CEILING PENETRATIONS FOR FIXTURES/SUPPORTS.
- C. CENTER EMERGENCY/EXIT LIGHTS ABOVE DOORS, UNLESS OTHERWISE NOTED.
- D. ADJUST FOCUS OF ALL TRACK AND RECESSED TRACK LIGHTING TO FULLY ILLUMINATE ALL ARTWORK, MENU BOARDS AND MERCHANDISE BAYS.
- E. IF PENDANT CYLINDERS CAN SUSPENDED LENGTH EXCEEDS 48" (1220MM) FROM CEILING, REPLACE WITH SURFACE MOUNTED CYLINDER CANS AND SUSPEND WITH WIRE. CONTRACTOR SUPPLY PENDANT AND J-BOX DIMENSIONED HEIGHT.
- F. REFER TO POWER PLAN FOR PANEL BOARD LOCATIONS.
- G. ALL EMERGENCY AND EXIT DISCHARGE LIGHTING SHALL BE CONNECTED TO CIRCUIT INDICATED, AHEAD OF ANY SWITCHING.

LAMP SCHEDULE

DESIGN ID	QUANTITY	DESCRIPTION	RESP.	MODEL
14516	60	7W LED PAR20 BLACK	SB	GE LIGHTING #99643 LED7DP20BB/827/20
14673	12	LED PAR 30 850LM 2700K NFL - BLACK	SB	GE LIGHTING #39608 LED12DP302BB/827/35

RESPONSIBILITY LEGEND

SB	STARBUCKS
GC	GENERAL CONTRACTOR
VD	VENDOR
LL	LANDLORD



STARBUCKS COFFEE COMPANY
2401 UTAH AVENUE SOUTH
SEATTLE, WASHINGTON 98134
(206) 318-1575


THESE DRAWINGS AND SPECIFICATIONS ARE CONFIDENTIAL AND SHALL REMAIN THE SOLE PROPERTY OF STARBUCKS CORPORATION, WHICH IS THE OWNER OF THE COPYRIGHT IN THIS WORK. THEY SHALL NOT BE REPRODUCED IN WHOLE OR IN PART, SHARED WITH THIRD PARTIES OR USED IN ANY MANNER ON OTHER PROJECTS OR EXTENSIONS TO THIS PROJECT WITHOUT THE PRIOR WRITTEN CONSENT OF STARBUCKS CORPORATION. THESE DRAWINGS AND SPECIFICATIONS ARE INTENDED TO EXPRESS DESIGN INTENT FOR A PROTOTYPICAL STARBUCKS STORE WHICH IS SUBJECT TO CHANGE AT ANYTIME AND DO NOT REFLECT ACTUAL SITE CONDITIONS. NEITHER PARTY SHALL HAVE ANY OBLIGATION OR LIABILITY TO THE OTHER (EXCEPT AS STATED ABOVE), UNTIL A WRITTEN AGREEMENT IS FULLY EXECUTED BY BOTH PARTIES.

Design Forum Architects Inc.
750 W. Pine Road, Suite 400
Cypress Gardens, FL 33884
Phone: 888-272-2710
Fax: 888-272-2710

Design Forum Engineering
750 W. Pine Road, Suite 400
Cypress Gardens, FL 33884
Phone: 888-272-2710
Fax: 888-272-2710

KEY NOTES

1. ELECTRICAL CONTRACTOR TO VERIFY THAT A WEATHERPROOF SWITCH IS PROVIDED BY THE SIGN COMPANY. IF NOT ONE MUST BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR.
2. ELECTRICAL CONTRACTOR TO PROVIDE DIRECT ACCESSIBLE POWER FOR ALL ELECTRICAL SIGNAGE WITHIN 6" OF THE SIGN LOCATION PROVIDE CONDUIT AND STUB THRU WALL, J-BOX AND ANY REQUIRED O.C.P.
3. SWITCH BANK LOCATION: SEE CONTROL ZONE DETAIL ON THIS SHEET. SWITCHES SHALL SERVE AS LOCAL OFF SWITCH.
4. LED LIGHT STRIP MOUNTED TO BOTTOM SIDE OF SHELVES: REFER TO ARCHITECTURAL DETAILS FOR ADDITIONAL MOUNTING INFORMATION.
5. PROVIDE 2A CURRENT LIMITING DEVICE (CLD) #RCLF11BL-TCL2BL. CIRCUIT ALL INDICATED SECTIONS OF TRACK VIA THIS CLD.
6. PROVIDE 3A CURRENT LIMITING DEVICE (CLD) #RCLF11BL-TCL3BL. CIRCUIT ALL INDICATED SECTIONS OF TRACK VIA THIS CLD.
7. OCCUPANCY SENSOR SHALL CONTROL LIGHTS IN ROOM.
8. EXISTING EXTERIOR LIGHTING PROVIDED BY OWNER UNDER SEPARATE CONTRACT AND REPLACED WITH SPECIFICATION INDICATED. MODIFY EXISTING CIRCUITING, FOR BUILDING MOUNTED LIGHTING CONNECTED TO STARBUCKS PANEL, TO ROUTE THROUGH NEW LIGHTING CONTRACTOR (SEE LIGHTING CONTROL DIAGRAM ON E-8001). PROVIDE (2) NEW SCONCES SHOWN AND CONNECT TO SAME CIRCUIT.



1 LIGHTING PLAN
SCALE: 1/4" = 1'-0"

CONTROL ZONE SCHEDULE

- a - BACK BAR/PREP AREA
- b - BACK BAR ACCENT LIGHTS
- c - NON DAYLIT LIGHTS
- d - DECORATIVE LIGHTS
- e - BACK OF HOUSE
- f - DAYLIGHT AREA LIGHTS
- T - 2 HR MAX TIMED OVERRIDE

2 LIGHTING SWITCHBANK DETAIL

Revision Schedule		
Rev	Date	Description

PROJECT NAME:
**CYPRESS GARDENS
BLVD & ROOSEVELT**

PROJECT ADDRESS:
**5709 CYPRESS GARDENS BLVD.
WINTER HAVEN, FL 33884**

STORE #: 50175
PROJECT #: 73763-001
ISSUE DATE: 05/02/2018
PROGRAM MANAGER: ROMINA VIGNOLO
LEED® AP: STARBUCKS
PRODUCTION DESIGNER: MICHAEL B. SARKA
CHECKED BY: ANA COSTANZO

SHEET TITLE:
LIGHTING DESIGN PLAN

SCALE: NOTED

SHEET:
E-1102

Order Plans