



6/28/18

General Notes:

- ALL MOUNTING HEIGHTS TO CENTER LINE OF DEVICE
- COORDINATE ALL CUSTOM RECEPTACLES AND CIRCUITS WITH EQUIPMENT FURNISHED BY OWNER.
- SUPPORT ALL ELECTRICAL CONDUIT, RACEWAY, OUTLET, AND JUNCTION BOXES. DO NOT SECURE ANY ITEMS EXCEPT LIGHT FIXTURES TO CEILING CONSTRUCTION OR SUPPORT WIRES.

Fire Alarm System:

ITEM	SYMBOL	REMARKS
FIRE ALARM CONTROL PANEL	FACP	6" TOP MAX., ADDRESSABLE FIRE ALARM VOICE EVAC SYSTEM WITH DACT
FIRE ALARM ANNUNCIATOR	FANI	MOUNTED AND LOCATED AS DIRECTED BY A.H.J. WHERE APPLICABLE
INDICATING CIRCUIT POWER EXPANDER POWER SUPPLY	ICPE	6" TOP MAX., MOUNTED AND LOCATED AS INDICATED ON SHOP DRAWINGS
FIRE ALARM TERMINAL CABINET	FATM	MOUNTED AND LOCATED AS INDICATED ON SHOP DRAWINGS
CENTRALIZED SITE MONITORING PANEL	DATM	MOUNTED AND LOCATED AS INDICATED ON SHOP DRAWINGS
ADDRESSABLE MANUAL PULL STATION WITH BUILT-IN MODULE	P	WALL MOUNTED 44" CENTER LINE A.F.F.
ADDRESSABLE PHOTO SMOKE DETECTOR	PS	WALL MOUNTED
120 VOLT UNIT SMOKE DETECTOR WITH BATTERY BACKUP	PSB	CEILING MOUNTED, INSTALLATION PER MANUFACTURER'S RECOMMENDATIONS
120 VOLT UNIT SMOKE DETECTOR WITH BATTERY BACKUP	PSB	WALL MOUNTED, INSTALLATION PER MANUFACTURER'S RECOMMENDATIONS
INTELLIGENT SENSOR SOUNDER BASE	ISB	CEILING MOUNTED
CARBON MONOXIDE DETECTOR	CM	CEILING MOUNTED
SMOKE DETECTOR	SD	MOUNTED UNDER FLOOR
ADDRESSABLE MONITOR MODULE	M	
CONTROL RELAY MODULE	CR	
CONTROL MODULE (FOR AUDIBLE/VISUAL SIGNALS)	CM	
ADDRESSABLE DUAL MONITOR MODULE	DM	
DUCT DETECTOR	DD	INSTALLED BY MECHANICAL CONTRACTOR
ADDRESSABLE HEAT DETECTOR	HD	CEILING MOUNTED
SPRINKLER FLOW SWITCH	SFS	FURNISHED BY OTHERS
SPRINKLER TAMPER SWITCH	STS	FURNISHED BY OTHERS
SPRINKLER BELL, 110V.	S	FURNISHED BY OTHERS
FIRE FIGHTER JACK	FJ	STAINLESS STEEL PLATE MOUNTED AT 44" A.F.F.
LIGHTNING SUPPRESSOR	LS	
KNOX BOX	K	F.B.O., MOUNTED AND LOCATED AS DIRECTED BY A.H.J. WHERE APPLICABLE
DOOR HOLDER	DH	FLUSH MOUNTED, SEE DOOR SCHEDULE
AUXILIARY RELAY	R	
SURGE SUPPRESSOR	SS	FURNISHED BY OTHERS 120V AC SURGE SUPPRESSOR
DOOR HOLDER POWER SUPPLY	DHPS	MOUNTED AND LOCATED AS INDICATED ON SHOP DRAWINGS
REMOTE MICROPHONE	RM	
END OF LINE RESISTOR	ELR	FURNISHED WITH CONTROL PANEL OR MODULES
SPEAKER, 1/2 WATT TAP U.O.N.	SP	WALL MOUNTED, 90" TOP A.F.F. MINIMUM AND NO LESS THAN 6" FROM CEILING
SPEAKER, 1/2 WATT TAP U.O.N.	SP	CEILING MOUNTED
MULTI-CANDELA SPEAKER WITH STROBE	MCS	WALL MOUNTED, 80" BOTTOM A.F.F.
MULTI-CANDELA SPEAKER / STROBE	MCS	CEILING MOUNTED
MULTI-CANDELA STROBE ONLY	MCS	WALL MOUNTED, 80" BOTTOM A.F.F.
MULTI-CANDELA STROBE ONLY	MCS	CEILING MOUNTED
APARTMENT HORN	AH	WALL MOUNTED, 90" TOP A.F.F. MINIMUM AND NO LESS THAN 6" FROM CEILING
HORN ONLY	H	WALL MOUNTED, 90" TOP A.F.F. MINIMUM AND NO LESS THAN 6" FROM CEILING
MULTI-CANDELA HORN WITH STROBE	MCHS	WALL MOUNTED, 80" BOTTOM A.F.F.
MULTI-CANDELA HORN WITH STROBE	MCHS	CEILING MOUNTED
MULTI-CANDELA HORN ONLY	MCH	WALL MOUNTED
MULTI-CANDELA HORN ONLY	MCH	CEILING MOUNTED
SMOKE DETECTION	SD	AS REQUIRED
CONTROL PANEL	CP	
WEATHERPROOF PULL BOX (NO SIGNALS)	WP	AS SHOWN ON SITE PLAN
WEATHERPROOF JUNCTION BOX	WP	AS SHOWN ON SITE PLAN
INTERCOM STATION	IC	44" AFF
AUDIBLE DOOR ALARM SOUNDER	ADR	
FIRE ALARM RELAY	FAR	< 3' FROM DOOR LOCK HARDWARE POWER SUPPLY

Telephone / Television Systems:

ITEM	SYMBOL	REMARKS: UNLESS OTHERWISE NOTED, MOUNTING HEIGHTS TO CENTER LINE
TELEPHONE OUTLET	TO	WALL MOUNTED, 18" A.F.F.
TELEPHONE OUTLET	TO	WALL MOUNTED, 44" A.F.F.
TELEPHONE FLOOR OUTLET	TF	FLUSH FLOOR MOUNTED
DATA WALL OUTLET	DWO	WALL MOUNTED, 18" A.F.F.
DATA FLOOR OUTLET	DF	FLUSH FLOOR MOUNTED
TELEPHONE / DATA WALL OUTLET	TDO	WALL MOUNTED, 18" A.F.F.
TELEPHONE / DATA FLOOR OUTLET	TDF	FLUSH FLOOR MOUNTED
TELEVISION OUTLET	TV	WALL MOUNTED, 18" A.F.F.
TELEVISION / PHONE OUTLET	TPO	WALL MOUNTED, 18" A.F.F.
TELEVISION / DATA OUTLET	TDO	WALL MOUNTED, 18" A.F.F.
TELEVISION / DATA / PHONE OUTLET	TDP	WALL MOUNTED, 18" A.F.F.
TELEVISION FLOOR OUTLET	TF	FLUSH FLOOR MOUNTED
TELEVISION / PHONE FLOOR OUTLET	TPO	FLUSH FLOOR MOUNTED
TELEVISION / DATA FLOOR OUTLET	TDF	FLUSH FLOOR MOUNTED
TELEVISION / DATA / PHONE FLOOR OUTLET	TDP	FLUSH FLOOR MOUNTED
DEMARC LOCATION	DL	MOUNTED 54" A.F.F. TO CENTER
WIRELESS ACCESS POINT	WAP	CEILING MOUNTED
MULTI-SYSTEM DISTRIBUTION	MSD	
HAX PLATE	HAX	
TELEPHONE ENTRY DEVICE	TE	44" AFF

Electrical Receptacles:

ITEM	SYMBOL	REMARKS: UNLESS OTHERWISE NOTED, MOUNTING HEIGHTS TO CENTER LINE
DUPLEX RECEPTACLE	DR	WALL MOUNTED, 18" A.F.F.
DUPLEX RECEPTACLE, COUNTERTOP	CDR	WALL MOUNTED, 44" A.F.F. ABOVE COUNTER
DUPLEX RECEPTACLE TOP HALF CONTROLLED VIA WALL SWITCH	DR	WALL MOUNTED, 18" A.F.F.
DUPLEX RECEPTACLE TOP HALF CONTROLLED VIA WALL SWITCH	DR	WALL MOUNTED, 44" A.F.F. ABOVE COUNTER
DOUBLE DUPLEX RECEPTACLE	DDR	WALL MOUNTED, 18" A.F.F.
DOUBLE DUPLEX RECEPTACLE	DDR	WALL MOUNTED, 44" A.F.F. ABOVE COUNTER
SPECIAL PURPOSE OUTLET	SP	WALL MOUNTED, AMPERE CAPACITY AS INDICATED
DUPLEX RECEPTACLE IN FLUSH FLOOR BOX	DF	FLOOR COVER TO BE FLUSH WITH FINISHED FLOOR
DUPLEX WITH GROUND FAULT INTERRUPTER	DFGFI	WALL MOUNTED, 18" A.F.F.
DUPLEX WITH GROUND FAULT INTERRUPTER	DFGFI	WALL MOUNTED, 44" A.F.F. ABOVE COUNTER
DUPLEX WITH GROUND FAULT INTERRUPTER	DFGFI	WALL MOUNTED, 18" A.F.F.
DUPLEX WITH GROUND FAULT INTERRUPTER	DFGFI	WALL MOUNTED, 44" A.F.F. ABOVE COUNTER
SINGLE RECEPTACLE	SR	WALL MOUNTED, 18" A.F.F.
USB RECEPTACLE	UR	WALL MOUNTED, 18" A.F.F.
USB RECEPTACLE	UR	WALL MOUNTED, 44" A.F.F. ABOVE COUNTER
SINGLE, 250V NON-LOCKING TYPE RECEPTACLE	SR	WALL MOUNTED, REFER TO PANEL SCHEDULE FOR AMPERAGE AND FLOOR PLAN FOR MOUNTING HEIGHT
JUNCTION BOX	JB	4" SQ. x 2-1/8" D WITH BLANK COVER
CEILING RATED JUNCTION BOX	CRJB	CEILING MOUNTED
DUPLEX WITH GROUND FAULT INTERRUPTER / WEATHER PROOF	DFGFIWP	WALL MOUNTED, 18"

Electrical Switches:

ITEM	SYMBOL	REMARKS: UNLESS OTHERWISE NOTED, MOUNTING HEIGHTS TO CENTER LINE
LIGHT SWITCH, 2 POLES SINGLE POLE	LS	WALL MTD. 44" A.F.F.
DIMMER SWITCH	DS	WALL MTD. 44" A.F.F.
THREE WAY SWITCH	TS	WALL MTD. 44" A.F.F.
FOUR WAY SWITCH	FS	WALL MTD. 44" A.F.F.
DOUBLE POLE SWITCH	DS	AS NOTED
KEY SWITCH	KS	WALL MTD. 44" A.F.F.
SWITCH WITH PILOT LIGHT	SL	AS NOTED
MOTOR RATED SINGLE POLE	MS	AS NOTED
OCCUPANCY SENSOR SWITCH	OS	WALL MTD. 44" A.F.F.
OCCUPANCY SENSOR SWITCH (CEILING MOUNTED)	OS	
PHOTO-ELECTRIC SWITCH (PHOTOCELL)	PE	MOUNTED AS INDICATED
TIMECLOCK	TC	SURFACE MOUNTED
EMERGENCY BATTERY PACK	EBP	
LIGHTING CONTROL POWER PACK	LCPP	MOUNTED ABOVE CEILING
DOOR BELL CHIME	DB	MOUNTING HEIGHT AS INDICATED
DOOR BELL CHIME WITH SIGNAL	DBS	MOUNTING HEIGHT AS INDICATED
POWER PACK	PP	

Drawing Index:

Drawing Number	Drawing Title	Revised	By	Date
E0.01	Electrical Legend and Symbols			06/29/18
E0.02	Light Fixture Schedule			06/29/18
E1.01	Electrical Site Plan			06/29/18
E1.02	Electrical Floor Schedule & Details			06/29/18
E1.03	Electrical Panel Schedules			06/29/18
E1.04	Electrical Panel Schedules			06/29/18

Legend:
 - Reissued Sheet / No Change
 - Deleted from Set

Abbreviations:

A	AMPERES
AFCI	ARC FAULT CIRCUIT INTERRUPTER
AFI	ABOVE FINISHED FLOOR
AFG	ABOVE FINISHED GRADE
AHJ	AUTHORITY HAVING JURISDICTION
AIC	AMPERES INTERRUPTING CAPACITY
AL	ALUMINUM
ATS	AUTOMATIC TRANSFER SWITCH
AWG	AMERICAN WIRE GAUGE
C	COUNTERTOP
CFI	CONTRACTOR FURNISHED, CONTRACTOR INSTALLED
CFOI	CONTRACTOR FURNISHED, OWNER INSTALLED
CU	COPPER
CUS	CEILING
DAS	DISTRIBUTED ANTENNA SYSTEM
EC	ELECTRICAL CONTRACTOR
EM	EMERGENCY
EP	EXPLOSION PROOF
EX	EXISTING TO REMAIN
F	FUSED
FBO	FURNISHED BY OTHERS
G	GROUND
GF	GROUND FAULT
GFP	GROUND FAULT PROTECTED
GRC	GALVANIZED RIGID CONDUIT
H	HORIZONTAL
HP	HORSEPOWER
KCMIL	THOUSAND CIRCULAR MILS
KVA	KILOVOLT - AMPERES
KW	KILOWATT
LT	LIQUID TIGHT FLEXIBLE METAL CONDUIT
MTG	MOUNTING
N	NEUTRAL
NEC	NATIONAL ELECTRICAL CODE
NF	NON-FUSED
NIC	NOT IN CONTRACT
NL	NIGHT LIGHT
OFOI	OWNER FURNISHED, OWNER INSTALLED
OFCI	OWNER FURNISHED, CONTRACTOR INSTALLED
PVC	POLYVINYL CHLORIDE RACEWAY
UNO	UNLESS OTHERWISE NOTED
V	VOLTS
W	WALL MOUNT
WP	WEATHERPROOF

Security / CCTV / Access Control:

ITEM	SYMBOL	REMARKS: UNLESS OTHERWISE NOTED, MOUNTING HEIGHTS TO CENTER LINE
DOOR CONTACT	DC	ON DOOR/FRAME
POWER SUPPLY	PS	54" AFF
ACCESS CONTROL READER	CR	WALL MOUNTED, 44" A.F.F.
COMPUTER	CP	
PUSH EXIT TO BUTTON	PB	
REQUEST TO EXIT MOTION	RE	8" ABOVE FLOOR
ELECTRIC STRIKE	ES	
MAGLOCK	ML	
TELEPHONE ENTRY	TE	
ACCESS CONTROL UNIT	ACU	
DIGITAL VIDEO RECORDER (DVR)	DVR	
CAMERA (PAN / TILT / ZOOM)	CA	
SECURITY SIREN	S	
SECURITY KEYPAD	KP	WALL MOUNTED, 44" A.F.F.
SECURITY PANEL	SP	
SECURITY MOTION DETECTOR	MD	WALL MOUNTED AS INDICATED ON DRAWINGS
SECURITY MOTION DETECTOR	MD	CEILING MOUNTED AS INDICATED ON DRAWINGS
GLASS BREAK	GB	
SPEAKER	SP	CEILING MOUNTED
SPEAKER	SP	WALL MOUNTED
HEADEND SOUND SYSTEM	SS	
VOLUME CONTROL	VC	WALL MOUNTED, 44" A.F.F.
BARCODE READER	BR	
PANIC HARDWARE WITH INTEGRATED KEY	PH	ON DOOR
HANDICAP PUSH BUTTON	HP	44" AFF
LONG RANGE RF RECEIVER	LR	
POWER TRANSFER HINGE	PTH	CENTER HINGE OR BOTTOM CENTER HINGE
ELECTRIFIED HARDWARE, PANIC BAR WITH BUILT IN SWITCH FOR MAGLOCK RELEASE	EH	ON DOOR

Miscellaneous Electrical Devices:

ITEM	SYMBOL	REMARKS: UNLESS OTHERWISE NOTED, MOUNTING HEIGHTS TO CENTER LINE
LOAD CENTER	LC	SURFACE MOUNTED TOP AT 6'-0" A.F.F.
DISTRIBUTION PANELBOARD	DP	SURFACE MOUNTED TOP AT 6'-0" A.F.F.
NON-FUSED DISCONNECT SWITCH SIZE AND TYPE AS NOTED	NS	SURFACE MOUNTED TOP AT 6'-0" A.F.F.
FUSED DISCONNECT SWITCH SIZE AND TYPE AS NOTED	FS	SURFACE MOUNTED TOP AT 6'-0" A.F.F.
MOTOR STARTER	MS	
COMBINATION MOTOR STARTER	MS	
CONDUIT / CABLE (RUN EXPOSED)	C	HATCH MARKS INDICATE NUMBER OF CONDUITS
CONDUIT / CABLE (RUN CONCEALED)	C	HATCH MARKS INDICATE NUMBER OF CONDUITS
CONDUIT / CABLE HOME RUN, EXPOSED, CONCEALED OR UNDERGROUND AS INDICATED ON PLANS	C	(3) HOTS WITH NEUTRAL
	C	(2) HOTS WITH NEUTRAL
	C	(1) HOTS WITH NEUTRAL
	C	(3) HOTS, NO NEUTRAL
	C	(2) HOTS, NO NEUTRAL
	C	EQUIPMENT GROUND #12, UNLESS OTHERWISE NOTED
TRANSFORMER	T	
ELECTRICAL MOTOR, H.P. AS NOTED	M	AS NOTED
GROUND CONNECTION	G	SIZE AS NOTED ON PLANS
ELECTRICAL CODED NOTE	CN	SEE RESPECTIVE DRAWING
OWNER FURNISHED EQUIPMENT	OFE	SEE EQUIPMENT SCHEDULE
VARIABLE FREQUENCY DRIVE	VFD	FURNISHED BY OTHERS
RELAY	R	
PULL BOX	PB	SIZE AS INDICATED ON DRAWINGS
TYPICAL ROAD CROSSING OR SLEEVE	RS	
BATHROOM EXHAUST FAN	BEF	FURNISHED BY OTHERS
GARBAGE DISPOSAL UNIT	GPU	FURNISHED AND INSTALLED BY OTHERS

Electrical Lighting:

ITEM	SYMBOL	REMARKS
2'x4' FLUORESCENT	FL	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
2'x2' FLUORESCENT	FL	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
2'x4' DOUBLE FLUORESCENT	FL	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
2'x4' SINGLE FLUORESCENT	FL	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
2'x4' FLUORESCENT (WALL MOUNTED)	FL	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
4' FLUORESCENT STRIP	FL	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
RECESSED DOWNLIGHT	DL	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
RECESSED DOWNLIGHT	DL	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
SURFACE MOUNTED DOWNLIGHT	DL	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
WALL WASHER	WW	SEE LIGHTING FIXTURE SCHEDULE
WALL WASHER - SMALL	WW	SEE LIGHTING FIXTURE SCHEDULE
PUCK LIGHT	PL	SEE LIGHTING FIXTURE SCHEDULE
PENDANT MOUNTED FIXTURE - SMALL	PF	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
PENDANT MOUNTED FIXTURE	PF	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
PENDANT MOUNTED FIXTURE - LARGE	PF	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
CHANDIELIER - SMALL	CH	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
CHANDIELIER	CH	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
WALL MOUNTED FIXTURE - ROUND	WF	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
WALL MOUNTED FIXTURE - SQUARE	WF	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
WALL MOUNTED FIXTURE - STRIP	WF	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
EXIT LIGHT	EL	SEE LIGHTING FIXTURE SCHEDULE
COMBINATION EXIT EMERGENCY LIGHT	EL	SEE LIGHTING FIXTURE SCHEDULE
EMERGENCY LIGHT WITH BATTERY BACK-UP	EL	SEE LIGHTING FIXTURE SCHEDULE
CEILING FAN / LIGHT	CF	SEE LIGHTING FIXTURE SCHEDULE
CEILING FAN / LIGHT	CF	SEE LIGHTING FIXTURE SCHEDULE
PENDANT MOUNTED TRACK LIGHT	PTL	SEE LIGHTING FIXTURE SCHEDULE
VANITY FIXTURE	VF	SEE LIGHTING FIXTURE SCHEDULE
TRACK LIGHTING	TL	SEE LIGHTING FIXTURE SCHEDULE
RECESSED FLOOR LIGHT	FL	SEE LIGHTING FIXTURE SCHEDULE
POLE LIGHT - SQUARE	PL	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
POLE LIGHT - ROUND	PL	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
POLE LIGHT - SERPENT	PL	SEE LIGHTING FIXTURE SCHEDULE HATCHED CENTER - ON EMERGENCY
BOLLARD - ROUND	BL	SEE LIGHTING FIXTURE SCHEDULE
BOLLARD - SQUARE	BL	SEE LIGHTING FIXTURE SCHEDULE
BOLLARD - ACORN	BL	SEE LIGHTING FIXTURE SCHEDULE
UPLIGHT	UL	SEE LIGHTING FIXTURE SCHEDULE
STEP LIGHT	SL	SEE LIGHTING FIXTURE SCHEDULE
STEP LIGHT - LONG	SL	SEE LIGHTING FIXTURE SCHEDULE

Naming Convention:

FEEDER AMPERE RATING, REFER TO RISER DIAGRAM FEEDER SCHEDULE FOR ADDITIONAL INFORMATION

CONDUCTOR DESIGNATION:
 'N' - NEUTRAL CONDUCTOR
 'G' - GROUNDING CONDUCTOR

AMPERE SIZE

NO. OF POLES

SIZE OF FUSE

CIRCUIT NUMBER

FIXTURE DESIGNATION:
 'Ax' - AMENITIES FIXTURE
 'Bx' - BUILDING FIXTURE
 'Gx' - GARAGE FIXTURE
 'Sx' - SITE FIXTURE
 'Ux' - UNIT FIXTURE

PROGRESSIVE ALPHA TAG FOR MULTIPLE PANELS OF THE SAME TYPE THAT ARE LOCATED ON THE SAME LEVEL (A,B,C, ETC.)

DESIGNATE LEVEL PANEL / EQUIPMENT IS LOCATED ON - THE LEVEL DESIGNATION SHOULD CORRESPOND WITH THE ARCHITECT'S DESIGNATION OF FLOOR LEVELS (G1, G2, 1, 2, ETC.)

INDICATE VOLTAGE:
 'L' - 120/208 VOLTS, 3Ø, 4W
 'H' - 277/480 VOLTS, 3Ø, 4W

DESIGNATES TYPE OF EQUIPMENT:
 BLANK - PANEL
 MSB - MAIN SWITCHBOARD
 MS - MAIN SWITCH
 MCC - MOTOR CONTROL CENTER
 MC - METER CENTER

DESIGNATES SOURCE OF POWER:
 BLANK - NORMAL POWER
 E - EMERGENCY POWER

DESIGNATES BUILDING (IF MULTIPLE BUILDINGS) THAT THE PANEL / EQUIPMENT IS LOCATED IN THE DESIGNATION SHOULD CORRESPOND WITH THE ARCHITECT'S BUILDING NAMING CONVENTION



PDI - PLAZA
1000 118th Ave North
Saint Petersburg, FL 33716

CADD Technician: E. Cruz	Date Signed:
Designer: A. Sirez	Date Issued: June 29, 2018
Engineer: A. Zotescu	Sheet Number: E0.01

Order Plans